

Vendor Product Manual - 3MW Standby Generator Set

Supplier: VEND-CATERPILLAR | Target Equipment: EQ-GEN-303

Performance Parameters: Automatic Transfer Switch (ATS) command loop initiates complete crank within 8.5 seconds.

Engine Constants: Synchronous alternator arrays hold continuous load profile at 1500 RPM with 50Hz stability.

Parameter	Value	Notes / Tolerance
Rated Output	3 MW	Matches client mandate
ATS Transfer Time	8.5 seconds	Within 10s client ceiling
Governed Speed	1500 RPM	Matches client mandate
Rated Frequency	50 Hz	+/- 0.5% steady state