

Vendor Product Manual - 3MW Standby Generator Set

Supplier: VEND-CATERPILLAR | Target Equipment: EQ-GEN-303

This manual addresses requirements REQ-GEN-001 and REQ-GEN-002.

Performance Parameters: Automatic Transfer Switch (ATS) command loop initiates complete crank within 8.5 seconds.

Engine Constants: Synchronous alternator arrays hold continuous load profile at 1500 RPM with 50Hz stability.

Req ID	Parameter	Value	Notes / Tolerance
REQ-GEN-001	Rated Output	3 MW	Matches client mandate
REQ-GEN-001	ATS Transfer Time	8.5 seconds	Within 10s client ceiling
REQ-GEN-002	Governed Speed	1500 RPM	Matches client mandate
REQ-GEN-002	Rated Frequency	50 Hz	+/- 0.5% steady state