

Client Specification - Direct Current Storage Architecture

Project: PRJ-MUM-2026 | Code: SPEC-ELE-004

Requirement: Valve-Regulated Lead-Acid (VRLA) cell layouts must fulfill 15 minutes of uninterrupted autonomy.

Mandate: Individual battery modules must support stable operating ambient thresholds of 22 degrees Celsius.

Req ID	Parameter	Value	Notes / Tolerance
REQ-BATT-001	Autonomy	15 minutes	At full rated UPS load
	Cell Chemistry	VRLA	Valve-Regulated Lead-Acid
REQ-BATT-002	Ambient Operating Temp	22 C	+/- 2 C for rated life
	Design Life	10 years	At rated ambient temp