

Client Specification - Uninterruptible Power Supply

Project: PRJ-MUM-2026 | Code: SPEC-ELE-001

Requirement: Emergency backup topology must utilize Tier III concurrent maintainability configurations.

Mandate: Static UPS modules must exhibit energy efficiency rating $\geq 96.5\%$ at a 50% partial load threshold.

Electrical Constants: Input operating voltage fixed at 415V, 3-Phase, 50Hz infrastructure.

Req ID	Parameter	Value	Notes / Tolerance
	Rated Capacity	300 kVA / 270 kW	Per module, N+1 config
REQ-UPS-001	Efficiency @ 50% Load	$\geq 96.5\%$	Minimum acceptance threshold
REQ-UPS-002	Input Voltage	415 V, 3-Phase	+/- 10% tolerance
REQ-UPS-002	Input Frequency	50 Hz	+/- 2% tolerance
	Battery Autonomy	10 minutes	At full rated load
REQ-UPS-003	Topology	Double Conversion, Tier III	Concurrently maintainable