

Vendor Maintenance Manual - Downflow Thermal Units

Supplier: VEND-VERTIV | Target Equipment: EQ-CRAH-505

This manual addresses requirement REQ-CRAH-001.

Operations Directive: Electronically commutated (EC) fans modulate response speeds via centralized BMS networks.

Humidity Range: Handles internal moisture tracking boundaries from 35% to 60% efficiently.

Req ID	Parameter	Value	Notes / Tolerance
	Fan Type	EC (Electronically Commutated)	BMS-integrated
REQ-CRAH-001	Humidity Range	35% - 60%	Wider than 40-55% client spec
	Airflow Configuration	Downflow	Matches spec
	Maintenance Interval	6 months	Filter + fan bearing check