

RFI-024: Structural Coordination Resolution

Status: CLOSED | Action Domain: ACT-E10

Description: Physical routing overlap discovered between overhead chilled lines and the main electrical busway near EQ-UPS-101.

Resolution Directive: Structural engineering teams approved lowering water line hangers by 300mm. Electrical busways maintain original elevations.