

Quality Inspection Field Report - EQ-BATT-404

Target Component Tracked: EQ-BATT-404 | Inspector: S. Menon | Date: 2026-03-22

Inspection Class: Structural Safety & Pre-Installation Sign-off.

Status: ACCEPTED

Battery rack seismic bracing torque-checked on all cross-members, within spec.

Ambient room temperature at time of inspection: 21.8C, within the 22C +/- 2C design band.

No electrolyte staining or terminal corrosion observed on any cell.