

Quality Inspection Field Report - EQ-CHILL-202

Target Component Tracked: EQ-CHILL-202 | Inspector: R. Iyer | Date: 2026-03-18

Inspection Class: Structural Safety & Pre-Installation Sign-off.

Status: ACCEPTED WITH REMARKS

Vibration isolation pads correctly seated on all 4 compressor mounting legs.

Condensate drain slope measured at 1.2%, marginally below the 1.5% design recommendation -- flagged for re-grading before final tie-in.

Refrigerant line insulation intact, no visible gaps.