

Commissioning Level 5 Functional Test Report: EQ-BATT-404

System Asset Identifier: EQ-BATT-404

Execution Stage: Level 5 Integrated Systems Testing (IST).

Acceptance Matrix Criteria: Verification of localized control interfaces, failsafe loops, and automatic failovers.

Status: PASS

Status Summary: Discharge test completed at full rated load. Autonomy measured at 16.2 minutes, exceeding the 15-minute design mandate.