

Commissioning Level 5 Functional Test Report: EQ-GEN-303

System Asset Identifier: EQ-GEN-303

Execution Stage: Level 5 Integrated Systems Testing (IST).

Acceptance Matrix Criteria: Verification of localized control interfaces, failsafe loops, and automatic failovers.

Status: PROVISIONAL PASS - EXTENDED MONITORING REQUIRED

Status Summary: Initial steady-state load evaluation (first ~35 minutes) showed voltage, frequency, and core temperature within standard performance boundaries. However, the test was run on a compressed schedule and did not complete a full sustained-load endurance cycle. Continuous BMS/SCADA telemetry monitoring was left active post-test as a condition of this provisional sign-off, pending a full extended load test to be scheduled before final handover. Any deviation flagged by continuous monitoring supersedes this provisional result.