

Client Specification - Mechanical Cooling Plant

Project: PRJ-MUM-2026 | Code: SPEC-MECH-002

Requirement: Chilled water distribution systems must maintain continuous N+1 redundancy.

Mandate: Maximum operational power draw profile cannot exceed 45kW per compressor fan unit.

Fluid Dynamics: Chilled water delivery set point configured precisely to 7.2 degrees Celsius.