

Client Specification - Computer Room Air Handler System

Project: PRJ-MUM-2026 | Code: SPEC-MECH-005

Requirement: Precision CRAH frameworks must enforce downflow variable speed fan controls.

Mandate: Moisture profiles must stay within 40% to 55% relative humidity to meet design baselines.