

Client Specification - Emergency Backup Generation

Project: PRJ-MUM-2026 | Code: SPEC-ELE-003

Requirement: Standby diesel generators must kick in and assume critical facility load inside a maximum of 10 seconds.

Mandate: Engine speed must dynamically govern at 1500 RPM to sustain steady 50Hz frequency output.

Emissions: Exhaust treatment configurations must pass regional environmental safety metrics.