

Project ID: PRJ-MUM-2026

Document Ref: SPEC-ELE-UPS-001

Section 4.2: Uninterruptible Power Supply (UPS) Requirements

1. System Architecture: Must achieve Uptime Institute Tier III concurrent maintainability.
2. Operational Efficiency: The static UPS system must maintain an efficiency rating of greater than 96.5% when operating under a 50% load threshold.
3. Electrical Rating: Input voltage must match 415V, 3-Phase, 50Hz infrastructure.