

Client Specification - Uninterruptible Power Supply

Project: PRJ-MUM-2026 | Code: SPEC-ELE-001

Requirement: Emergency backup topology must utilize Tier III concurrent maintainability configurations.

Mandate: Static UPS modules must exhibit energy efficiency rating $\geq 96.5\%$ at a 50% partial load threshold.

Electrical Constants: Input operating voltage fixed at 415V, 3-Phase, 50Hz infrastructure.