

RFI-024: Structural & Electrical Clash Resolution

Request For Information: RFI-ELE-024

Subject: Spatial Clash in Zone B Electrical Room

Status: CLOSED

Description: Field survey indicates an physical routing conflict between the main overhead 48-inch chilled water supply pipe and the incoming electrical busway pathway above Row G.

Resolution Response: Structural teams have approved lowering the chilled water pipe hanger configuration by 300mm. Electrical layout will maintain priority overhead line of sight. This modification must be logged against schedule task ACT-E10.