

CERTIFICATE OF ANALYSIS

Product: PAC 10

Product Description: PAC 10LB Solution 1200KG

Product Code: PAC10LB-1000

Batch Number: R1.69.2024

Delivery Number:

Date of Testing: 25/11/2024

Date of expiry: 25/11/2025

Parameter	Specification	Units	Result
Al2O3	10-11	%	10.98
Chloride	9-11	%	10.45
SG	1.18-1.22	-	1.205
pH	2.2-2.8	-	2.75

Site of manufacture: Ixom Wyong

Contact:

Email: ixom.certs@ixom.com

Ph: AU 1300 550 036 NZ 0800 22 22 77

*This certificate of conformance is generated electronically. No signature is required.



IXOM OPERATIONS PTY LTD.

1 NICHOLSON STREET,

EAST MELBOURNE VIC 3002

PH: 1300 550 036 FAX: 1300 550 081

IXOM.COM

IXOM OPERATIONS PTY LTD.

166 TOTARA STREET

MT MAUNGANUI

NEW ZEALAND

Phone: 0800 22 22 77

IXOM.COM

24 HR EMERGENCY RESPONSE SERVICE

Australia 1800 033 111

New Zealand 0800 754 607

International +61 (0)3 9663 2130

ACN 120 540 511