



Certificate of Conformance

Product Description: PAC 10LB SOLUTION 1200KG
Product Code: PAC10LB-1000
Batch: R1.42.2025
Date of Manufacture: 20.06.2025
Date of Expiry: 20.06.2027
Site of Manufacture/Origin: N118 Watercare - Wyong
Inspection Lot: 130000004394
Date of Issue: 24.06.2025
Authorised by: Quality Representative

RESULTS

Parameter	Specification	Units	Conforms
pH	2.20 - 2.80		YES
SG @15°C	1.180 - 1.220		YES
Al ₂ O ₃	10.00 - 11.00	% w/w	YES
Chloride	9.00 - 11.00	%	YES

This Certificate of Conformance is generated electronically. No signature is required.

This certificate relates specifically to the sample(s) that were drawn and/or provided to Ixom Operations Pty Ltd or its agent or contractor. The information specified in this certificate provide no warranty, guarantee or verification on the sample(s) representing any specific goods and/or shipment of goods and only relate to the sample(s) as received and tested by or on behalf of Ixom Operations Pty Ltd. This certificate is valid as at the date and time of issue. The customer is advised to review the information set out in this certificate in the specific context of its intended application. To the maximum extent permitted by law, Ixom Operations Pty Ltd and its related bodies corporate exclude any and all loss and damage of whatsoever nature arising out of or in connection with the use of or reliance upon this certificate. It is the exclusive responsibility of the customer to undertake its own inquiries to ensure that the sample to which information in this certificate relates is fit or suitable for its uses, purposes, applications, processes or equipment.

IXOM

IXOM OPERATIONS PTY LTD.
1 NICHOLSON STREET,
EAST MELBOURNE VIC 3002
PH: 1300 550 036 FAX: 1300 550 081
ixom.com

IXOM OPERATIONS PTY LTD.
166 TOTARA STREET
MT MAUNGANUI
NEW ZEALAND
Phone: 0800 22 22 77
ixom.com

24 HR EMERGENCY RESPONSE SERVICE

Australia
1800 033 111
New Zealand
0800 734 607
International
+61 (0)3 9663 2130

ACN: 600 546 512