Interactive comment to "The Aerosol Limb Imager: acousto-optic imaging of limb scattered sunlight for stratospheric aerosol profiling" by B. J. Elash et al

> B. J. Elash et al. (brenden.elash@usask.ca) February 18, 2016

We would like to thank the referee for their helpful comments and suggestions. Below are the referee's comments in italics followed by our reply. A full list of changes can be seen in the attached file.

1) I am not sure that the introduction section should be so long. To me, regarding the scope of the paper, the not-so-concise discussion on previous limb missions having measured stratospheric aerosols is not helping in appreciating the work done here. Shortening this part could free some space for some missing information in the calibration section or for the error analysis.

Reply: The discussion of previous aerosol missions is quite relative in regard to the work presented here. The motivating work behind ALI is to eventually use an ALI type instrument on a microsat mission to continue the global aerosol record. This record has been used recently to infer climate altering effects and sources of additional stratospheric aerosol through small volcanic eruptions with the use of serval measurement techniques. Outlining this information in detail is fundamental to understanding the purpose behind the ALI instrument and its mission.

2) p. 13290, l. 23-24: the width of the spectral transmission function of an AOTF is something which is frozen at the manufacturing step, i.e. when the crystal cutting angles are frozen. In that sense, there is no such thing like typical bandwidths, as one can design an AOTF with a 5-10 times narrower or broader bandpass.

Reply: Yes this is correct and the phrasing of this sentence does not adequately reflect this possibility of the AOTF design, as such the sentence has been reworded into the following: "Additionally, the spectral bandpass of the AOTF has reasonable resolutions at these wavelengths, such as 3–6 nm, which is very suitable for the broadband scattering characteristics of the aerosol limb signal."

Reply: Noted and has been corrected.

³⁾ p. 13291, l. 24: The acoustic wave in this kind of device is not a standing wave. In TeO2 AOTF, it is a shear wave mostly absorbed at the opposite end of the crystal.

4) AOTF design. There is an extensive discussion on the selection of the most appropriate optical design which is well argued. However, I wonder why the rear facet of the AOTF was cut such as depicted in fig.2 (by the way, replace "standing RF" by "acoustic" in this figure). From the moment it is decided to work with the e-light as input, a better configuration could have been found where the diffracted beam remains parallel to the incident axis and a larger angular separation is achieved with the 0-order. This is important because with a half-FOV of 3, and taking into account your drawing and the fact that the diffracted beam leaves the crystal with an angle of 2.7, there should be a significant overlapping of the 0th and 1st orders... Could you better justify this design choice in the text?

Reply: The geometry in Fig. 2 is meant to be representation of the diffraction interactions within the AOTF and not accurate to physical geometry and the text has been changed to "A representative AOTF..." and the phase "standing RF" and been replaced with "acoustic". Although the diffraction angle is 2.7° the separation between the zeroth and first order is at minimum 6.4° which alleviates any concern with 0th order and 1st order overlap. The addition of the separation angle has been added into the text in the following sentence "...in this way and is diffracted 2.7 from the input optical axis of the device with a minimum separation angle of 6.4° between the zeroth and first order." (pg 13293, line 18). As for 2.7° offset and not having the light propagate straight through the system was just a feature of the AOTF that we purchase from the selection available at the time of purchase.

Reply: A complete radiometric model is outside of the scope of the work presented here. Additional detail will be provided the in the results section outlining where the primary error terms arise in the formation of the measurement vector and how this effect the final uncertainty estimation.

⁵⁾ I think the section 2.2 should contain a proper mathematical description of the radiometric model of the instrument, including the spectral transmission function, the polarization sensitivity and other effects such as PRNU. This would certainly help in understanting the impact of the calibration uncertainties when discussing the error budget.

⁶⁾ p. 13299, l. 14-15: I would not say that 1.2nm is much less than

the AOTF spectral resolution. You indeed performed a characterization of the spectral transmission function of the AOTF with a not-exactly monochromatic light source. In the end you got a result (fig.6a) which is the convolution of the incident light spectrum and the AOTF response. The typical sidelobes are not completely resolved, but this is not really an issue for your calibration as the results seem perfectly in line with standard AOTF performance. I would recommend next time to work with sharp emission lines or laser lines at some selected wavelengths, and rely on the physics of acousto-optic interaction to extrapolate the AOTF response function between the calibration points.

Reply: This will be noted for future work involving the ALI instrument, but a complete spectral calibration performed here helps verify the working range of the device and thus why it was used. As well using a full calibration uses an more exact wavelength calibration then theory which uses some approximations to yield the final form commonly used.

7) Section 3.1: Why didn't you use a physical model to fit the experimental data with the AOTF tuning curve? This would provide a better understanding of the overall instrument. Also, as the F(lambda) relationship is dependent on the crystal temperature, it would be usefull to compare the temperature in the lab when the calibration of the instrument was done with the temperature of the crystal during the flight. Again, a physical model of the AOTF would help in extrapolating the calibration to other working temperatures. The reported 0.1% error in the fit can yield an uncertainty as high as 1nm. A 10C shift of temperature would also yield a 1nm drift. Is this still tolerable for your measurements? More details on the precision of the wavelength selection would be appreciated.

Reply: A physical model was not selected since since a full wavelength calibration was performed with a spectrometer an an curve could be used to fit the entire wavelength range that was being used by the instrument during the flight. It is understandable that a 0.1% error in the wavelength calibration results in a maximum error of 1 nm in the calibrated wavelength, furthermore the difference between the the estimated AOTF flight temperature during flight and the lab calibration was approximately 15°C which adds an additional uncertainty of approximately 1.5 nm for a total of approximately 2.5 nm. With the slowly varying broadband scattering effects of

aerosol this error in the wavelength is not a large concern for this prototype. The text has been modified in the following way to clarify these concerns with the addition of the following sentence "...(see Fig. 6b). Even with considering the temperature change the AOTF would experience during the mission compared to the lab measurements the error of wavelength calibration during the campaign would at most be 2.5/,nm which is acceptable for the slowly varying broadband scattering cross section of aerosol.".

8) Section 3.2: It is mentioned that a diffraction efficiency of 54-64% is observed, but nothing is said concerning the power applied to the transducer of the crystal. Also, these values appear quite low compared to typical DE for TeO2 easily reaching 90%. Moreover the method described neglects the attenuation by the crystal itself, and it is not clear if the incident light was initially polarized. I would recommend to re-write this section such that one can better understand how these values could be obtained.

Reply: Our crystal was rated for 2 W RF and the power pumped into the crystal was approximately 2.0 W. As the RF power was increased the the DE increased. However we did not want to exceed the power rating for our crystal. The DE that was determined by our tests were close to the factory specified DE of 60%. As previously noted, the AOTF was purchase from off the shelf and this was the best option available for our needs. The light entering the system was linearly polarized aligned with the AOTF polarization axis. Lastly the attenuation of the signal from the AOTF is technically a loss of signal and not a change in the DE but was never calculated as the two effects were lumped together in our analysis and a note has been made about this in the text. See section 3.1 for the complete changes to this section.

Reply: From my understanding the propagation directions of the non-desired orders passing through the AOTF are slightly altered by the acoustic

⁹⁾ Stray light: Cycling between the ON/OFF state of the AOTF is probably a unique feature of the AOTF which is well emphasized in the text. However, knowing how complex straylight characterization can be, I wonder why all these efforts were made as in the end, the problem is mostly solved by the ON/OFF approach. The only effect which is not solved by the ON/OFF method is the straylight generated after the AOTF. Is there something that can be said on this based on the characterization that was performed?

wave. As such work was done to verify that an ON/OFF approach would be able to remove most of the unwanted signal from the final image which it was able. As for stray light within the system some was expected due to reflections off of components inside of the system and and estimation of the stray light has been added to the text.

10) Relative flat fielding: It is not clear which setup was used to create the radiometric flat field, and if the complete FOV was illuminated. From what can be read, I understand that only sub-sections of the detector were illuminated, so it is not clear how the response of pixels looking at the bottom of the scene can be related to the response of the pixels looking above... This is important as you perform a spatial normalization in the processing algorithm. A mathematical radiometric model would help understanding what has been done. I would suggest to re-write this section in order to explain how the setup looked like, with which accuracy for the flatness of the radiometric field, and how does it impact the final product.

Reply: The entire FOV was illuminated during the relative flat fielding experiment and the diffuse source was imaged by the system at multiple wavelengths with varying exposure times. These images were used to determine an average flat fielding calibrations for each pixel across the wavelength and FOV. Addition detail has been added about the experimental set up. See this section for the alterations.

11) Conclusion: Taking into account the impressive amount of work that has been done in this work, I would have expected some more discussion in the concluding section. From what can be read in this section, further improvements of the instrument would only consist in reaching absolute radiometric calibration, and a better flat fielding. I am not convinced that this will significantly reduce the error bars (50% at 1 sigma). Actually the shortness of the conclusion reflects the absence of a detailed error budget. This is probably my main concern with the manuscript: due to the absence of a mathematical model of the instrument, it is not possible to understand the amplitude of the different errors, and the results presented in fig.12 cannot really be interpreted.

Reply: Though the inversion method used to retrieve aerosol from the limb a large amplification of error is seen in the final determined value. If a

radiance measurement has approximately a 1% uncertainty this is amplified by the retrieval method by approximately a factor of ten (Regier et al., 2014; Bourassa et al., 2012). So with a 5-8% error on the radiance profile a 40-70% uncertainty is expected on the retrieved result. From our error budget analysis about 3-5% of the error on the measurement vector is propagated from the flat fielding calibration and contributes the largest uncertainty in the final aerosol extinction measurements. Additional details can be found in the results section.

Bourassa, A. E., McLinden, C. A., Bathgate, A. F., Elash, B. J., and Degenstein, D. A.: Precision estimate for Odin-OSIRIS limb scatter retrievals, J. Geophys. Res., 117, D04303, doi:10.1029/2011JD016976, 2012a.

Rieger, L. A., Bourassa, A. E., and Degenstein, D. A.: Stratospheric aerosol particle size information in Odin-OSIRIS limb scatter spectra, Atmos. Meas. Tech., 7, 507–522, doi:10.5194/amt-7-507-2014, 2014.