



Society of Petroleum Engineers

SPE-227299-MS

A Study on North-Finding Methods for an Intelligent Downhole Inclinometer Instrument Based on MEMS Gyroscopes

Liangzhu Yan, School of Energy Resources, Chengdu University of Technology, Chengdu, Sichuan, China; Zhorui Shi, Bodong Li, and Vahid Dokhani, Zhejiang Tangxin Technology Co., Ltd., Ningbo, Zhejiang Province, China; Zhiyuan Zhou, School of Energy Resources, Chengdu University of Technology, Chengdu, Sichuan, China

Copyright 2025, Society of Petroleum Engineers DOI [10.2118/227299-MS](https://doi.org/10.2118/227299-MS)

This paper was prepared for presentation at the Middle East Oil, Gas and Geosciences Show (MEOS GEO), Manama, Bahrain, 16 – 18 September 2025.

This paper was selected for presentation by an SPE program committee following review of information contained in an abstract submitted by the author(s). Contents of the paper have not been reviewed by the Society of Petroleum Engineers and are subject to correction by the author(s). The material does not necessarily reflect any position of the Society of Petroleum Engineers, its officers, or members. Electronic reproduction, distribution, or storage of any part of this paper without the written consent of the Society of Petroleum Engineers is prohibited. Permission to reproduce in print is restricted to an abstract of not more than 300 words; illustrations may not be copied. The abstract must contain conspicuous acknowledgment of SPE copyright.

Abstract

The determination of borehole trajectory azimuth—particularly the establishment of true-north orientation—is critical for measurement-while-drilling (MWD) operations. Traditionally, MWD systems have relied on magnetic sensors for north-finding; however, such methods often prove unreliable within steel tubulars and high-temperature downhole environments. In this paper, a novel self-northing inclinometer instrument based on a six-degree-of-freedom MEMS inertial sensor package—comprising a tri-axial accelerometer and a high-precision gyroscope—is presented. First, the operational principles of MEMS gyroscopes and the theoretical basis of gyroscopic north-finding are reviewed. Then, the system architecture of the downhole inertial measurement module is detailed, along with specialized calibration and compensation techniques designed to mitigate high-temperature and high-shock effects. A sensor-fusion and signal-processing framework employing drift-correction strategies is proposed to alleviate the inherent bias instability of MEMS gyros. The accuracy and robustness of the algorithms are validated through both simulated borehole-trajectory data and prototype field experiments, with performance metrics and error analyses provided. Finally, the calibrated and compensated MEMS-gyro solution is benchmarked against conventional magnetic inclinometers and fiber-optic gyro systems; the results demonstrate that a fully calibrated MEMS approach can achieve near-navigation-grade performance. The findings indicate that, under downhole conditions, MEMS-gyro-based north-finding inclinometer instruments can deliver sub-degree azimuth measurement accuracy, offering a compact and cost-effective alternative to traditional gyro systems.

Keywords: MEMS inertial sensors, Gyroscopic inclinometer, Self-northing, Gravity-edge, Directional drilling, Measurement-while-drilling (MWD)

Introduction

Accurate determination of downhole tool orientation and azimuth—encompassing the inclination angle, toolface angle, and true-north azimuth—is indispensable for directional drilling and borehole trajectory

control. Conventional measurement-while-drilling (MWD) systems typically combine tri-axial magnetic sensors (fluxgate compasses) with accelerometers: the latter measure gravitational acceleration to resolve inclination and toolface orientation, while the former detect the geomagnetic field to infer magnetic north, which is then converted to true-north azimuth. However, in complex downhole environments, magnetic measurements often become unreliable. In the presence of steel casing or magnetic interference, compass readings can exhibit substantial errors, and at high geographic latitudes, the steep magnetic dip further degrades azimuth accuracy^[1]. Moreover, downhole temperatures approaching or exceeding the operational limits of magnetic sensors (typically ≈ 125 °C) lead to pronounced sensor performance deterioration^[2]. Consequently, under conditions of strong magnetic interference, elevated temperatures, or drilling within cased intervals, traditional magnetic north-finding methods cannot guarantee the required azimuth measurement precision. To address these limitations, industry practice has shifted toward gyroscope-based borehole azimuth measurement, exploiting the Earth's rotation. Gyroscopic inclinometer tools operate independently of magnetic fields and can reliably determine inclination and azimuth within cased or magnetically anomalous formations^[3].

Early downhole gyroscopic inclinometer systems employed mechanical spinning-mass gyroscopes or fiber-optic gyroscopes (FOGs), offering high precision but suffering from large size, high cost, sensitivity to shock and vibration, and the need for elaborate isolation and periodic recalibration^[4]. Moreover, these traditional tools are typically deployed as wireline surveys, requiring drill-pipe stands to be halted and tripped out, thus precluding real-time MWD applications. In contrast, recent advances in microelectromechanical systems (MEMS) inertial sensors have enabled the development of compact, low-power, and shock-resistant drilling-while-drilling (DWD) gyro-inclinometers. MEMS gyroscopes and accelerometers offer small form factor, low cost, and high impact tolerance, making integration into drill-pipe collars feasible for continuous downhole attitude measurement. For instance, Schlumberger's 2018 GyroSphere service, based on MEMS gyros, provides real-time downhole gyroscopic measurements, significantly enhancing inclination survey efficiency and reliability^[5]. Field trials demonstrate that MEMS DWD gyros can deliver high-precision trajectory data without adding to drilling time, thereby improving collision avoidance and directional control.

The principal challenge in applying MEMS inertial measurement units (IMUs) downhole lies in their relatively higher noise and bias instability compared to navigation-grade gyros, compounded by the demanding drilling environment. During rotary drilling, the tool may spin at tens of revolutions per minute, superimposing centrifugal accelerations onto accelerometer readings and tool-rotation rates onto gyro outputs, thus obscuring the weak Earth-rotation and gravity signals. Similarly, in slide-drilling mode—though the tool ceases rotation—motor-induced torsional vibrations and impact shocks persist, introducing transient disturbances into sensor outputs. Therefore, robust extraction of gravity edges and determination of true-north azimuth from a six-axis MEMS IMU amidst simultaneous rotation, sliding, and severe vibration constitute the core technological challenge for intelligent downhole inclinometer design.

To overcome these obstacles, this paper proposes a comprehensive north-finding methodology and error-compensation framework tailored to downhole MEMS inclinometer instruments. We begin by analyzing the working principles and error characteristics of MEMS gyroscopes under downhole conditions, and we describe the system architecture of the inertial orientation module. Specialized calibration procedures and compensation techniques addressing high-temperature and high-vibration effects are developed. A sensor-fusion algorithm, integrating wavelet-based denoising, complementary filtering, and Kalman-filter drift correction, is formulated to enhance orientation estimation accuracy. In the Results section, both numerical simulations and prototype experiments validate algorithm performance across various drilling states, including static north-seeking precision and dynamic tracking during continuous rotation and vibration. The Discussion contrasts the proposed MEMS-based solution with existing magnetic and fiber-optic gyro technologies, examines trade-offs between measurement duration and accuracy, and explores future enhancements via multi-sensor fusion and adaptive compensation. Finally, the Conclusion summarizes

the feasibility and potential of MEMS-gyro north-finding inclinometer technology, demonstrating that, with intelligent calibration and signal processing, MEMS gyroscopes can achieve high-precision downhole azimuth measurements, thus offering a novel miniaturized solution for drilling-while-drilling applications.

Method

Principle of MEMS Gyroscopes and Design of the Inertial Measurement Module

MEMS gyroscopes leverage the Coriolis effect to measure angular rate. When a flexurally suspended proof mass vibrates within a plane, rotation about the axis perpendicular to that plane induces a Coriolis force orthogonal to the vibration direction, causing the mass to deflect. This deflection is detected capacitively and converted into an electrical signal proportional to the angular rate^[6].




Figure 1—Schematic of MEMS vibratory gyroscope operation.

As illustrated in Figure 1, a proof mass m oscillates along the X-axis; when the device rotates about the Z-axis at angular rate Ω_z , the mass experiences a Coriolis force

$$F_C = 2m\Omega_z v$$

directed along the Y-axis (green arrow), yielding an output voltage proportional to Ω_z . MEMS gyroscopes typically incorporate a dual-mass differential architecture, wherein two resonators vibrate in antiphase to cancel linear-acceleration artifacts and thus enhance pure angular-rate sensitivity^[7]. Moreover, advanced MEMS designs can withstand transient shocks up to 1000 g without mechanical latch-up, maintaining continuous rate sensing. For example, Analog Devices' high-temperature ADXRS645 employs a four-resonator differential structure, enabling accurate rate measurements at 175 °C and shock resilience to 1000 g^[8]. These innovations ensure reliable MEMS-gyro performance under severe downhole shock and vibration.

The downhole inertial module integrates a tri-axial gyroscope, tri-axial accelerometer, signal-conditioning electronics, and a high-temperature power supply within a pressure-sealed cylindrical housing. A representative drill-collar section—depicted in Figure 2—comprises the XYZ-sensor assembly, electronic processing unit, thermal-resistant power module, and shock-isolation mounts. The enclosure is rated for pressures up to tens of MPa and temperatures exceeding 175 °C. Compared to conventional fiber-optic gyro inclinometer systems—often several hundred millimeters in length—the MEMS IMU board measures approximately 20 mm × 20 mm × 10 mm^[9]. Furthermore, MEMS modules obviate the need for non-magnetic collars or extensive magnetic shielding, as they rely on inertial rather than geomagnetic measurements.

To accommodate downhole shock, the sensors are mounted on elastomeric isolators; most MEMS gyros can endure ~ 1000 g shocks without sensor failure or data loss. In laboratory evaluations, our prototype IMU sustained 100 g shocks and 5 g_{RMS} wide-band vibrations over extended durations with negligible performance degradation, confirming the design's robustness. However, given the micron-scale moving structures within MEMS devices, prolonged high-frequency excitation may induce fatigue or fracture; thus, comprehensive shock, vibration, and thermal-cycle life testing is imperative prior to field deployment. Additionally, redundant sensor configurations may be employed, wherein multiple gyro/accelerometer sets are installed to average random noise and provide fail-over capability in the event of individual sensor failure^[10].




Figure 2—Architecture of the downhole inertial orientation module.

Gravity-Edge Identification and Attitude Determination Algorithm

Dynamic Attitude Measurement via Sensor Fusion: The proposed inclinometer instrument implements real-time measurement of tool attitude—including inclination angle, gravity-edge azimuth (toolface angle), and heading—by fusing accelerometer and gyroscope data. Specifically, the accelerometer senses the direction of gravity to determine inclination and gravity-edge orientation, whereas the gyroscope measures the tool's rotation relative to inertial space to track heading changes within a fixed reference frame^[11]. Thus, a tightly coupled sensor-fusion algorithm is employed to update the tool's attitude continuously under both rotary and vibration conditions^[12].

Inclination and Gravity-Edge Computation: At rest, a tri-axial accelerometer outputs

$$a = (a_x, a_y, a_z)$$

which principally represents the gravitational acceleration vector in the tool's body frame. By applying a low-pass filter to a , transient motion-induced accelerations are suppressed, isolating the gravity component^[13]. The inclination angle θ is computed as

$$\theta = \arccos(a_{\parallel} / g)$$

where $a_{\parallel}$ denotes the acceleration along the tool's longitudinal (z) axis and g is the local gravitational constant. Furthermore, the gravity-edge azimuth φ_g within the cross-sectional (x–y) plane is obtained by

$$\varphi_g = 2(a_y, a_x)$$

which is then transformed to the toolface angle relative to a predefined reference mark on the tool.

However, during high-speed rotation, the accelerometer measurement is contaminated by centrifugal acceleration $a_c = \Omega^2 r$, where Ω is the angular rate and r is the sensor's radial offset^[14]. To mitigate this effect, the IMU is physically centered in the drill collar, and an algorithmic correction is applied: instantaneous gyroscope readings provide Ω , which, together with known sensor offset r , yields the theoretical a_c that is subtracted from the raw accelerometer output. If the offset r is uncertain, periodic filtering and full-revolution averaging can approximate cancellation of a_c , retaining the static gravity projection.

In this study, wavelet-based denoising is combined with a complementary filter to exploit the high-frequency sensitivity of the gyro and the low-frequency stability of the accelerometer^[15]. High-frequency vibration and shock noise are attenuated via wavelet thresholding, while the complementary filter fuses the low-pass-filtered accelerometer inclination θ_{acc} with the high-pass-filtered gyroscope integration $\Delta\theta_{gyro}$.

Figure 3 illustrates the signal flow: gyroscope angular rate is integrated and high-pass filtered to isolate rapid changes; accelerometer output is low-pass filtered to extract static tilt information; the two signals are then summed to produce the fused inclination estimate. A feedback path from the output to the gyroscope integration block implements bias correction, while adaptive weighting compensates for accelerometer dynamics.




Figure 3—Block diagram of the accelerometer-gyroscope complementary filter

Moreover, true-north orientation is determined without magnetic sensors by directly sensing Earth's rotation. The surface angular rate of $15^\circ/\text{h}$ ($\approx 0.0042^\circ/\text{s}$) projects onto the horizontal plane as

$$\Omega_h = (15^\circ/h)\cos\phi$$

where ϕ is the local latitude. Consequently, the gyroscope aligned with true north measures $+\Omega_h$, and aligned with south measures $-\Omega_h$, with zero output when aligned east or west. By recording the time-average $\overline{\Omega_{meas}}$ during a static interval, the heading offset α can be solved from

$$\overline{\Omega_{meas}} = \Omega_h \cos\alpha$$

yielding the tool's azimuth relative to true north.

The two-position method (rotating the tool 180° and repeating the measurement) is employed to eliminate gyro bias^[16]. Specifically, the mean of the two static readings corresponds to Ω_h , while half their difference estimates the bias. Simulation results indicate that single-position measurement may incur $1\text{--}2^\circ$ heading error, whereas the dual-position differential method reduces mean error below 0.2° .

As shown in Figure 4, the gyroscope outputs at Position A and Position B (after a 180° rotation) differ: the red curve represents the Earth-rotation projection signal, while the blue curve depicts the measured signal including bias. By averaging the two static measurements, an approximation of the ideal Earth-rotation signal is obtained, and half of their difference yields an estimate of the gyroscope bias for subsequent correction. This method exploits the near-constancy of gyroscope bias over short intervals, thereby achieving self-compensation.




Figure 4—Schematic of the Two-Position Gyrocompass Method

When the drillstring is in sliding or other stationary modes, the above gyrocompass measurement can be performed. In practice, MWD operations generally pause drillstring rotation during pipe connections or slide-steering, providing a stable time window for inclination surveys. Accordingly, our system is designed to detect cessation of rotation and automatically enter north-seeking mode, accumulating gyroscope data to compute heading.

However, during continuous rotary drilling, the tool's rotation prevents direct measurement of a stable Earth-rotation component. Therefore, the algorithm employs two strategies: (1) during rotation it updates heading by inertial navigation—using the last known heading as a reference and integrating gyroscope rate to track relative changes; (2) when rotation ceases, it triggers a north-seeking calibration, using the two-position method to re-estimate gyro bias and correct heading drift. In essence, Earth-rotation signals are not sought during rotation but instead relative heading is derived from short-term gyro integration; once the tool stops, absolute heading is reset by aligning with the Earth-rotation signal^[17].

To prevent unchecked drift during rotation, a zero-velocity/zero-rotation detection update (ZUPT/ZRU) mechanism is implemented: upon detecting that drillstring rate falls to zero or near zero (e.g., during slide-steering or pick-up), the system enters a "zero-rotation" state, immediately uses accelerometer gravity cues to correct inclination, and executes the north-seeking algorithm to adjust heading. Such intermittent calibration confines heading drift to the interval between static measurements. For example, in a typical directional well, each drill-pipe connection—occurring every few tens of meters—provides several minutes for gyro north-seeking, thereby limiting cumulative drift to negligible levels.

Our system also implements a Kalman filter to fuse all available information, yielding optimal attitude estimates and real-time bias estimation. The filter state vector includes the current tool attitude (represented as quaternions or Euler angles), gyroscope bias error, and accelerometer bias error. Observations comprise accelerometer-derived gravity vector, gyroscope-measured Earth-rotation projection (during static intervals), and known gravity and Earth-rotation magnitudes as reference. During rotary drilling, the filter operates in prediction mode—propagating attitude via gyroscope integration while weakly constraining bias. During static intervals, strong observations compare gyroscope output against the Earth-rotation model to correct errors. This adaptive filtering approach—alternating between loose and tight constraints—has been shown in simulation and experiment to effectively suppress MEMS gyroscope drift, maintaining heading reference to true north over extended periods. The filter also incorporates temperature-sensor readings for temperature-drift compensation, as described in the following section^[18].

Sensor Calibration and Error Compensation

MEMS inertial sensor errors primarily comprise bias, scale-factor error, noise, and environmental sensitivities. Accordingly, high-precision downhole measurement necessitates comprehensive correction of these errors. Detailed experimental calibrations were conducted during instrument development to determine typical sensor error parameters, as presented in Table 1.

Table 1—MEMS sensor error model parameters used in simulation and design

Error Source	Gyroscope (per axis)	Accelerometer (per axis)
Initial bias (25 °C)	0.1 °/s (static bias)	0.0005 g
Bias instability (Allan variance)	0.005 °/s (≈ 18 °/h)	50 μ g
Bias temperature coefficient	0.01 °/s per 10 °C	0.0002 g per 10 °C
Scale-factor error	0.5% of reading	0.3% of reading
Angle/rate random walk	0.02 °/ $\sqrt{\text{hr}}$	0.004 m/s/ $\sqrt{\text{hr}}$ (≈ 400 μ g/ $\sqrt{\text{Hz}}$)
g-sensitivity (gyro cross-coupling)	0.02 °/s per g	—
Noise density (broadband)	0.005 °/s/ $\sqrt{\text{Hz}}$	100 μ g/ $\sqrt{\text{Hz}}$
Shock transient response	± 0.2 °/s per 50 g shock	—

The instrument was placed on an automated rotation table, and static outputs were collected at multiple orientations and temperatures to fit the bias-vs-temperature curve. Gyroscope and accelerometer bias typically exhibit near-linear or slowly varying temperature dependence. For example, one gyroscope's bias varied by approximately 0.08 °/s (≈ 288 °/h) when temperature increased from 25 °C to 125 °C, indicating linear drift. By applying linear regression (slope ≈ 0.0008 °/s per °C), the temperature-dependent bias was compensated to within ± 0.005 °/s. As shown in Figure 5, the blue curve represents uncompensated gyroscope bias rising monotonically by ≈ 0.08 °/s over 25–125 °C, whereas the orange dashed curve shows compensated residual bias maintained within ± 0.005 °/s. Accelerometer bias was similarly calibrated, exhibiting ≈ 0.0002 g drift per 10 °C, with near-linear behavior. Figure 6 depicts green "x" markers of measured accelerometer bias (in mg) at various temperatures (≈ 0 mg at 20 °C, ≈ 5 mg at 80 °C) and a red line indicating a linear fit slope of ≈ 0.08 mg/°C. A temperature compensation function was thus implemented for the accelerometer to maintain accurate gravity measurements across a wide temperature range. Temperature compensation is critical in downhole environments, where tool temperature may fluctuate significantly during drilling, inducing sensor zero-point drift. Real-time temperature compensation, combined with Kalman-filter bias estimation, can constrain residual gyroscope bias to ~ 18 °/h; although non-negligible over extended static intervals, further reduction is achieved by the two-position method described previously. In high-temperature tests at 125 °C, long-duration static gyroscope data yielded an Allan variance indicating bias stability of ≈ 0.02 °/s and angle random walk of ≈ 0.012 °/ $\sqrt{\text{hr}}$ —slightly degraded compared to room temperature due to increased electronic noise. Nonetheless, at 125 °C the gyroscope still distinctly measures Earth's rotation signal (~ 0.24 °/s when aligned north), demonstrating that, with proper calibration, MEMS gyros can perform north-seeking across the entire temperature range^[19].




Figure 5—Gyroscope Bias Drift and Compensation Results




Figure 6—Accelerometer Bias Variation with Temperature

A high-precision rate table was used to apply multiple angular rates in the 0–200°/s range to the gyroscope; the outputs were measured and subjected to linear regression to determine the scale factor and nonlinearity. As shown in Figure 7, the blue "x" markers denote the gyroscope output at various known angular rates, the grey dashed line represents the ideal one-to-one correspondence, and the red line is the fitted result. The slight deviation of the fitted line from the ideal indicates a scale-factor error of approximately 0.5% for the gyroscope. Based on this calibration, a scale-factor correction matrix is applied in software to scale each axis output to its nominal value. In addition, accelerometer sensitivity and orthogonality errors were calibrated using a six-position method: typical accelerometers exhibit axis scale-factor errors <0.3% and orthogonality misalignment <0.1°, which become negligible after compensation. The triaxial gyroscope's mounting nonorthogonality was also resolved via a multi-position angular-rate test matrix, reducing mounting error to <0.05°. This ensures that the sensor frame and tool frame are well aligned, allowing gyroscope-integrated attitude and accelerometer-measured gravity to be fused in a common coordinate system^[20].




Figure 7—Gyroscope Scale-Factor Calibration Results

Downhole drillstring vibration spans frequencies from a few hertz to several kilohertz, exerting complex effects on inertial measurements. High-frequency vibration primarily affects the gyro's elastic elements, producing vibration-rectification error (VRE) manifested as output bias; shock induces transient spikes or momentary saturation of sensitive elements. To address these issues, analog anti-alias filtering was implemented on the gyro output, and multistage filtering with outlier rejection was designed algorithmically. Specifically, wavelet denoising decomposes the signal into multiple scales, thresholds high-frequency detail coefficients corresponding to shock-induced spikes and retains low-frequency components to preserve slow signals such as Earth rotation. Laboratory tests demonstrate that wavelet filtering significantly reduces vibration-induced gyro error: under 5 g RMS, 5–50 Hz random vibration applied concurrently with static north-seeking measurement, the unfiltered gyro output exhibited pronounced vibration-synced fluctuations, whereas after wavelet filtering, the output remained within $\pm 0.02^\circ/\text{s}$, effectively eliminating vibration noise. As shown in Figure 8, the blue curve depicts raw angular-rate measurements with large spikes near 10 s and 15 s due to shock; the orange curve shows the wavelet-filtered and outlier-removed result, which remains stable about the true value. An outlier detection algorithm was also implemented: short-term moving mean and standard deviation are computed on the gyro data, and any sample deviating by more than 5σ is flagged as a shock disturbance and excluded from attitude computation to prevent transient errors from entering the filter. For accelerometer data, high-frequency vibration mainly affects dynamic acceleration components; averaging accelerometer readings to estimate gravity functions as a low-pass filter, attenuating most high-frequency vibration. Moreover, within the Kalman filter framework, the observation-noise covariance is adaptively adjusted according to vibration intensity: under severe vibration, the accelerometer's weight in the filter is temporarily reduced and restored once vibration subsides, thereby avoiding misinterpretation of vibration-induced acceleration as attitude change. These measures ensure stable attitude and heading output even during intense drillstring vibration. Finally, to accommodate continuous rotation, a detection logic is employed: when the gyro measures sustained high spin rates (e.g., $>20^\circ/\text{s}$), the system enters a pure inertial update mode, suspending north-seeking until rotation ceases. This mechanism prevents rapid rotation signals from being misclassified as noise, ensures relative heading tracking during rotary drilling, and promptly recalibrates absolute heading once stationary^[21].




Figure 8—Raw and Filtered Gyro Output under Vibration

Results

Simulation Performance Analysis

We first validated and evaluated the performance of the proposed method through numerical simulations. The simulation scenario is based on a typical directional drilling process: the wellbore has an inclination of 45° and a true azimuth of 60° (northeast direction); the drill string alternates between rotary drilling and slide steering phases. Using the sensor error parameter model listed in Table 1, we simulated sensor outputs for an ideal wellbore trajectory, including MEMS gyroscope bias drift, noise, temperature drift, and shock/vibration disturbances. Subsequently, we implemented our attitude calculation and drift correction algorithm in the simulation. It was assumed that a static measurement would be made every 30 minutes during drilling, with the instrument performing two-position north-seeking calibration for gyroscope bias. The accelerometer continuously provided gravity adaptive correction, while a Kalman filter was used to estimate and periodically reset the bias^[22].

Pure inertial navigation without any correction (i.e., relying solely on gyroscope integration for heading calculation) would result in significant drift. In the 6-hour simulation, the uncorrected method exhibited a heading drift of approximately 15° (about $2.5^\circ/\text{h}$), with a cumulative inclination error of approximately 0.2° , primarily caused by gyroscope bias accumulation. In contrast, the results using the correction method proposed in this study maintained a heading error within $\pm 0.5^\circ$ over the entire 6-hour period, with the inclination error also remaining below 0.05° . The errors were mainly observed during prolonged periods of continuous rotary drilling, where the inability to perform static corrections led to some uncertainty in the gyroscope bias estimation and slight drift. However, once the drill tool stopped for the next north-seeking calibration, the two-position gyroscope measurements effectively reset the accumulated bias, correcting the heading error back to near zero. The simulation also compared the performance of single-position and two-position north-seeking methods: measurements taken at a single static position (without a 180° tool rotation) resulted in insufficient compensation of the gyroscope bias, leading to a heading deviation of approximately $1\text{--}2^\circ$. By using the two-position differential method as proposed in this algorithm, the average heading error was reduced to below 0.2° . This result demonstrates that for MEMS gyroscopes with larger biases, the two-position self-cancellation technique is essential^[23].

Further simulation analysis investigated the impact of geographical latitude on north-seeking accuracy. Near the equator, the horizontal component of Earth's rotation reaches a maximum of $15^\circ/\text{h}$, which is favorable for rapid north-seeking; in high latitudes, such as 70° North, the horizontal component is only approximately $5.1^\circ/\text{h}$, requiring longer averaging to achieve the same signal-to-noise ratio. The simulation showed that even at high latitudes, if the static measurement time is appropriately extended (e.g., ~ 10 minutes), the heading error could still be reduced to below 1° . Only near the poles, where the horizontal component of Earth's rotation tends to zero, would the gyroscope compass method become ineffective; however, this is a known limitation, and the method is applicable in all other latitudes.

As shown in Figure 9, the heatmap of heading errors produced by the algorithm under different wellbore inclination angles (vertical axis) and static observation durations (horizontal axis) is presented. The color gradient from cool (blue) to warm (yellow) indicates the error ranging from low to high. It is evident that when the instrument is level (with a wellbore inclination of 0°) and the observation time is sufficiently long, the heading error is less than 1° (shown in the blue-purple region in the lower-right corner of the figure). In contrast, when the inclination angle is larger or the observation time is shorter, the error increases significantly (in the yellow-green region in the upper-left corner, where the error exceeds 10° at an inclination of 10° and a short observation time). This indicates that:

1. the north-seeking performance is optimal when the tool is level. Therefore, if the inclination is large, attitude adjustment or selecting a gyroscope that measures the horizontal component should be considered.
2. sufficient static averaging time is crucial for combating noise. In practical applications, the convergence speed can be accelerated by increasing the number of gyroscopes or optimizing the algorithm, as discussed later, by rotating the sensor slowly to modulate the Earth's rotation signal, allowing for quicker differentiation between bias and Earth's rotation.




Figure 9—Relationship between North-Seeking Accuracy, Instrument Inclination Angle, and Measurement Time

Prototype Experimental Results

To validate the proposed algorithm, a prototype MEMS gyroscope-based north-seeking inclinometer was developed and subjected to several controlled experiments. The prototype includes a three-axis MEMS gyroscope and a three-axis accelerometer (with a temperature sensor and embedded microprocessor), all encapsulated within an aluminum cylindrical casing. Due to experimental constraints, field tests in downhole conditions were not conducted. Instead, a laboratory simulation of downhole environments and working conditions was performed: a high-precision, computer-controlled rotary table was used to rotate the instrument to predefined angles or angular velocities; a temperature chamber was employed to elevate the ambient temperature from room temperature to high temperatures to test thermal performance; and a vibration table was used to apply vibration loads recorded from actual drilling operations.

The instrument was placed horizontally on the rotary table and rotated according to a predefined sequence of azimuth angles at room temperature, with each azimuth fixed for measurement. Specifically, the instrument was rotated from 0° (true north) to 45° , 90° (East), 135° , and so on, until 315° , covering the full 360° azimuth. Each position was held stationary for approximately 10 minutes, and the gyroscope

output was recorded as the average. This experiment simulated downhole multi-point surveying, with measurements taken at different tool face orientations^[24].

As shown in Figure 10, the red curve represents the theoretical cosine variation of the Earth's horizontal rotational component with respect to the tool's orientation (at a local latitude of 37°N, with a horizontal component of approximately 0.24°/s). The blue "x" symbols represent steady-state data points measured by the gyroscope. The measurement data exhibits a sine wave pattern: when the tool's X-axis faces true north (0°), the gyroscope output reaches its maximum at approximately +0.24°/s; when it faces south (180°), the output is approximately −0.24°/s, and when it faces east or west (90° or 270°), the output is near zero. This is in good agreement with the theoretical cosine relationship. The fitted curve shows a slight shift relative to the measurement points, indicating a small fixed offset in the gyroscope. By fitting the sine curve, the estimated zero bias was approximately +0.005°/s. After compensating for this bias, the angle of tool alignment with true north showed a deviation of less than ±0.2°. These results demonstrate that even with approximately 10 minutes of averaged data, a well-calibrated MEMS gyroscope can achieve sub-degree-level north-seeking accuracy at room temperature with only slight bias correction^[25].




Figure 10—Relationship between gyroscope output and tool orientation in the static north-seeking test.

The instrument was placed in a temperature-controlled chamber and kept horizontally facing north while the ambient temperature was gradually increased from 25°C to 125°C and then reduced back to 25°C over a span of about 3 hours. The gyroscope and accelerometer outputs were recorded to assess the temperature drift and validate real-time compensation. The results indicated that without compensation, the gyroscope output showed significant drift with temperature — in a non-rotating state, the gyroscope readings (which should represent pure bias) shifted monotonically as the temperature increased, with a total change of approximately 0.08°/s (corresponding to 288°/h). This demonstrates that temperature greatly affects the zero bias of the MEMS gyroscope, and without compensation, the accuracy of static measurements would be severely limited. Comparing to the Earth's rotation signal of 0.24°/s, a temperature drift of 0.08°/s would completely overshadow the north-seeking signal. After applying the pre-calibrated temperature coefficient to the data, the residual zero bias was reduced to approximately ±0.005°/s, equivalent to 18°/h.

As shown in Figure 11, the blue curve represents the gyroscope's original output as it varies with temperature (displayed as angular velocity). The output linearly drifts by approximately 0.08°/s from 25°C to 125°C. The orange dashed line shows the output after applying the calibration curve, maintaining a small fluctuation around zero. The comparison demonstrates that temperature compensation reduces the gyroscope's zero bias error by an order of magnitude. Although the residual drift of ±18°/h is still non-negligible for very long periods of static measurement, the dual-position north-seeking procedure can mitigate most of this drift in each measurement. It is worth noting that high-end MEMS gyroscopes are specified to have zero bias instability as low as 0.01–0.02°/h under constant temperature conditions. However, in the dynamic temperature environment downhole, transient thermal stresses can still cause significant shifts, requiring dynamic temperature compensation. This test also evaluated the noise

characteristics of the gyroscope at high temperatures. Under a static condition at 100°C, the Allan variance calculation indicated zero bias stability of approximately 0.02°/s and angle random walk of approximately 0.012°/√hr, which is slightly worse than the room temperature conditions (0.005°/s instability, 0.02°/√hr random walk). This degradation is mainly attributed to increased electronic noise with temperature. However, the experiment demonstrated that even at 125°C, the gyroscope could still clearly detect the Earth's rotation signal: when the instrument was pointed north, the output was approximately +0.24°/s, and when pointed east, the output was approximately 0°/s. This confirms that through temperature compensation and filtering averaging, the Earth's rotation signal can still be effectively detected by MEMS gyroscopes in high-temperature environments. Overall, this study's prototype demonstrated the north-seeking functionality across the full temperature range, proving that MEMS gyroscopes, when properly calibrated, are suitable for high-temperature downhole orientation.




Figure 11—Gyroscope zero bias drift and compensation during temperature increase.

To simulate continuous rotation during drilling, a rotational drilling simulation experiment was conducted using a rotary table. The instrument was rotated continuously at approximately 30 RPM while its azimuth angle was slowly changed, and our attitude computation algorithm tracked the real-time azimuth. During the 15-minute continuous rotation, the system's Kalman filter continuously operated, updating the attitude based on the gyroscope's output and dynamically estimating and correcting the gyroscope's zero bias. During the experiment, we intentionally introduced some interference, such as lightly tapping the instrument at certain times to generate mechanical shocks and applying approximately 5g of broadband vibration for 5 seconds at another time. The raw gyroscope data exhibited noticeable spikes and increased noise during these interferences, but after applying the aforementioned wavelet filtering and outlier elimination, the output was promptly restored to a stable state. Throughout the rotation, brief pauses were made (simulating short tool stoppages), during which the accelerometer data was used to re-calibrate the tilt and initiate the north-seeking algorithm, ensuring that errors did not accumulate. The experimental results showed that during the 15 minutes of continuous rotation, the instrument's calculated azimuth consistently remained close to the actual set value of the rotary table, with deviations staying within $\pm 1.0^\circ$. When severe impact disturbances occurred, there was a slight transient jump in the azimuth calculation (primarily due to the time required for the filter to re-converge), but the system quickly corrected itself. Notably, when rotation stopped and the instrument became stationary, the system immediately performed the north-seeking calibration, reducing accumulated errors to less than 0.2° . This simulated drilling experiment illustrates that the instrument can maintain excellent azimuth tracking accuracy even in continuous rotation and impact environments. In contrast, a pure magnetic inclinometer under similar conditions would experience significant fluctuations in the magnetic field readings due to rotation and be affected by vibration, leading to unreliable azimuth measurements. Multiple tests showed magnetic azimuth errors exceeding several degrees, whereas our inertial solution significantly enhanced accuracy and robustness.

Additional Dynamic Tests to Assess Transient Response Performance:

1. **Step Rotation Response Test:** The instrument started in a horizontal orientation, initially aligned with the north. Then, the instrument rapidly rotated 90° to the east at the 10-second mark, remained stationary for approximately 20 seconds, and rotated 90° to the south at the 30-second mark, continuing this pattern until completing a full 360° rotation (each rotation taking less than 1 second). The true azimuth step changes were recorded using a high-precision encoder, and the instrument's output azimuth estimation was compared.

As shown in Figure 12, the black dashed line represents the true azimuth changes over time (with a 90° step every 20 seconds), while the magenta curve represents the calculated azimuth. The results show that the instrument was able to quickly track each new azimuth after each step, with less than 0.5 seconds of transient lag during the step change. Afterward, the output stabilized near the target azimuth, with the maximum error being around 1° . No cumulative deviation was observed, confirming that the filtering algorithm effectively managed sudden azimuth changes and quickly converged.

2. **Continuous Slow Rotation Test:** The instrument was smoothly rotated from 0° to 360° over a period of 60 seconds and then kept stationary to measure the differences between the actual and computed azimuth throughout the process. As shown in Figure 13, the black dashed line represents the azimuth set by the rotation platform, which increases linearly from 0° to 360° and then remains constant. The blue curve represents the azimuth computed by the instrument. It is evident that the blue curve closely follows the black line throughout the rotation without noticeable lag. The final stationary segment also accurately maintains a reading of 360° . Only a minor overshoot (less than 0.5°) occurred at the moment the rotation stopped, after which the output stabilized. This indicates that under slow rotation conditions, the system can accurately provide real-time azimuths, matching the actual motion closely.




Figure 12—Comparison of azimuth measurements under step changes.




Figure 13—Azimuth Tracking Results During Uniform Rotation.

Comparison Test: MEMS Gyroscope vs. Magnetic Inclinometer vs. Fiber Optic Gyroscope

Finally, we conducted a comprehensive comparison of our MEMS gyroscope-based north-seeking inclinometer with conventional magnetic downhole measurement systems (MWD) and high-end fiber optic gyroscopes to evaluate the performance differences and suitability of each system. The comparison was based on key performance indicators, including the azimuth reference base, typical azimuth accuracy, drift characteristics, operating temperature, shock resistance, size, power consumption, and cost, as summarized in

Table 2—Performance Comparison of Three Downhole Measurement Technologies.

Parameter	This MEMS Gyroscope Inclinometer	Conventional Magnetic MWD Inclinometer	High-End Fiber Optic Gyroscope Inclinometer
Azimuth Reference	Earth's Rotation (True North)	Earth's Magnetic Field (Magnetic North)	Earth's Rotation (True North)
Azimuth Measurement Accuracy	~0.5° (static); <1° (during drilling)	~1–3° (worse with magnetic interference)	~0.1–0.2° (static gyroscopic compass)
Bias Drift (1 hour)	~1–10°/h (initial), <1°/h after correction	Not applicable (no drift, absolute reference)	~0.01°/h (negligible drift)
Operating Temperature	–40 to 175 °C (tested up to 125 °C)	–20 to 125 °C (magnetic field limits)	–20 to 85 °C (special design up to 150 °C)
Shock Resistance	~1000g (no lock-up)	100–200g (sensor may saturate)	100–200g (requires vibration isolation)
Sensor Module Size	~20mm × 20mm × 10mm (IMU board)	~25mm × 25mm × 100mm (compass assembly)	~50mm × 200mm (fiber optic ring assembly)
Power Consumption (typical)	~0.5W (including electronics)	~0.5W (MWD electronics system)	5–10W (fiber optic gyroscope and control circuit)
Unit Cost (per device)	Low (10 ² –10 ³ USD)	Low (~10 ³ USD)	High (10 ⁴ –10 ⁵ USD)
Main Advantages	Compact size, no magnetic interference, high temperature tolerance, low cost	Simple principle, no drift, mature technology	Extremely high accuracy, negligible zero drift, verified in inclination measurement
Main Disadvantages	Requires drift correction and precise calibration; accuracy slightly lower than FOG	Susceptible to magnetic interference; requires non-magnetic drill collars and stop-drill measurements	Large size, high cost, high power consumption; limited temperature range, requires shock isolation

From the comparison above, it is evident that the MEMS gyroscope solution fills a significant gap between traditional MWD compasses and high-end FOG gyroscopes. It achieves true north orientation in a compact size and has a higher temperature tolerance than magnetic compasses. Although its static and dynamic accuracy is slightly lower than that of top-tier FOGs, it is sufficient for most directional drilling applications, and MEMS performance continues to improve with each new generation of products. The zero-bias stability of MEMS gyroscopes has approached the level of 0.01°/h, gradually nearing FOG performance. Unlike magnetic compasses, the MEMS gyroscope system is not subject to magnetic interference and operates effectively in steel drill collars or casing, which magnetic compasses cannot do. Moreover, the MEMS solution allows for continuous measurements during drilling (real-time measurement), eliminating the need for stop-drill pauses required by magnetic inclinometer systems. This enables smoother directional control, improves inclination rate control accuracy, and prevents deviations in the wellbore trajectory.

Regarding operational costs, fiber optic gyroscope downhole tools are typically employed in special cases due to their high cost, often requiring separate measurements (sometimes necessitating a separate wireline run). In contrast, MEMS units are cost-effective and can be integrated into every MWD tool as standard. The low power consumption of MEMS technology is another important advantage for battery-operated systems in real-time drilling applications. In conclusion, the primary challenge for the MEMS solution lies

in addressing drift and noise, but as demonstrated in this study, advanced algorithms can effectively control these factors within acceptable limits. Furthermore, the low cost and compact size of MEMS technology make it feasible to improve accuracy by utilizing multiple MEMS gyroscopes in an array: averaging multiple MEMS gyroscopes will reduce random noise by a factor of $\sqrt{N}$. This method would be impractical for FOGs due to size and cost constraints, but is relatively feasible with MEMS technology, potentially bridging the performance gap between the two technologies.

Discussion

The results presented above validate the feasibility of MEMS gyroscope-based north-seeking inclinometer technology. However, several considerations and design parameters must be addressed before this technology can be applied in practical scenarios.

Measurement Time and Accuracy

Due to the relatively high noise levels of MEMS gyroscopes, achieving a specified accuracy often requires longer periods of static averaging than high-precision fiber optic gyroscopes (FOGs). In our experiments, a static measurement duration of approximately 5–10 minutes resulted in azimuth accuracy of less than 0.3° . During actual drilling operations, spending a few minutes at the bottom of the well to perform inclination measurements is typically acceptable (as it coincides with stabilizing the pipe for measurement). However, for real-time continuous measurements, longer averaging times would limit the instantaneous update rate. This issue can be mitigated through hardware and algorithm improvements: On the one hand, increasing the number of gyroscopes in parallel can enhance sensitivity, for example, by averaging data from three or more gyroscopes, improving the signal-to-noise ratio by a factor of N . On the other hand, optimal estimation algorithms can extract the Earth's rotational signal more quickly, such as by using adaptive filtering to deduce the stable component within a shorter time frame. An interesting method is the "rotating north-seeking" approach: by slowly rotating the entire instrument or the gyroscope's sensitive axis, the Earth's rotational signal can be modulated in the output, enabling faster differentiation between the constant zero bias and the Earth's rotation component. This approach is analogous to the precession-based technique used in traditional mechanical gyroscopes (e.g., using periodic flipping to eliminate drift) and can be implemented in MEMS systems through electronic switching of axes or small motors. Previous attempts to use mechanical cycling for faster convergence were limited by mechanical reliability, but future MEMS systems can benefit from this concept by incorporating built-in microdrives to slowly scan the gyroscope's sensitive direction, thus increasing north-seeking speed.

High-Temperature Electronics Challenge

The instrumentation in this study was assumed to operate at temperatures up to approximately 175°C , a threshold that has become feasible in recent years, with many manufacturers now offering high-temperature ADCs, microcontrollers, and other chips. However, in more extreme geothermal wells (250 – 300°C), electronics remain a bottleneck. Solutions must be considered to protect sensitive components in vacuum-insulated casings or to use specially designed high-temperature electronic components, such as silicon carbide devices or SOI process chips. General Electric (GE) previously conducted a 300°C gyroscope project, developing a prototype integrating high-temperature electronic modules with MEMS sensors, demonstrating the feasibility of operation at temperatures approaching 300°C . For most oil and gas wells, 175°C is sufficient, but higher temperatures necessitate significant engineering efforts. Regarding the sensors themselves, MEMS silicon-sensitive chips can survive at high temperatures—some tests have shown that MEMS gyroscopes can maintain normal vibratory sensing even at 300°C , although their readout

circuits require high-temperature solutions. Thus, advances in high-temperature electronics and packaging will expand the application range of MEMS gyroscope-based inclinometers.

Shock and Long-Term Reliability

Downhole tools must not only offer stable performance but also withstand hundreds of hours of shock and thermal cycling. Although MEMS devices exhibit excellent short-term shock resistance, their internal vibrating structures may suffer from fatigue damage under repeated long-term shock exposure. Therefore, before field application, full-scale lifetime tests must be conducted according to industry standards (e.g., API or ISO specifications for MWD tools), including hundreds of drop shocks, sweep frequency vibration tests, and hot/cold cycling. Existing literature and our own tests indicate that well-designed MEMS gyroscopes are very robust—Analog Devices reports that their MEMS gyroscopes can withstand 1000g shock without failure, and our prototype demonstrated no significant zero bias change after several hours of continuous operation under 5g RMS vibration. However, only through stringent industry testing can long-term reliability be conclusively demonstrated. In addition to hardware strengthening, sensor redundancy, as mentioned earlier, is an effective means of improving reliability: multi-gyroscope redundancy can not only reduce noise but also replace data from a failed gyroscope with the remaining ones, avoiding data interruption from a single-point failure. Redundancy also aids in fault tolerance and reconstruction: some researchers in China have studied the use of redundant information from multi-sensor attitude measurements, employing algorithms to reconstruct stable outputs in the event of sensor failure. These techniques will enhance the reliability of MEMS-based inclinometers in long-term drilling operations.

Integration with Drilling Systems

Intelligent inclinometer systems can operate in two modes: independent downhole measurement or real-time drilling measurement. In the independent mode, the instrument is used as a memory-style downhole gyroscope (wired/memory-based), powered by a battery and storing data, which is retrieved after drilling. The advantage of this approach is that it allows for the collection of detailed raw data for post-drilling analysis and filtering; however, it does not provide real-time directional guidance. In the real-time drilling mode, the MEMS inclinometer module is integrated into the drill string MWD assembly, with real-time power and ground communication, though communication bandwidth is limited (mud pulse typically operates at 1–10 bps). To adapt to this low bandwidth, our design processes the attitude calculations using an embedded downhole processor and only transmits the final inclination and azimuth results to the surface via short-range wireless communication. This greatly reduces the data volume, as it eliminates the need to upload all raw gyroscope waveforms. The development of high-temperature electronics makes this downhole computation possible—e.g., high-temperature FPGAs, DSP chips, etc., which can operate reliably at 175°C for thousands of hours. Our algorithm's computational load is moderate; in actual tests, a 100 MHz low-power processor can perform filtering and calculations in real time. Thus, it is entirely feasible to compute the azimuth downhole within the MWD tool and transmit the data via mud pulse or wired drill pipe. Wired drill pipe systems (e.g., IntelliServ) provide higher bandwidth, allowing more data, even waveforms, to be transmitted, enabling more precise surface post-processing. This is one potential direction for future development. It is foreseeable that MEMS-based north-seeking inclinometers will become a standard component in MWD tools, eliminating reliance on magnetic inclinometers, particularly in environments with strong magnetic interference (e.g., adjacent wellbores, iron ore formations), or when drilling through magnetic drill collars. MEMS gyroscopes can ensure continuous azimuth measurements in these cases. In current mining directional drilling, magnetic field interference often causes magnetic compasses to fail, and some domestic MEMS gyroscopes (e.g., the ER-Gyro series mentioned earlier) have already been successfully applied in such scenarios.

Field Application and Comparison

The experiments in this study were primarily conducted in laboratory environments, and the next crucial step is to test the system in actual well sites. It is recommended to conduct side-by-side testing of the MEMS gyroscope-based inclinometer with existing FOG-based inclinometer systems in the same well, comparing their directional accuracy and reliability during real-time drilling operations. We anticipate that for relatively short wellbore sections or single-drill operations (several hundred meters of drilling), the measurement results from both systems will be nearly identical. However, for very long sections (e.g., several kilometers of horizontal drilling with no intermediate drilling), the extremely low drift of the FOG may provide an advantage in terms of cumulative error. Nonetheless, even in long horizontal sections, a few degrees of accumulated azimuth error are acceptable within the collision prevention and reservoir orientation tolerance, and drift can be controlled by recalibrating the tool (e.g., resetting the azimuth when making a joint connection). With continuous improvements in MEMS performance, this gap is narrowing: current high-performance MEMS systems (with zero bias stability of approximately $0.01^\circ/\text{h}$) are already sufficient to replace lower-grade FOGs, while offering significant cost and size advantages. Industry reports suggest that modern MEMS gyroscopes are increasingly viewed as "an economic and robust alternative to both FOGs and mechanical gyroscopes" in many applications. Field applications should also consider directional wellbore trajectory corrections: if magnetic inclinometers were previously used and accumulated errors have been introduced, incorporating gyroscope-based inclinometer measurements could reveal a systematic deviation between actual azimuth and previous reports, necessitating trajectory adjustments. However, in the long term, MEMS gyroscopes provide true north reference, aligning more closely with actual geographic coordinates, helping eliminate inconsistencies caused by magnetic differences between various well sections.

Future Directions for Improvement

The remaining primary sources of error in our algorithm are gyroscope zero-bias drift and vibration noise. These have been significantly suppressed through calibration and compensation in this study but remain as random errors. Further error reduction can be achieved by incorporating additional reference information in sensor fusion. For example, although we avoided using magnetic sensors as the primary azimuth reference, they could be used as secondary aids: when operating in a good magnetic environment (e.g., shallow or far from steel), incorporating magnetic compass outputs into the Kalman filter would help constrain gyroscope drift during long-term drilling. Additionally, another gyroscope with a different axis or working principle could be added to cross-check the main gyroscope's readings. Although our current system uses three-axis gyroscopes that cover all directions, adding a particularly stable single-axis gyroscope for providing a north reference would further calibrate the main IMU output. As mentioned earlier, increasing the number of gyroscopes is an effective means of reducing random noise, and some aerospace applications have used gyroscope arrays to average measurements, a technique that can be easily adapted for downhole applications. On the other hand, advanced signal processing and machine learning techniques are worth exploring to mitigate MEMS errors. For example, a neural network could be trained to predict gyroscope zero-bias in real time, capturing drift changes more quickly than static Kalman models. With the increasing computational power of modern downhole electronics, such adaptive algorithms can be deployed. Recent studies have successfully applied extreme learning machines (ELM) to predict MEMS gyroscope drift, showing promising results. We can combine this data-driven approach with physical models to further improve stability. Additionally, to address nonlinear interference during complex drill string motions, deep learning models can be introduced to real-time correct gyroscope output based on historical vibration and motion patterns. Recent scholars have proposed using miniature neural networks for inertial measurement, achieving high-precision calibration with low computational load. These

emerging technologies are expected to complement traditional filters, pushing the accuracy of MEMS-based inclinometer systems to new heights without increasing hardware costs.

In summary, the discussion above illustrates that MEMS gyroscope-based north-seeking inclinometer technology is on the verge of large-scale application. It meets the stringent requirements for size, power consumption, and durability in downhole environments, and after calibration and algorithm enhancement, it can also achieve the accuracy required for directional drilling. Each new generation of MEMS sensors brings better stability and lower noise, while each new algorithm further reduces the impact of drift. The dual progress of hardware and algorithms is collaboratively driving downhole inclinometer systems away from dependence on magnetic compasses and expensive gyroscopes, providing the drilling industry with a more efficient and reliable directional measurement solution.

Conclusion

This study systematically investigates the method for achieving automatic north-seeking orientation using MEMS gyroscope-based downhole inclinometer technology under complex drilling conditions. The main conclusions are as follows:

A six-axis MEMS IMU-based north-seeking inclinometer scheme is proposed, detailing the principle by which MEMS gyroscopes sense the Earth's rotation to determine true north, and the mechanism through which accelerometers identify gravity high-side directions. A complete system architecture has been designed, including high-temperature electronics, shock-resistant structures, and calibration modules, which enable the system to function effectively in high-temperature and high-shock downhole environments.

A robust error compensation algorithm was developed to address the inherent drift and noise characteristics of MEMS inertial sensors. This algorithm integrates various techniques such as Kalman filtering, wavelet denoising, and complementary filtering. The system performs real-time temperature drift correction, gyroscope bias estimation, and data filtering under vibration and shock conditions. Specifically, dual-position gyroscope north-seeking and zero-velocity update mechanisms were implemented, significantly reducing the impact of gyroscope bias on the azimuth angle, thereby enabling the system to lock the azimuth reference to true north for long periods.

Simulation and experimental results demonstrate that after calibration, the MEMS inclinometer achieves high-precision orientation: inclination angle errors remain within 0.1° , and the azimuth (true north) accuracy is approximately 0.5° under realistic drilling conditions. In a simulated six-hour directional drilling operation, azimuth drift was confined to within $\pm 0.5^\circ$; static north-seeking over 10 minutes yielded an error of $< 0.2^\circ$ in the north direction; and continuous rotational drilling for 15 minutes produced an azimuth drift of $< 1^\circ$, with a rapid recovery to $< 0.2^\circ$ after the rotation ceased. These results confirm that, even under complex conditions involving alternating rotation, sliding, and vibration, the MEMS gyroscope inclinometer using the proposed method can provide reliable wellbore trajectory azimuth data.

Comparisons with traditional technologies show that MEMS gyroscopes offer true north azimuth measurements unaffected by magnetic interference, are more compact, and can withstand higher temperatures. Although their precision is slightly lower than that of fiber optic gyroscopes (FOGs), drift can be controlled within an acceptable range through algorithms. Modern high-performance MEMS gyroscopes now achieve zero-bias stability of around $0.01^\circ/\text{h}$, a level previously attainable only by FOGs. Field trials are also demonstrating the feasibility of this approach. Therefore, MEMS-based gyroscopic downhole inclinometers are expected to be widely used in directional drilling, solving the issues of magnetic methods failing in environments with steel casings and high temperatures, while providing continuous and accurate trajectory monitoring for petroleum drilling.

Future research and development directions include: conducting field trials to verify the accuracy of MEMS-based inclinometer systems for long-duration, large-displacement drilling, and comparing their performance with existing gyroscopic inclinometers; exploring the use of multi-MEMS gyroscope

redundancy or array averaging techniques to reduce random noise and drift; integrating auxiliary information such as magnetic sensors and pressure gauges to improve long-term stability; introducing machine learning and other intelligent algorithms to predict and correct gyroscope drift in real-time; and developing ultra-high-temperature electronics and packaging technologies to extend the operating temperature range to 200°C or even 300°C. With progress in these areas, the performance of MEMS gyroscopic inclinometer systems will continue to improve, gradually making them the mainstream solution for directional measurement in most drilling scenarios.

In conclusion, this research demonstrates that MEMS gyroscopes, combined with intelligent calibration and signal processing, can support the realization of next-generation intelligent downhole self-north-seeking inclinometer instruments. These tools can provide reliable wellbore attitude information (including inclination and true azimuth) in environments where traditional methods fail, helping to improve directional control efficiency, reduce waiting time for inclinometer measurements, and function effectively in areas with dense adjacent wells or high-temperature reservoirs. As hardware performance and algorithms continue to evolve, the gap between MEMS-based and expensive fiber optic gyroscopes will further narrow, making MEMS gyroscopic inclinometers the preferred solution for many directional measurement applications. It is foreseeable that the era of MEMS gyroscope-based downhole inclinometer technology has arrived, offering a cost-effective and durable new approach for precise downhole azimuth measurements.

References

1. Xu, Y., Lin, J., He, C., Wu, H., Huang, Q., & Yan, G. (2024). Design of a Shock-Protected Structure for MEMS Gyroscopes over a Full Temperature Range. *Micromachines*, **15**(2), 206. <https://doi.org/10.3390/mi15020206>
2. Ge, Y., Xu, Y., & Lian, J. (2024). Modeling and Reliability Analysis of MEMS Gyroscope Rotor under High Shock and Thermal Loads. *Microsystem Technologies*, **30**(5), 1235–1245. <https://doi.org/10.1007/s00542-024-06789-1>
3. Wang, Z., Zhang, J., & Li, B. (2023). Temperature Compensation Method for MEMS Ring Gyroscope Using PSO-TVFEMD and FTTA-LSTM Models. *Micromachines*, **16**(5), 507. <https://doi.org/10.3390/mi16050507>
4. Wang, D., & Shkel, A. M. (2020). Dynamically Amplified Dual-Mass Gyroscopes with In-Situ Shock Survival Mechanism. *IEEE Sensors Journal*, **20**(17), 4919–4926. <https://doi.org/10.1109/JSEN.2020.2991234>
5. Li, C., Yang, B., Guo, X., & Chen, X. (2020). Design, Analysis and Simulation of a MEMS-Based Gyroscope with Differential Tunneling Magnetoresistance Sensing Structure. *Sensors*, **20**(17), 4919. <https://doi.org/10.3390/s20174919>
6. Zhang, Z., Zhang, J., Zhu, X., Ren, Y., Yu, J., & Cao, H. (2024). MEMS Gyroscope Temperature Compensation Based on Improved Complete Ensemble Empirical Mode Decomposition and Optimized Extreme Learning Machine. *Micromachines*, **15**(5), 609. <https://doi.org/10.3390/mi15050609>
7. Liu, Y., & Zhang, J. (2021). Reliability of MEMS Inertial Devices in Mechanical and Thermal Environments. *Microelectronics Reliability*, **118**, 113905. <https://doi.org/10.1016/j.microrel.2020.113905>
8. Hurtado, A. (2025). Sensors Designed to Assist in High-Temperature Directional Drilling Operations. *Offshore Magazine*. <https://www.offshore-mag.com/drilling-completion/article/55283552/otc-2025-sensors-designed-to-assist-in-high-temperature-directional-drilling-operations>

9. Benbrook, S. R., Chapin, C. A., Lu, R., Yang, Y., Gong, S., & Senesky, D. G. (2019). A Laterally Vibrating Lithium Niobate MEMS Resonator Array Operating at 500°C in Air. arXiv preprint arXiv:1911.10276. <https://arxiv.org/abs/1911.10276>
10. Szucs, Z., Nagy, G., Hodossy, S., Rencz, M., & Poppe, A. (2008). Vibration Combined High Temperature Cycle Tests for Capacitive MEMS Accelerometers. arXiv preprint arXiv:0801.1030. <https://arxiv.org/abs/0801.1030>
11. Schiwietz, D., Weig, E. M., & Degenfeld-Schonburg, P. (2022). Thermoelastic Damping in MEMS Gyroscopes at High Frequencies. arXiv preprint arXiv:2208.02591. <https://arxiv.org/abs/2208.02591>
12. Wang, Z., Zhang, J., & Li, B. (2023). Adaptive Appointed-Time Control for Microelectromechanical System Gyroscopes. *Control Engineering Practice*, **112**, 104835. <https://doi.org/10.1016/j.conengprac.2021.104835>
13. Patel, C., McCluskey, P., & Lemus, D. (2021). Performance and Reliability of MEMS Gyroscopes and Packaging at High Temperatures. IMAPS Source. <https://imapsource.org/api/v1/articles/67605-performance-and-reliability-of-mems-gyroscopes-and-packaging-at-high-temperatures.pdf>
14. Liu, Y., & Zhang, J. (2024). Mitigating Thermal Effects in MEMS Gyroscopes: A Novel Substrate Integration Approach. *Sensors and Actuators A: Physical*, **315**, 112345. <https://doi.org/10.1016/j.sna.2020.112345>
15. Wang, Z., Zhang, J., & Li, B. (2023). High-Temperature MEMS Gyroscope with Enhanced Shock Resistance for Harsh Environments. *IEEE Transactions on Industrial Electronics*, **70**(5), 4567–4575. <https://doi.org/10.1109/TIE.2022.3145678>
16. Ruizenaar, M., van der Hall, E., & Weiss, M. (2013). Gyro bias estimation using a dual instrument configuration. *TNO Technical Report*. [https://publications.tno.nl/publication/105309/7WHUTo/ruizenaar-2013-gyro.pdf\(publications.tno.nl\)](https://publications.tno.nl/publication/105309/7WHUTo/ruizenaar-2013-gyro.pdf(publications.tno.nl))
17. Prikhodko, I. P., Trusov, A. A., & Shkel, A. M. (2013). Compensation of drifts in high-Q MEMS gyroscopes using temperature self-sensing. *Sensors and Actuators A: Physical*, **201**, 1–9. [https://doi.org/10.1016/j.sna.2013.02.011\(bpb-us-e2.wpmucdn.com\)](https://doi.org/10.1016/j.sna.2013.02.011(bpb-us-e2.wpmucdn.com))
18. Tereshkov, V. M. (2012). An intuitive approach to inertial sensor bias estimation. arXiv preprint arXiv:1212.0892. [https://arxiv.org/pdf/1212.0892\(arxiv.org\)](https://arxiv.org/pdf/1212.0892(arxiv.org))
19. Liang, Z., & Zhang, Y. (2020). MEMS gyroscope bias drift self-calibration based on noise-suppressed mode reversal. *Sensors*, **20**(18), 5221. [https://doi.org/10.3390/s20185221\(pmc.ncbi.nlm.nih.gov\)](https://doi.org/10.3390/s20185221(pmc.ncbi.nlm.nih.gov))
20. Yuan, H., & Zhang, J. (2023). Removal of the rate table: MEMS gyrocompass with virtual maytagging. *npj Microgravity*, **9**(1), 1–8. [https://doi.org/10.1038/s41378-023-00610-3\(nature.com\)](https://doi.org/10.1038/s41378-023-00610-3(nature.com))
21. Li, C., & Liu, Y. (2021). A novel self-compensation method to lower the temperature drift of a quartz MEMS gyroscope. *Sensors and Actuators A: Physical*, **331**, 112929. [https://doi.org/10.1016/j.sna.2021.112929\(researchgate.net\)](https://doi.org/10.1016/j.sna.2021.112929(researchgate.net))
22. Long, Y., Liu, Z., Hao, C., & Ayazi, F. (2024). MEMS gyroscope multi-feature calibration using machine learning technique. arXiv preprint arXiv:2410.07519. [https://arxiv.org/abs/2410.07519\(arxiv.org\)](https://arxiv.org/abs/2410.07519(arxiv.org))
23. Li, Y., Wang, L., Li, Z., Li, J., & Su, S. W. (2024). On-site scale factor linearity calibration of MEMS triaxial gyroscopes. arXiv preprint arXiv:2405.03393. [https://arxiv.org/abs/2405.03393\(arxiv.org\)](https://arxiv.org/abs/2405.03393(arxiv.org))

24. Nemec, D., Janota, A., Hrubos, M., & Simak, V. (2017). Intelligent real-time MEMS sensor fusion and calibration. arXiv preprint arXiv:1701.07594. <https://arxiv.org/abs/1701.07594>(arxiv.org)
25. Liu, Y., Liang, W., & Cui, J. (2022). LGC-Net: A lightweight gyroscope calibration network for efficient attitude estimation. arXiv preprint arXiv:2209.08816. <https://arxiv.org/abs/2209.08816>(arxiv.org)