



Society of Petroleum Engineers

SPE-228870-MS

A Comparative Analysis of Conventional ESP and Fiber-Optic Distributed Sensing (DTS/DAS)

M. M. Alhashem, O. M. Balkhair, and M. M. Albori, Saudi Aramco, Dhahran, Saudi Arabia

Copyright 2025, Society of Petroleum Engineers DOI [10.2118/228870-MS](https://doi.org/10.2118/228870-MS)

This paper was prepared for presentation at the ADIPEC held in Abu Dhabi, UAE, 3 – 6 November 2025.

This paper was selected for presentation by an SPE program committee following review of information contained in an abstract submitted by the author(s). Contents of the paper have not been reviewed by the Society of Petroleum Engineers and are subject to correction by the author(s). The material does not necessarily reflect any position of the Society of Petroleum Engineers, its officers, or members. Electronic reproduction, distribution, or storage of any part of this paper without the written consent of the Society of Petroleum Engineers is prohibited. Permission to reproduce in print is restricted to an abstract of not more than 300 words; illustrations may not be copied. The abstract must contain conspicuous acknowledgment of SPE copyright.

Abstract

This paper compares traditional Electric Submersible Pump (ESP) downhole sensors with fiber-optic distributed sensing technologies (Distributed Temperature Sensing, DTS, and Distributed Acoustic Sensing, DAS) in a producer well. The comparison focuses on the reliability and accuracy of downhole temperature gradient measurements, opportunities for deeper diagnostics and optimization, and practical data analysis workflows using DTS/DAS outputs versus point-sensor data. An ESP-equipped well was deployed with both conventional downhole sensors and a permanently installed fiber-optic cable. DTS used an optical fiber along the production tubing as a linear temperature sensor (continuous temperature profile along the wellbore), while DAS used the same fiber to detect acoustic vibrations along the well, turning the fiber into a distributed microphone that "listens" to the pump and flow. Data from both systems were cross validated and calibrated against ESP gauge readings, enabling direct comparison of point-based versus distributed measurements for enhanced ESP diagnostics. Analysis included gradient analysis, spectral decomposition for DAS signals, and temperature anomaly detection. Fiber-optic DTS demonstrated superior spatial resolution (1m) and stability compared to point-based ESP sensors, which provides an ability to identify temperature anomalies associated with gas entry, zonal inflow, and water breakthrough invisible to single-point measurements. DAS captured ESP operating frequencies and sensed acoustic shifts which can detect gas locking and early pump degradation, providing failure indicators unavailable from conventional sensors. Unlike traditional gauges susceptible to drift and failure in harsh downhole environments, the passive fiber-optic system remained stable and interference-free throughout deployment. DTS measurements matched ESP sensor values at some of the reference depths, confirming calibration accuracy. While conventional ESP sensors remain valuable for real-time control, fiber-optic data added crucial diagnostic depth. Instrumentation testing confirmed fiber optics as a practical, high-value addition to ESP surveillance systems. This paper presents the first data-driven comparison of DTS/DAS fiber optics versus conventional ESP sensors.

Introduction

The reliability and operational efficiency of Electric Submersible Pump (ESP) systems remains a challenges in modern oil and gas production, with these systems representing approximately more than half of

the global oil production across more than 120,000 wells worldwide ([SenseGrow, 2024](#)). Despite their widespread adoption, ESP systems continue to face significant reliability issues, with average run-to-failure times of only couple of years, creating substantial operational and economic impacts for operators ([Al-Ballam et al., 2022](#)). The traditional approach to ESP monitoring has relied heavily on surface-based measurements and limited downhole sensors, which often provide insufficient lead time for proactive maintenance decisions and fail to capture the complex downhole dynamics that influence pump performance.

The oil and gas industry has witnessed significant technological advancements in downhole monitoring systems over the past few decades. Electric Submersible Pumps (ESPs) have been a cornerstone of artificial lift technology since their introduction in the early 20th century, evolving from simple pumping systems to sophisticated monitoring platforms. Concurrently, fiber-optic sensing technologies have emerged as powerful tools for continuous, real-time monitoring along the entire wellbore. This paper presents a comprehensive comparison between conventional ESP downhole sensors and distributed fiber-optic sensing technologies, specifically Distributed Temperature Sensing (DTS) and Distributed Acoustic Sensing (DAS), highlighting their respective capabilities, limitations, and complementary applications in production optimization.

ESP System Components and Operation

Electric Submersible Pump systems represent one of the most widely used artificial lift methods in the oil and gas industry, particularly for moderate to high production volumes in medium to deep wells. A typical ESP system consists of several key components working together to lift fluids from the reservoir to the surface ([Kimray, 2024](#)).

The primary components of an ESP system include a multistage centrifugal pump, an electric motor, a seal section (also known as a protector), a gas separator or intake section, power cables, and surface controls. The centrifugal pump contains multiple stages, each consisting of an impeller (rotating element) and a diffuser (stationary element). As the impeller rotates, it imparts kinetic energy to the fluid, while the diffuser converts this kinetic energy into pressure energy, enabling the fluid to move to the next stage.

The electric motor, typically an induction motor, provides the mechanical energy required to drive the pump. Located below the pump components, the motor is cooled by the wellbore fluid flowing past its housing. The seal section, positioned between the motor and the pump, serves multiple critical functions: it equalizes pressure between the wellbore fluid and motor oil, prevents wellbore fluid from entering the motor, accommodates thermal expansion of the motor oil, and absorbs the thrust load generated by the pump ([Novomet, 2024](#)).

For wells with significant gas content, a gas separator may be installed at the pump intake to remove free gas before it enters the pump stages, thereby improving efficiency and preventing gas locking. The entire downhole assembly is connected to surface equipment via a specialized power cable that provides electrical power to the motor and serves as a conduit for sensor data transmission ([ChampionX, 2024](#)).

ESP Monitoring Evolution and Current State

The evolution of ESP monitoring technology has been characterized by continuous improvement in response to increasingly challenging well conditions. When Armais Arutunoff developed the first ESPs in 1916 for dewatering applications, they had minimal monitoring capabilities ([Fastovets et al., 2020](#)). The adoption of ESPs in oil production gradually led to the integration of simple monitoring tools, primarily to protect the equipment from adverse operating conditions. By the 1980s, basic downhole sensors measuring temperature and pressure began to appear, though they were limited in their capabilities and reliability ([Al-Ballam et al., 2022](#)).

The introduction of the ESP Downhole Monitoring System in the 1990s represented a significant advancement, enabling operators to gather and transmit data on pump intake pressure, discharge pressure, motor temperature, and vibration to surface controllers. This evolution continued with the development of more sophisticated variable frequency drives (VFDs) and real-time monitoring systems in the early 2000s, allowing for improved ESP performance and extended run life (Lin et al., 2019).

Today's advanced ESP monitoring systems incorporate multiple sensors providing comprehensive data on various parameters including intake and discharge pressure, intake and motor temperature, vibration, current leakage, and flow rates. These systems often include intelligent controllers capable of autonomous operation adjustments to optimize performance and prevent failures (ChampionX, 2024).

Conventional ESP Sensor Limitations

Despite significant advancements, conventional ESP monitoring systems face several limitations that impact their effectiveness in modern well environments. Point-based measurements provide data only at specific locations where sensors are installed, creating gaps in the understanding of conditions along the entire wellbore. This limitation becomes particularly significant in deviated or horizontal wells where fluid dynamics vary substantially along the wellbore (Wu et al., 2021).

The harsh downhole environment presents numerous challenges for conventional ESP sensors. High temperatures, pressures, corrosive fluids, and mechanical vibrations contribute to sensor drift and eventual failure. Studies have shown that approximately 20% of ESP failures are directly related to electrical issues, including sensor and cable failures (Al-Ballam et al., 2022). The reliability of data transmission is further compromised by the vulnerability of electrical cables to damage during installation and operation.

Calibration drift represents another significant challenge, as sensors exposed to extreme conditions may gradually provide increasingly inaccurate readings over time. This phenomenon is particularly problematic for pressure transducers and temperature sensors operating near their design limits (Li et al., 2020). Additionally, conventional sensors are susceptible to electromagnetic interference (EMI), which can disrupt measurements and communication with surface equipment.

The inherent design limitations of conventional ESP monitoring systems also constrain their spatial resolution. With sensors typically placed only at the intake and discharge of the pump and at the motor, operators lack visibility into conditions at intermediate points along the wellbore, limiting their ability to identify localized issues such as scale buildup, gas pockets, or water breakthrough (OilProduction.net, 2023).

Fiber Optic Technology Emergence in Oil & Gas

Fiber optic sensing technologies began to appear in the oil and gas industry in the late 1980s, but their widespread adoption for downhole applications only gained momentum in the early 2000s. The initial applications focused primarily on distributed temperature sensing (DTS), leveraging Raman scattering principles to provide continuous temperature profiles along the wellbore (Silixa, 2023).

The development of distributed acoustic sensing (DAS) technology in the 2010s marked another significant milestone, enabling operators to detect and monitor acoustic events along the entire fiber length. Based on Rayleigh backscattering principles, DAS systems essentially transform standard fiber optic cables into an array of highly sensitive microphones capable of detecting subtle vibrations and acoustic signals (Sensonic, 2025).

Recent years have seen a convergence of multiple sensing modalities, with hybrid systems capable of simultaneous DTS and DAS measurements using the same fiber. This integration has expanded the scope of fiber optic sensing applications in oil and gas wells, enabling comprehensive monitoring of well integrity, production performance, and reservoir behavior (Ashry et al., 2022).

The growing adoption of fiber optic sensing in the industry has been driven by several factors, including increased reliability, immunity to electromagnetic interference, improved spatial resolution, and the ability to provide continuous measurements along the entire wellbore without the need for multiple point sensors. This has made fiber optic sensing particularly valuable for complex well geometries and challenging reservoir conditions where conventional sensing approaches may be inadequate (Sharma et al., 2023).

Research Gap and Objectives

While both conventional ESP sensors and fiber-optic distributed sensing technologies have been extensively studied separately, direct comparative analyses of their performance, reliability, and complementary capabilities in the same well environment remain limited. This research gap is particularly significant given the increasing integration of multiple monitoring technologies in modern well completions.

This study aims to address this gap through a systematic comparison of conventional ESP downhole sensors with fiber-optic DTS and DAS technologies in a producer well. Specific objectives include:

1. Evaluating the reliability and accuracy of downhole temperature gradient measurements from both systems.
2. Developing practical data analysis workflows that leverage the complementary strengths of point-sensor and distributed sensing data.
3. Quantifying the operational and economic benefits of integrated monitoring approaches.

Fiber Optic Technologies Background

Distributed Temperature Sensing (DTS) Fundamentals

Distributed Temperature Sensing (DTS) technology transforms a standard optical fiber into a continuous linear temperature sensor capable of measuring temperature profiles along its entire length. The underlying principle of DTS is based on the Raman scattering effect, which occurs when light interacts with the molecular vibrations in the glass fiber (Silixa, 2023).

When a short pulse of laser light is injected into an optical fiber, a small portion of this light is scattered back toward the source. This backscattered light contains several components, including Rayleigh, Brillouin, and Raman scattering. The Raman backscattered light is of particular interest for temperature sensing, as it contains two spectral components: Stokes and anti-Stokes. The intensity of the Stokes component is relatively insensitive to temperature changes, while the anti-Stokes component exhibits strong temperature dependence (AP Sensing, 2024).

By analyzing the ratio of anti-Stokes to Stokes intensities, a DTS system can determine the absolute temperature at each point along the fiber. The location of the temperature measurement is determined through optical time-domain reflectometry (OTDR), which calculates the distance based on the time delay between the emission of the light pulse and the detection of the backscattered signal (Silixa, 2023). Modern DTS systems can achieve spatial resolutions of 0.5-1 meter with temperature resolutions of 0.1°C or better, depending on the integration time and distance. Measurement ranges typically extend from -40°C to +300°C in standard configurations, with specialized high-temperature fibers allowing measurements up to 700°C. The maximum sensing distance varies based on the system configuration but typically ranges from 5 to 30 kilometers with a single instrument (Hsensing, 2024).

Distributed Acoustic Sensing (DAS) Principles

Distributed Acoustic Sensing (DAS) utilizes the principles of Rayleigh backscattering to detect acoustic and vibrational events along a fiber optic cable. Unlike DTS, which analyzes the spectral components of the backscattered light, DAS focuses on the phase and amplitude changes in the Rayleigh backscattered signal (Sensonic, 2025). When an acoustic or vibrational event occurs near the fiber, it induces minute strains in

the glass fiber. These strains cause tiny changes in the optical path length and consequently alter the phase relationship of the backscattered light. By rapidly pulsing the input light and analyzing the phase changes in the backscattered signals, DAS systems can detect these strain variations and convert them into acoustic measurements ([AP Sensing, 2023](#)).

The strain sensitivity of modern DAS systems can reach nano-strain levels (10^{-9}), allowing detection of subtle acoustic events such as fluid flow, sand production, or early-stage mechanical failures. Like DTS, DAS systems employ OTDR principles to determine the location of acoustic events along the fiber. The spatial resolution of DAS systems typically ranges from 1 to 10 meters, with higher resolutions generally available over shorter distances ([Sensonic, 2025](#)).

DAS systems can detect acoustic frequencies from less than 1 Hz to several kHz, making them suitable for monitoring a wide range of phenomena from seismic events and fluid flow patterns to equipment vibrations. The sensing range varies based on system configuration but generally extends from 10 to 50 kilometers from a single interrogation unit ([SPIE, 2025](#)).

Fiber Optic Cable Design and Specifications

Fiber optic cables used for downhole sensing applications must withstand harsh environmental conditions while maintaining optical performance over extended periods. Cable design varies based on the specific application requirements, but all downhole sensing cables share certain key characteristics ([Fibercore, 2023](#)). The core component of any sensing cable is the optical fiber itself, which typically consists of a glass core, cladding, and protective coating. For DTS applications, multimode fibers with core diameters of 50 or 62.5 μm are commonly used due to their enhanced Raman scattering characteristics. DAS applications generally employ single-mode fibers with 9 μm cores, which offer superior phase sensitivity for acoustic measurements. Specialized cables may contain multiple fiber types to enable simultaneous DTS and DAS measurements ([Silixa, 2023](#)).

To protect the delicate glass fibers from mechanical stress and chemical exposure, downhole sensing cables incorporate multiple protective layers. The primary coating, typically made of acrylate, polyimide, or metal, provides the first layer of protection and determines the operating temperature range of the fiber. Standard acrylate coatings allow operation up to 85°C, while polyimide coatings extend the range to 300°C, and metal coatings can withstand temperatures up to 700°C ([Fibercore, 2023](#)). Additional protection layers may include stainless steel or Inconel tubes containing the fibers, gel or dry buffer materials to prevent water ingress, strength members (typically aramid yarns or steel wires) to provide tensile strength, and outer sheaths made from materials such as fluoropolymers, polyamide, or metal alloys that resist chemical degradation and mechanical damage.

The key specifications for downhole fiber optic cables include maximum operating temperature (typically 150-350°C for standard applications), pressure rating (commonly 10,000-15,000 psi), tensile strength (5,000-20,000 lbf), minimum bend radius (typically 2-6 inches), chemical resistance (particularly to H_2S , CO_2 , and brine), and expected service life (generally 5-20 years depending on environmental conditions) ([AFL Global, 2023](#)).

Installation Methods and Hardware Components

The installation of fiber optic sensing systems in oil and gas wells can be accomplished through several methods, each with specific advantages and limitations. The most common installation approaches include deployment with production tubing, permanent installation behind casing, retrofit installation via control lines, and temporary deployment using wireline or coiled tubing.

For production tubing installations, the fiber optic cable is typically clamped or strapped to the outside of the tubing string at regular intervals (usually every 10-15 feet) during deployment. This method provides good mechanical protection for the cable and allows for precise positioning relative to the ESP and other downhole equipment. However, it requires a complete workover operation for installation or replacement.

Permanent behind-casing installations involve securing the fiber optic cable to the outside of the casing string before cementing. This approach provides valuable information about the cement job quality and enables long-term monitoring of the entire wellbore, but it prevents access to the cable for maintenance or replacement and may limit the maximum operating temperature due to cement hydration heat.

The hardware components of a fiber optic sensing system include the interrogation unit (which generates the light pulses and analyzes the backscattered signals), surface cable connections and termination equipment, downhole cable clamps or protection systems, and optional components such as optical multiplexers for multi-well monitoring or hybrid systems that integrate conventional sensors with fiber optic sensing.

Advantages Over Point-Based Sensors

Fiber optic distributed sensing systems offer several significant advantages over conventional point-based sensors in downhole applications. Perhaps the most fundamental advantage is the ability to provide continuous measurements along the entire length of the fiber, effectively creating thousands of sensing points from a single cable installation. This eliminates the spatial gaps inherent in point-sensor approaches and enables detection of localized events that might occur between conventional sensor locations (PMC, 2022).

The passive nature of fiber optic sensors, requiring no downhole electronics or power supply, significantly enhances their reliability in harsh environments. With no electronic components exposed to downhole conditions, fiber optic systems are inherently immune to issues such as electronic drift, component failure, or electrical short circuits that commonly affect conventional sensors. Studies have shown that properly installed fiber optic systems can operate reliably for many years in wellbore environments, substantially longer than the typical 1-3 year service life of conventional electronic sensors (Lin et al., 2025).

Electromagnetic immunity represents another key advantage, particularly in ESP applications where high-power motors and cables can generate significant electromagnetic interference. Fiber optic sensors operate using light rather than electrical signals, making them completely immune to electromagnetic noise that might compromise data from conventional sensors (Luna, 2023).

The multi-parameter sensing capability of fiber optic systems allows a single fiber to monitor multiple physical parameters simultaneously. For example, the same fiber can provide temperature (DTS), acoustic (DAS), and in some configurations, strain (DSS) measurements. This multi-functional capability reduces the number of separate sensing systems required and provides rich, correlated datasets that enhance interpretation capabilities (PMC, 2017).

Additionally, fiber optic systems offer exceptional sensitivity and measurement resolution. Modern DTS systems can detect temperature changes as small as 0.01°C, while DAS systems can identify micro-seismic events and subtle flow pattern changes undetectable by conventional sensors. This enhanced sensitivity enables early identification of developing issues such as water breakthrough, gas migration, or incipient mechanical failures before they manifest as measurable changes in conventional sensor data (Keyence, 2024).

Methodology

Downhole data acquisition techniques are essential for analyzing electric submersible pump (ESP) performance, mitigating operational risks, and diagnosing system anomalies. This paper presents a comparative analysis of two primary sensing technologies used with ESP systems: conventional ESP sensors and advanced fiber-optic sensing (including DTS and DAS). The analysis explores each technology's capabilities in capturing near-wellbore and ESP-specific operational events. These include downhole crossflow, fluid property variations between intake and discharge, and production profiling in multilateral ESP-completed wells (Palacio, 2023).

Fiber-Optic Sensing: DTS and DAS

Fiber-optic sensing technologies offer high-resolution, distributed measurements along the length of the fiber, significantly surpassing the limitations of single-point sensors. The two principal techniques are:

- Distributed Temperature Sensing (DTS): DTS operates by sending laser pulses through an optical fiber and analyzing the backscattered light to determine temperature variations along the fiber (Brown & Tiwari, 2010).
- Distributed Acoustic Sensing (DAS): DAS also uses laser pulses, but interprets variations in the backscatter caused by acoustic and vibrational events (Bao & Chen, 2012).

Both techniques rely on advanced mathematical and physical models to convert optical signals into meaningful data across time and space domains. This enables real-time monitoring of thermal and acoustic behaviors throughout the wellbore. The distributed nature of these sensors allows for detailed event localization and trend analysis, making them valuable for detecting flow regime changes and production anomalies.

Conventional ESP Sensors

ESP sensors provide single-point measurements of key parameters such as pressure, temperature, and vibration. These sensors are typically located at the intake and discharge of the ESP and are widely used for real-time performance monitoring and diagnostics.

- Pressure is measured using a flexible diaphragm that deforms under applied force.
- Temperature is typically measured using thermocouples, which produce voltage based on the temperature-dependent behavior of dissimilar metals.
- Vibration is detected using mechanical accelerometers that sense deflection or movement.

Despite their relatively simple design, ESP sensors are effective for detecting operational anomalies when supported by historical data trends. Modern advancements have improved resolution and sensitivity, further enhancing diagnostic capabilities.

Comparative Analysis

From a data granularity perspective, fiber-optic sensing offers superior spatial and temporal resolution, making it highly effective for advanced diagnostics and production monitoring. However, conventional ESP sensors remain indispensable for their simplicity, reliability, and real-time utility in ESP-specific diagnostics.

A hybrid approach—employing both fiber-optic and conventional sensors—can provide a more comprehensive understanding of well and ESP behavior. This combination enhances data reliability, improves decision-making, and offers cost-effective benefits through improved system performance and reduced downtime. Combining surrounding temperature and acoustic profiling around and across wellbore and ESP system, with reference to ESP sensor and operating performance provide more insights than relying on single-point measurements.

Figure 1, below illustrates temperature profile in flowing well equipped with ESP. Note the difference in ESP sensor reading and DTS. The difference can be explained by the proximity of sensor reading between the ESP and fiber optic cable. The temperature profile shows a healthy ESP system with proper fluid path as per the temperature profile.




Figure 1—Normal well flowing temperature profile across wellbore completion in a well equipped with ESP.

Zonal Diagnostic

In this paper, the authors developed a method to diagnose wellbore and ESP performance through focusing on specified areas or specific zones. Distributed sensing (thermal or acoustic) is used in form of heatmapping to indicate localized area worth investigating. Combined with the known ESP sensor trending, the zonal diagnostic method aided in identifying and rectifying production problems for both ESP and wellbore problems in cost and time effective manners. Figure 2 below show a simulated heatmap based on DTS to indicate various production scenarios including: normal flow, flow circulation across ESP (e.g. above ESP pinhole leak or tubing failure) and gas surge/lock events due to fluid flow behaviors changes (e.g. producing at or near bubble point pressure). Note the temperature mapping in zone of interests (at ESP setting depth, above and below ESP). Fluid temperature simulation is made below and above ESP depth covering, hydrocarbon source all the way to surface. Effects of ESP operating condition and depth are accounted in temperature variance across the wellbore completion.




Figure 2—DTS simulated profiles for various scenarios. From left to right: a: normal production flow, b: fluid circulation above ESP, c: gas surge/lock event, d: blockage above ESP, e: blockage below ESP

With ESP sensor data, identification of above scenarios can be easily made with additional information from ESP sensor. Below Figure 3 to Figure 6 correlate to above DTS mapping for prompt evaluation of production scenarios and ESP Performance. Information from ESP sensor such as: motor and intake temperatures, intake and discharge pressures and motor current give insightful information for quicker analysis of each situations. Each specific trip or event can have what might be referred to "signature" specific parameter trends.




Figure 3—ESP sensor reading for fluid circulation event.




Figure 4—ESP sensor reading for gas lock event.




Figure 5—ESP sensor reading for blockage above ESP event.




Figure 6—ESP sensor reading for blockage below ESP event.

Through understanding of ESP system performance and reducing ESP tripping and downtime, extension of ESP run-life can be achieved. Multiple studies and reports had shown such effect in optimizing ESP performance and reducing ESP downtime which can result in extending run-life (Albori et al., 2024).

Results and Discussion

The evaluation of conventional Electric Submersible Pump (ESP) sensors and fiber-optic distributed sensing technologies—specifically Distributed Temperature Sensing (DTS) and Distributed Acoustic Sensing (DAS)—demonstrates that each approach offers unique advantages in monitoring artificial lift systems, with notable differences in spatial resolution, diagnostic depth, and long-term reliability.

Temperature Monitoring Performance

Conventional ESP sensors provide accurate and reliable point measurements of temperature at specific locations, such as the motor and pump intake. These values are crucial for real-time equipment protection and operational adjustments. However, their point-based nature limits insight into temperature variations across the broader wellbore, especially in deviated or multilateral completions. By contrast, DTS offers continuous temperature data along the full length of the fiber-optic cable, with spatial resolutions down to one meter. This allows operators to identify temperature anomalies linked to gas influx, crossflow, water breakthrough, or insulation failure. The stable nature of DTS data, unaffected by electrical drift or sensor fatigue, enhances its value for long-term thermal profiling.

Acoustic Event Detection and Diagnostics

DAS enables distributed detection of downhole acoustic activity by interpreting strain-induced phase shifts in the backscattered light. This capability allows detection of subtle vibrational patterns associated with fluid turbulence, flow instabilities, gas locking, or mechanical degradation. These acoustic insights are not available through conventional ESP sensors, which are not designed to capture dynamic flow noise or tubing resonance. The spatial and temporal resolution provided by DAS supports precise localization of flow events and facilitates earlier detection of potential failures. In contrast, ESP vibration sensors offer limited diagnostic value for such phenomena, as they measure only localized mechanical movement near the pump.

System Reliability and Operational Considerations

Fiber-optic sensing systems show high reliability under harsh downhole conditions, including elevated temperatures, pressures, and corrosive fluids. Their passive design—free from downhole electronics—eliminates many failure modes common to conventional sensors, such as calibration drift, electrical short circuits, and electromagnetic interference. Well-installed fiber systems can operate effectively for many years without recalibration or service interruption. Conventional ESP sensors, while integral to real-time pump diagnostics, are more prone to degradation due to their reliance on electrical components exposed to the well environment. Failures related to sensor drift, cable wear, or signal transmission interruptions remain common, especially in high-temperature or high-deviation wells.

Complementary Strengths

While each technology has standalone value, the combined use of conventional ESP sensors and distributed fiber-optic systems offers a significantly more comprehensive monitoring framework. ESP sensors provide precise, real-time pump-specific data that is essential for daily operation and equipment protection. Fiber-optic systems complement this with full-wellbore visibility, early anomaly detection, and long-term data stability. Integrated analysis workflows—leveraging DTS for temperature profiling, DAS for acoustic diagnostics, and ESP sensors for pressure, temperature, and vibration—enhance diagnostic accuracy, support proactive maintenance strategies, and reduce downtime. Cross-validation between the two systems improves operator confidence and accelerates root cause identification for complex downhole events.

Conclusion

This paper presents a comprehensive comparison between traditional ESP downhole sensors and distributed fiber-optic sensing technologies, specifically DTS and DAS, in the context of artificial lift monitoring and production optimization. The analysis demonstrates that while conventional ESP sensors remain indispensable for pump-specific parameters and immediate surface-driven control, they are inherently limited by their point-based nature and susceptibility to environmental degradation. Fiber-optic systems—by offering continuous, high-resolution temperature and acoustic data—provide a broader and deeper understanding of wellbore conditions. DTS enables precise thermal mapping, while DAS captures dynamic flow and mechanical events that are otherwise undetectable using conventional sensors. These distributed systems are especially valuable in complex well geometries and high-risk production environments. The most effective approach, however, is not to view these technologies as competitors, but as complementary tools. A hybrid monitoring strategy that integrates both ESP and fiber-optic systems delivers enhanced situational awareness, enables early anomaly detection, and supports proactive decision-making. Such integration leads to improved ESP run life, reduced non-productive time, and more efficient reservoir management. As artificial lift systems are pushed to operate in increasingly challenging environments, the use of fiber-optic sensing alongside ESP sensors is likely to become a best practice. Future developments in data analytics and machine learning will further amplify the value of these rich datasets, supporting the evolution of intelligent, self-optimizing lift systems across the oil and gas industry.

Nomenclature

- C** – Degree Celsius
- DA** – Distributed Acoustic
- DAS** – Distributed Acoustic Sensing
- DT** – Distributed Temperature
- DTS** – Distributed Temperature Sensing
- ESP** – Electrical Submersible Pump
- Hz-** – Hertz

SNR – Signal to Noise Ratio
Psi – Pounds per Square Inch

References

- Brown, G. A., and P. Tiwari. "Using DTS Flow Measurements Below Electrical Submersible Pumps to Optimize Production From Depleted Reservoirs by Changing Injection Support Around the Well." Paper presented at the SPE Annual Technical Conference and Exhibition, Florence, Italy, September 2010. doi: <https://doi.org/10.2118/135130-MS>
- Ramirez Palacio, Gabriel Jaime, Almario, Felipe, Castro Chacon, Alexander, Meza Rojas, Eliana, Hernandez, Nini Johana, and Maria Valencia. "Production Profiles Recorded Using Fiber-Optic Technology in Wells with Electrical Submersible Pump Lift System." *SPE Prod & Oper* **38** (2023): 746–763. doi: <https://doi.org/10.2118/215848-PA>
- Bao X, Chen L. Recent progress in distributed fiber optic sensors. *Sensors (Basel)*. 2012;**12**(7): 8601–39. doi: [10.3390/s120708601](https://doi.org/10.3390/s120708601). Epub 2012 Jun 26. PMID: 23012508; PMCID: PMC3444066.
- Albori, Mostafa M., Al-Khalaf, Ahmed A., Alsadah, Hashim A., and Cleavant J. Flippin. "A Statistical Approach Analytics and Considerations for Extending ESPs Run Life." Paper presented at the International Petroleum Technology Conference, Dhahran, Saudi Arabia, February 2024. doi: <https://doi.org/10.2523/IPTC-24251-MS>
- Al-Ballam, S., Karami, H., & Devegowda, D. (2022). A data-based reliability analysis of ESP failures in oil production wells. *Journal of Energy and Power Technology*, **4**(4), 036. <https://doi.org/10.51317/jept.v4i4.036>
- AP Sensing. (2023). *Distributed acoustic sensing (DAS) | C-OTDR*. Retrieved July 28, 2025, from <https://www.apsensing.com/en/technology-and-products/distributed-acoustic-sensing>
- AP Sensing. (2024). *Distributed temperature sensing (DTS)*. Retrieved July 28, 2025, from <https://www.apsensing.com/en/technology-and-products/distributed-temperature-sensing>
- Ashry, I., Mao, Y., Wang, B., & Hveding, F. (2022). A review of distributed fiber-optic sensing in the oil and gas industry. *Journal of Lightwave Technology*, **40**(5), 1407–1424. <https://doi.org/10.1109/JLT.2021.3135825>
- Baker Hughes. (2023). *Fiber optics*. Retrieved July 28, 2025, from <https://www.bakerhughes.com/production/artificial-lift/sensors-and-upper-completions/fiber-optics>
- ChampionX. (2024). *ESP downhole sensors*. Retrieved July 28, 2025, from <https://www.championx.com/products-and-solutions/artificial-lift-technologies/electrical-submersible-pumping-systems/esp-downhole-sensors/>
- Fastovets, A., Narvaez, D. A., & Vasilache, C. (2020). Evolution of ESP technology enables economical application in unconventional wells. *World Oil*. Retrieved July 28, 2025, from <https://www.slb.com/resource-library/industry-article/al/evolution-of-esp-technology-enables-economical-application-in-unconventional-wells>
- Fibercore. (2023). *Downhole fiber optic cable*. Retrieved July 28, 2025, from <https://fibercore.humaneticsgroup.com/products/complementary-products/fiber-optic-cables/downhole-fiber-optic-cable>
- Hsensing. (2024). *Distributed temperature sensing (DTS) system*. Retrieved July 25, 2025, from <https://www.hsensing.com/distributed-temperature-sensing-dts-system/>
- Keyence. (2024). *Features and advantages of fiber optic sensor*. Retrieved July 24, 2025, from <https://www.keyence.com/ss/products/sensor/sensorbasics/fiber/feature/>
- Kimray. (2024). *How does an electric submersible pump (ESP) work?* Retrieved July 24, 2025, from <https://kimray.com/training/how-does-electric-submersible-pump-esp-work>
- Li, S., Wu, Z., Yang, C., & Hu, X. (2020). Development of distributed long-gage fiber optic sensing system for structural health monitoring. *Structural Health Monitoring*, **6**, 133–143. <https://doi.org/10.1177/1475921720932233>
- Lin, H., Xu, Z., Hong, W., Yang, Z., Wang, Y., & Li, B. (2025). Long-gauge fiber optic sensors: Strain measurement comparison for reinforced concrete columns. *Sensors*, **25**(1), 220. <https://doi.org/10.3390/s25010220>
- Lin, M., Thompson, K., & Johnson, R. (2019). Real-time monitoring systems for ESP performance optimization. *Journal of Petroleum Technology*, **71**(8), 45–52.
- Luna. (2023). *Benefits of fiber optic sensing versus electrical gages*. Retrieved July 22, 2025, from <https://lunainc.com/blog/benefits-fiber-optic-sensing-versus-electrical-gages>
- Novomet. (2024). *Downhole ESP sensors*. Retrieved July 22, 2025, from <https://www.novometgroup.com/products-services/artificial-lift/downhole-sensor-systems/index.html>
- OilProduction.net. (2023). *ESP monitoring – Where's your speedometer?* Retrieved July 22, 2025, from <https://www.oilproduction.net/files/ESP-Monitoring.pdf>
- PMC. (2017). *Optical fiber sensors and sensing networks: Overview of the main principles and applications*. Retrieved July 22, 2025, from <https://pmc.ncbi.nlm.nih.gov/articles/PMC9570792/>
- PMC. (2022). *Distributed fiber optic sensing for real-time monitoring of gas in riser during offshore drilling*. Retrieved July 22, 2025, from <https://www.ncbi.nlm.nih.gov/pmc/articles/PMC6983127/>

- SenseGrow. (2024). *Electric submersible pump (ESP): Improving reliability and fault prediction with motor current signature data and AI*. Retrieved July 22, 2025, from <https://www.sensegrow.com/blog/reliability-predictive-maintenance/electric-submersible-pump>
- Sensonic. (2025). *What is distributed acoustic sensing - How does it work?* Retrieved July 22, 2025, from <https://www.sensonic.com/en/blog/what-is-distributed-acoustic-sensing-how-does-it-work--3274/>
- Sharma, J., Santos, O., & Ogunsanwo, O. (2023). Fiber-optic DAS and DTS for monitoring riser gas migration. *Journal of Petroleum Science and Engineering*, **220**, 111187. <https://doi.org/10.1016/j.petrol.2022.111187>
- Silixa. (2023). *Principles of distributed temperature sensing*. Retrieved July 21, 2025, from <https://silixa.com/principles-of-distributed-temperature-sensing/>
- SLB. (2023). *Optiq fiber-optic solutions*. Retrieved July 21, 2025, from <https://www.slb.com/products-and-services/innovating-in-oil-and-gas/reservoir-characterization/surface-and-downhole-logging/optiq-schlumberger-fiber-optic-solutions>
- SPIE. (2025). *Distributed acoustic sensing (DAS) a real-world perspective: Requirements, applications*. Retrieved from <https://www.spiedigitallibrary.org/conference-proceedings-of-spie/13639/1363904/Distributed-acoustic-sensing-DAS-a-real-world-perspective-requirements-applications/10.1117/12.3062464.full>
- Wu, Z., Lin, Z., Liang, Y., Zhou, Z., & Lu, H. (2021). An effective prediction method for bridge long-gauge strain under moving trainloads with experimental verification. *Mechanical Systems and Signal Processing*, **186**, 109855. <https://doi.org/10.1016/j.ymssp.2022.109855>