

INSTRUMENTATION & RELIABILITY - ENGINEER REPORT

Target Equipment: Pump P102 Telemetry Analysis

Clearance Level: Engineer

Technical Metrics & Telemetry:

Vibration: 8.4 mm/s (Threshold: 7.5 mm/s - Warning Exceeded)

Temperature: 82 C (Normal range: 60-75 C)

Historical Trend: Increasing over last 30 days.

Recommendation: Immediate bearing inspection and alignment check required.