

MRPL - ENVIRONMENTAL COMPLIANCE AUDIT Q4

Facility: Effluent Treatment Plant (ETP)

Classification: STRICTLY CONFIDENTIAL

Findings:

- Average COD levels at Outlet Stream B recorded at 210 mg/L (permissible limit: 250 mg/L).
- Neutralization basin #3 recorded temporary acidic spikes (pH 5.2) due to an upstream dosing pump malfunction on January 18, 2026.

Mandatory Actions:

1. Chemical dosing pump at Neutralization Basin #3 must be replaced under Protocol E-4.
2. Hazardous bio-sludge in Lagoon #2 must be transferred to authorized facilities within 7 days.