

**XLPE Power Cable
Specification No. 322 or 1001**



**Substation Electrical
Equipment Engineering Department**

Ratings and Features	Designed : วิจัย ๑๗	Validated : ศ.ดร.	Revision 2	Page 1/1
RF No. PC2110	Verified : ๑๗/๕/๖๒	Approved : [Signature]	Dated : 17.04.60	

- | | | |
|---|---|-----------------|
| a. Type | Underground Power Cable | |
| b. Nominal System Voltage | 22 | kV |
| c. Nominal Cross-Sectional Area | 35 | mm ² |
| d. Conductor | | |
| - Material | Annealed Copper | |
| - Construction | Compacted Round Concentric Lay Stranded | |
| - Diameter | 7 | mm |
| - Min. Number of Wires | 6 | |
| - Max. Resistance at 20° C | 0.524 | Ω/km |
| e. Thickness of Conductor Shield | 0.6 | mm |
| f. Thickness of XLPE Insulation | 8.76 | mm |
| g. Thickness of Insulation Shield | 0.6 | mm |
| h. Metal Shield | | |
| - Material | ☒ Copper Tape
☐ Copper Wire | |
| - Thickness of Copper Tape | 0.1 | mm |
| - Min. Number of Copper Wire | - | |
| - Total Cross-Sectional Area of Copper Wire | - | mm ² |
| i. Cushion | | |
| - Material | Polyester Non-Woven Tape | |
| - Thickness | ≥ 0.03 | mm |
| j. Jacket | | |
| - Material | Black Polyvinyl Chloride (PVC) | |
| - Thickness | 2.03 | mm |
| k. Cable Outside Diameter (Approx.) | 34 | mm |