

Objektname	Gerätemodell	Adresse + Port	Geräteinstanznr.	Beschreibung
Desigo CC Workstation 1049621	Desigo CC	172.16.13.198	1049621	Desigo CC BACnet Workstation Device
00DB302	PXC3.E16A-2	172.16.13.14	3148814	Automationsstation
01DB301	PXC3.E16A-2	172.16.13.22	3148822	Automationsstation
00DA302	PXC3.E75A-2	172.16.13.13	3148813	Automationsstation
01DA301	PXC3.E75A-2	172.16.13.21	3148821	Automationsstation
02DB301	PXC3.E16A-2	172.16.13.32	3148832	Automationsstation
01DA303	PXC3.E75A-2	172.16.13.25	3148825	Automationsstation
01DA302	PXC3.E75A-2	172.16.13.23	3148823	Automationsstation
01DB302	PXC3.E16A-2	172.16.13.24	3148824	Automationsstation
00DB301	PXC3.E16A-2	172.16.13.12	3148812	Automationsstation
BNR03	PXG3.M-1	172.16.13.1	2100225	PXG Router 03 Geb. C
02DB302	PXC3.E16A-2	172.16.13.34	3148834	Automationsstation
AS_C100 02PC310	PXC4.E16-2	172.16.13.53	681013	M-Bus Zähler EG/1.OG
AS_C100 02PD310	PXC4.E16-2	172.16.13.54	681014	M-Bus Zähler 2.OG/3.OG
00DA304	PXC3.E75A-2	172.16.13.16	3148816	Automationsstation
CP_B001	PXM40.E	172.16.15.15	681007	Control Point CP_B001.B
CP_B200	PXM40.E	172.16.15.24	681005	Control Point B200
BNR04	PXG3.M-1	172.16.14.1	2101249	PXG Router 04 Geb D
BNR01	PXG3.M-1	172.16.11.1	2098177	PXG Router 01 Geb. A
AS_C100 02CENF310	PXC5.E003	172.16.13.55	681017	Automation station 05
BNR02	PXG3.M-1	172.16.12.1	2099201	PXG Router 02 Geb. B
BACnet-Edge-Router-50 00	Connect X300/X200	172.16.15.252	5000	BACnet Edge Router 1.5
BNR05	PXG3.M-1	172.16.15.1	2098178	PXG Router 05 Primäranlagen
00DB103	PXC3.E16A-2	172.16.11.15	3146767	Automationsstation
02DB103	PXC3.E16A-2	172.16.11.35	3146787	Automationsstation
02DA102	PXC3.E75A-2	172.16.11.33	3146785	Automationsstation
00DB101	PXC3.E75A-2	172.16.11.12	3146764	Automationsstation
02DB101	PXC3.E16A-2	172.16.11.32	3146784	Automationsstation
01DB103	PXC3.E16A-2	172.16.11.25	3146777	Automationsstation
03DB103	PXC3.E16A-2	172.16.11.45	3146797	Automationsstation
00DB202	PXC3.E16A-2	172.16.12.15	3147791	Automationsstation

Objektname	Gerätemodell	Adresse + Port	Geräteinstanznr.	Beschreibung
02DA202	PXC3.E75A-2	172.16.12.33	3147809	Automationsstation
00DA110	PXC3.E75A-2	172.16.11.51	3146803	Automationsstation
00DA203	PXC3.E75A-2	172.16.12.16	3147792	Automationsstation
01DA103	PXC3.E75A-2	172.16.11.24	3146776	Automationsstation
03DA201	PXC3.E75A-2	172.16.12.41	3147817	Automationsstation
02DA201	PXC3.E75A-2	172.16.12.31	3147807	Automationsstation
03DB201	PXC3.E16A-2	172.16.12.42	3147818	Automationsstation
01DB401	PXC3.E16A-2	172.16.14.22	3149846	Automationsstation
03DA103	PXC3.E75A-2	172.16.11.44	3146796	Automationsstation
03DA202	PXC3.E75A-2	172.16.12.43	3147819	Automationsstation
02DB401	PXC3.E16A-2	172.16.14.32	3149856	Automationsstation
00DA201	PXC3.E75A-2	172.16.12.11	3147787	Automationsstation
00DA402	PXC3.E75A-2	172.16.14.13	3149837	Automationsstation
AS_B100 02PD210	PXC4.E16-2	172.16.12.54	681012	M-Bus Zähler 2.OG/3.OG
00DA401	PXC3.E75A-2	172.16.14.11	3149835	Automationsstation
03DB101	PXC3.E16A-2	172.16.11.42	3146794	Automationsstation
02DB201	PXC3.E16A-2	172.16.12.32	3147808	Automationsstation
AS_D100 02PC410	PXC4.E16-2	172.16.14.53	681015	M-Bus Zähler EG/1.OG
00DB201	PXC3.E16A-2	172.16.12.12	3147788	Automationsstation
AS_D100 02PD410	PXC4.E16-2	172.16.14.54	681016	M-Bus Zähler 2.OG
AS_B100 02PC210	PXC4.E16-2	172.16.12.53	681011	M-Bus Zähler EG/1.OG
01DA401	PXC3.E75A-2	172.16.14.21	3149845	Automationsstation
Siemens LoBo	Siemens Smart Building Recorder	100:0xac100ffcbad2	4122122	
01DB402	PXC3.E16A-2	172.16.14.24	3149848	Automationsstation
AS_A200.1B	PXC7.E400M	172.16.15.12	681002	Automation station A200.1B
AS_B200	PXC7.E400M	172.16.15.21	681004	Automation station B200
AS_B001.A	PXC7.E400M	172.16.15.13	681006	Automation station B001.A
02DB402	PXC3.E16A-2	172.16.14.34	3149858	Automationsstation
02DA403	PXC3.E75A-2	172.16.14.35	3149859	Automationsstation
AS_A200.2	PXC7.E400M	172.16.15.16	681003	Automation station A200.2
01DB101	PXC3.E16A-2	172.16.11.22	3146774	Automationsstation
02DA210	PXC3.E75A-2	172.16.12.52	3147828	Automationsstation

Objektname	Gerätemodell	Adresse + Port	Geräteinstanznr.	Beschreibung
00DA303	PXC3.E75A-2	172.16.13.15	3148815	Automationsstation
01DA201	PXC3.E75A-2	172.16.12.21	3147797	Automationsstation
AS_A100 02PC110	PXC4.E16	172.16.11.53	681009	M-Bus Zähler EG/1.OG
MS01	INSIGHT	172.16.14.141	1048577	MS01
00DA103	PXC3.E75A-2	172.16.11.14	3146766	Automationsstation
00DA301	PXC3.E75A-2	172.16.13.11	3148811	Automationsstation
AS_A100 02PD110	PXC4.E16	172.16.11.54	681010	M-Bus Zähler 2.OG
02DA103	PXC3.E75A-2	172.16.11.34	3146786	Automationsstation
01DA102	PXC3.E75A-2	172.16.11.23	3146775	Automationsstation
00DB401	PXC3.E16A-2	172.16.14.12	3149836	Automationsstation
01DA101	PXC3.E75A-2	172.16.11.21	3146673	Automationsstation
01DA402	PXC3.E75A-2	172.16.14.23	3149847	Automationsstation
02DA303	PXC3.E75A-2	172.16.13.35	3148835	Automationsstation
00DA101	PXC3.E75A-2	172.16.11.11	3146763	Automationsstation
AS_A200.1A	PXC7.E400M	172.16.15.11	681001	Automation station A200.1A
01DB201	PXC3.E16A-2	172.16.12.22	3147798	Automationsstation
00DA202	PXC3.E75A-2	172.16.12.14	3147790	Automationsstation
00DA102	PXC3.E75A-2	172.16.11.13	3146765	Automationsstation
AS_B001.B	PXC4.E16	172.16.15.27	681008	Automation station AS_B001.B
00DA310	PXC3.E75A-2	172.16.13.51	3148851	Automationsstation
02DA402	PXC3.E75A-2	172.16.14.33	3149857	Automation station
02DA301	PXC3.E75A-2	172.16.13.31	3148831	Automationsstation
00DA410	PXC3.E75A-2	172.16.14.51	3149875	Automationsstation
02DA401	PXC3.E75A-2	172.16.14.31	3149855	Automationsstation
02DA302	PXC3.E75A-2	172.16.13.33	3148833	Automationsstation
02DA110	PXC3.E75A-2	172.16.11.52	3146804	Automationsstation
03DA101	PXC3.E75A-2	172.16.11.41	3146793	Automationsstation
03DA102	PXC3.E75A-2	172.16.11.43	3146795	Automationsstation
02DA410	PXC3.E75A-2	172.16.14.52	3149876	Automationsstation
02DA310	PXC3.E75A-2	172.16.13.52	3148852	Automationsstation
01DA403	PXC3.E75A-2	172.16.14.25	3149849	Automationsstation
01DA202	PXC3.E75A-2	172.16.12.23	3147799	Automationsstation
00DA403	PXC3.E75A-2	172.16.14.15	3149839	Automationsstation

Objektname	Gerätemodell	Adresse + Port	Geräteinstanznr.	Beschreibung
02DA101	PXC3.E75A-2	172.16.11.31	3146783	Automationsstation
00DA210	PXC3.E75A-2	172.16.12.51	3147827	Automationsstation
00DA404	PXC3.E75A-2	172.16.14.14	3149838	Automationsstation