

Objektnam e	Gerätemodell	Hersteller	Firmwareversion	Adresse + Port	Geräteins tanznr.	SW Version Applikation	Beschreibung
Desigo CC Workstation 9998	Desigo CC	Siemens	8.0	172.16.0.10	9998	8.09	Desigo CC BACnet Workstation Device
Projekt_109 00001L So nderaustell ung	E-DDC3.3	SE-Elektronik	03.07.13	172.16.0.60	2001	UNVERSIONED @ Tue Jul 9 10:15:25 2024	RLT Anlage Sonderausstellung
LTAPX'AS0 09	PXC100-E.D / HW=V1.00	Siemens Building Technologies	FW=V6.00.320 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.70	2098179	1\DE\2\LT Mannheim\AS009	PH10.19 Seminar u Werkraum 10.OG
Projekt_109 00002L	E-DDC3.3	SE-Elektronik	03.03.26	172.16.0.61	2002	u00.00.01	RLT
LTAPX'AS0 02	PXC200-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.124 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.76	2098181	1\DE\2\LT Mannheim\AS002	KB01.14 L01/20/30/40/50/51 Hzg
LTAPX'AS0 06	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.124 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.67	2098183	1\DE\2\LT Mannheim\AS006	AH01.56 WT / Heizkreis
LTAPX'AS0 19	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.030 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.83	2098194	1\DE\2\LT Mannheim\AS019	AH01.35 Nord Dampfmaschine / Elektro
LTAPX'AS0 08	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.123 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.75	2098178	1\DE\2\LT Mannheim\AS008	AH11.07 L60
LTAPX'AS0 07	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.123 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.74	2098180	1\DE\2\LT Mannheim\AS007	AH00.02 L60 / H11
LTAPX'AS0 21	PXC50-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.205 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.80	2098187	1\DE\2\LT Mannheim\AS021	AH03.05 Elektro
LTAPX'AS0 13	PXC50-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.205 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.69	2098182	1\DE\2\LT Mannheim\AS013	PH10.20 Fortluftanlagen Wetterstation
LTAPX'AS0 11	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.328 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.72	2098177	1\DE\2\LT Mannheim\AS011	KB12.01 RLT Auditorium / Fenstersteuerung
LTAPX'AS0 24	PXC50-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.205 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.57	2098190	1\DE\2\LT Mannheim\AS024	AH06.32 Elektro
LTAPX'AS0 12	PXC50-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.124 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.77	2098188	1\DE\2\LT Mannheim\AS012	PH10.21 Fortluftanlagen

Objektnam e	Gerätemodell	Hersteller	Firmwareversion	Adresse + Port	Geräteins tanznr.	SW Version Applikation	Beschreibung
LTAPX'AS0 16	PXC50-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.124 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.78	2098192	1\DE\2\LT A Mannheim\AS016	KB02.01 Dachbewässerung / Telefon
LTAPX'AS0 17	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.205 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.84	2098196	1\DE\2\LT A Mannheim\AS017	PH01.55 Elektro
LTAPX'AS0 10	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.123 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.52	2098186	1\DE\2\LT A Mannheim\AS010	PH10.17 RLT Sond erausst/Innenl.Räu me
LTAPX'AS0 23	PXC50-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.205 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.79	2098189	1\DE\2\LT A Mannheim\AS023	AH05.19 Elektro
LTAPX'AS0 25	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.205 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.58	2098191	1\DE\2\LT A Mannheim\AS025	PH10.19 Elektro / Fenster
LTAPX'AS0 14	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.205 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.82	2098195	1\DE\2\LT A Mannheim\AS014	PH01.60 L91 / Digestorien / Tischabsaugung
PXM20ET MP021007 b9	PX MMI, PXM20-E	Siemens Building Technologies	FW=V5.10.064 / BACStack=V1.17 / SBC=10.02 / HW=V2.01	172.16.0.73	1050553		Desigo PXM20E
LTAPX'AS0 18	PXC100-E.D / HW=V3.00	Siemens Building Technologies	FW=V6.00.314 / SBC=11.01 / FLI=06.00 / BBI=13.06 / LWI=01.10 / PMC=01.30 / STF=01.20	172.16.0.81	2098193	1\DE\2\LT A Mannheim\AS018	AH01.35 Süd Elektro