

Facultad de Física
Departamento de Física Atómica, Molecular y Nuclear



VNIVERSITAT
DE VALÈNCIA

TRITIUM: Design, Construction and Commissioning of an In-Water Tritium Detector

Marcos Martínez Roig

PhD in Physics
15th March 2022

Under the supervision of:

José Díaz Medina
Nadia Yahlali Haddou

*Dedicated to
my family*

Sometimes it is the people no one imagines anything
of who do the things that no one can imagine.

"Alan Turing"

I

Acknowledgements

Muchas personas han colaborado a lo largo de estos cuatro años para hacer posible este trabajo. En primer lugar me gustaría agradecer enormemente a mis tutores, Jose Díaz Medina y Nadia Yahlali Haddou, por intentar transmitirme en todo momento tantos conocimientos como les ha sido posible. También agradecer su tiempo ya que, a pesar de sus obligaciones, siempre han encontrado un hueco en sus agendas para ayudarme rápidamente con cualquier problema. Estoy muy agradecido por su cercanía y sus consejos, tanto en el mundo laboral como en la vida personal, los cuales me han ayudado a llegar a donde estoy ahora. Gracias de todo corazón por todo, nada de esto hubiera sido posible sin vosotros.

En segundo lugar me gustaría agradecer a mis compañeros de laboratorio Andrea Esparcia Córcoles, Ana Bueno Fernández, Marcos Llanos Expósito y sobre todo a Mireia Simeo Vinaixa, con quienes los largos e interminables trabajos de laboratorio han sido mucho más fáciles, ayudandome en todo momento a comprender y mejorar los resultados experimentales obtenidos. También me gustaría agradecer a los técnicos e investigadores del LARAM, Clodoaldo Roldán García, Teresa Cámara García, Vanesa Delgado Belmar y Rosa María Rodríguez Galán, por su ayuda, su tiempo y sus esfuerzos en hacer que todo esto haya sido posible.

En tercer lugar me gustaría agradecer a todos los investigadores del proyecto TRITIUM, gente que me ha acogido con los brazos abiertos,

que me ha ayudado en todo lo que les ha sido posible y con la que he tenido el placer de trabajar y aprender a su lado. Me gustaría agradecer en especial a Carlos Azevedo, junto al cual tuve el placer de trabajar. Gracias por todo el tiempo que invertiste en mi y en mi formación en temas tan interesantes y dispares como programación con Arduino y Rasberry Pi (llegando a realizar proyectos en común) o simulaciones con el paquete de programación Geant4 (llegando a realizar mis propias simulaciones).

En cuarto lugar me gustaría agradecer a David Calvo Díaz-Aldagalán, ingeniero del IFIC, gracias al cual pudieron llevarse a cabo los diseños de las distintas PCBs utilizadas en el proyecto TRITIUM.

Finalmente me gustaría dar las gracias a los investigadores de otros proyectos los cuales, pese a no ayudarme directamente en mi labor de investigación, si han aportado a mi trabajo debido a las sinergias existentes entre los objetivos experimentales de los proyectos:

- A los investigadores del proyecto DUNE, Anselmo Cervera, Miguel Ángel García y Justo Martín-Albo, los cuales me han ayudado con su tiempo, sus conocimientos e su instrumentación experimental a completar la caracterización de los SiPMs.
- A los ingenieros del proyecto NEXT, Vicente Álvarez, Marc Querol, Javier Rodríguez Samaniego y Sara Cárcel, con quienes he compartido laboratorio y, aun sin trabajar directamente con ellos, siempre han estado dispuestos a echarme una mano.
- A los investigadores del IFIMED, Gabriela Llosá, Ana Ros, Marina Borja Lloret, John Barrio, Rita Viegas y Jorge Roser e investigadores del proyecto ATLAS (Urmila Soldevila y Carlos Mariña) por prestarnos sus instalaciones y, en concreto, sus sistemas de control de temperatura los cuales fueron necesario para la caracterización de los SiPMs.

-
- A los investigadores del laboratorio HYMNS, Ion Ladarescu y César Domingo, quienes me ayudaron en mis primeros pasos con la electrónica PETsys además de asesorarme con las questiones que me han surgido a lo largo del camino.
 - A los investigadores del ICMOL, Henk Bolink, Alejandra Soriano y Lidón Gil Escrig, por ayudarnos con el protocolo de limpieza de las fibras centelleadoras además de permitirnos usar sus instalaciones.
 - A toda la gente de los distintos departamentos del IFIC que hay ayudado con su tiempo y sus consejos. Me gustaría agradecer especialmente la ayuda de Jose Vicente Civera, Manolo Montserrat, Jose Luis Jordan y Daniel Tchogna del departamento de mecánica, Ximo Navajas, Ximo Nadal, Carlos Martinez y Francisco Javier Sanchez del departamento de informática y Manuel Lopez, Jorge Nacher y Jose Mazorra del departamento de electrónica.
 - A mis amigos del IFIC, Pepe, Kevin, Jose Antonio, Pablo, Stefan y Victor, los cuales, aun sin haber aportado directamente a mi trabajo, compartir mis días con ellos ha sido uno de los mayores apoyos de esta aventura. No solo me llevo amigos de esta etapa, me llevo una familia.
 - A mi amigo, Galo, una amistad que empezó en el master, donde tuve el placer de compartir muchas de las duras horas de estudio, y continuó en el doctorado, donde compartimos muchos buenos momentos y siento que nos ayudamos a crecer mutuamente tanto profesional como personalmente. Amistad que, sinceramente, espero que dure para toda la vida.
 - A mi familia, quienes sin comprender exactamente en que consiste mi trabajo, me han apoyado y animado ciegamente desde el principio. Fueron, son y serán una pieza imprescindible en todas las areas de mi vida.

Finalmente me gustaría agradecer al programa INTERREG-SUDOE por financiar el proyecto TRITIUM, gracias al cual todo esto se ha podido materializar.

Abstract

Tritium is one of the most abundantly emitted radioisotopes by nuclear facilities and, specifically, by nuclear power plants. Large amounts of tritium are normally produced in the water of their cooling system, which are finally emitted to the environment. Due to the fact that large releases of tritium could be dangerous for human health and for the environment, there exist several regulations around the world which try to control this radioactive emissions in each country, like the Directive Europeen 2013/51/Euratom, which establishes the tritium limit for drinking water in Europe to 100 Bq/L, or the Environmental Protection Agency, in United States, that limits tritium in drinking water to 20 nCi/L.

Due to the low energy of electrons emitted in the tritium decay, very sensitive detectors are needed for measuring them like LSC. The issue with LSC is that it is an off-line method and the measurement process can take 2 days or more, a time too long to detect a problem in the NPP.

Detectors based on solid scintillators are a promising idea for building a tritium detector that works in quasi-real time. This type of detectors is developed so far successfully but without achieving the required sensitivity of the legal limits.

The results of the TRITIUM project are presented in this thesis. In the framework of this project a quasi-real time monitor for low tritium

activities in water have been developed. This monitor is based on a tritium detector that contains several detection cells which are read in parallel, several active vetos and a passive shielding for reducing the natural background of the natural radioactivity and a water purification system to prepare the sample before being measured. Each detection cell is made up of hundreds of scintillating fibers read out by PMTs or SiPM arrays.

The final objective of this monitor will be the radiological protection around the nuclear power plant. This monitor will provide an alarm in case of an unexpected tritium release that exceeds the legal limits established in Europe. The final idea will be to include this monitor in the early alarm system of Extremadura consisting of several detectors the objective of which is to control the impact of Nuclear Power Plants to the environment.

Keywords: Very low-energy charged particle detectors, radiation monitoring, tritium detection, scintillators, scintillating fibers and light guides, detector design and construction technologies and materials, instruments for environmental monitoring, detector modelling and simulations.

Acronyms and Symbols

Acronyms:

<i>ALARA</i>	— As low as reasonably achievable criterium
<i>APD</i>	— Avalanche photodiode
<i>BIXS</i>	— Beta induced X-ray spectrometry
<i>BWR</i>	— Boiling water reactor
<i>CCD</i>	— Charge-coupled device
<i>CNRS</i>	— Centre National de la Recherche Scientifique
<i>CSN</i>	— Consejo de Seguridad Nuclear
<i>DAQ</i>	— Data acquisition system
<i>DRIM</i>	— Deteção da Radiação e Laboratorio Imagem Médica
<i>EEC</i>	— European Economical Community
<i>EPA</i>	— Environmental Protection Agency
<i>EU</i>	— European Union
<i>EURATOM</i>	— European Atomic Energy Community
<i>G – APD</i>	— Geiger avalanche photodiode
<i>GCR</i>	— Gas cooled reactor
<i>HPGe</i>	— High purity germanium detector
<i>HWR</i>	— Heavy water reactor
<i>IAEA</i>	— International Atomic Energy Agency
<i>IC</i>	— Ionization chamber
<i>ICRP</i>	— International Commission on Radiological Protection

<i>ICRU</i>	— International Commission of Radioactivity Units and Measurements
<i>ISR</i>	— International Society of Radiology
<i>LARUEX</i>	— Laboratorio de Radiactividad Ambiental of the University of Extremadura (Environmental Radioactivity Laboratory of the University of Extremadura)
<i>LED</i>	— Light-emitting diode
<i>LSC</i>	— Liquid scintillation counting
<i>LWR</i>	— Light water reactor
<i>MAPD</i>	— Micro-pixel avalanche photodiode
<i>MDA</i>	— Minimum detectable activity
<i>MPPC</i>	— Multi-pixel photon counter
<i>MRS – ADP</i>	— Metal-resistor-semiconductor avalanche photodiode
<i>NPP</i>	— Nuclear power plant
<i>PCB</i>	— Printed circuit board
<i>PHWR</i>	— Pressurized heavy water reactor
<i>PMMA</i>	— Polymethyl methacrylate
<i>PMT</i>	— Photomultiplier tube
<i>POF</i>	— Plastic optical fiber
<i>PVC</i>	— Polyvinyl chloride
<i>PWR</i>	— Pressurized water reactor
<i>RDL</i>	— Reference dose level
<i>REA</i>	— Red de Estaciones Automáticas
<i>REM</i>	— Red de Estaciones de Muestreo
<i>ROI</i>	— Region of interest
<i>SDD</i>	— Silicon drift detector
<i>SiPM</i>	— Silicon photomultiplier
<i>SSPM</i>	— Solid state photomultiplier
<i>STP</i>	— Standard temperature and pressure conditions
<i>UDL</i>	— Upper detection limit
<i>UNSCEAR</i>	— United Nations Scientific Committee on the Effects of Atomic Radiation

<i>DOE</i>	— United States Department of Energy
<i>EIA</i>	— United States Energy Information Administration
<i>EPA</i>	— United States Environmental Protection Agency
<i>WHO</i>	— World Health Organization

Symbols

A_m	— Activity measured
CE	— Collection efficiency
C_t	— Terminal capacitance of SiPM
DCF	— Dose conversion factor
δ	— Multiplication factor of a PMT dynode
ΔTV_{op}	— Temperature coefficient ($mV/^\circ C$)
E_b	— Binding energy of the electron in a specific material
ε_{det}	— Specific detector efficiency
E_e	— Electron energy
$E_\gamma = h\nu$	— Photon Energy
FF	— SiPM fill factor
F_{sci}	— Plastic scintillator active surface
GL	— Guideline level
G_{PMT}	— PMT Gain
G_{SiPM}	— SiPM Gain
η_{det}	— Intrinsic detector efficiency
HV	— High voltage
I_{DC}	— PMT dark current
I_{PMT}	— PMT Intensity
λ	— Wavelength
λ_p	— Most probable wavelength of a spectrum
mip	— Minimum ionizing particle
m_0	— Electron rest mass
NaI(Tl)	— Thallium doped Sodium Iodide

NA	— Numerical aperture
OBT	— Organically bound tritium molecule
P_{av}	— SiPM avalanche probability
PDE	— Photodetection efficiency of the SiPM
q	— Annual volume of drinking water consumed per capita
QE	— Quantum efficiency
q_e	— Electron charge
Q_β	— Energy released in decay
R_q	— SiPM Quenching resistance
S	— Specific energy loss
S_{ij}	— Single states of energy levels of electrons in a scintillator
S/cm	— Siemens per centimeter
σ	— Cross section of a radioactive process
σ^{rel}	— Relative uncertainty
σ_{sys}	— Systematic uncertainty
σ_{st}	— Statistical uncertainty
σ_t	— Total uncertainty
σ_{TM}	— Uncertainty of a tritium measurement due to the scintillating fibers
$T_{1/2}$	— Half-life time of a radioactive element
T_{ij}	— Triple states of energy levels of electrons in a scintillator
V_{BD}	— SiPM breakdown voltage
V_{bias}	— SiPM supply voltage
V_{OV}	— SiPM over voltage a SiPM

Contents

Acknowledgements	III
Abstract	VII
Nomenclature and Acronyms	IX
List of Figures	XXX
List of Tables	XXXIV
1 Introduction	1
1.1 Tritium and Nuclear Energy	1
1.2 Tritium Properties and Radiological Hazards	8
1.3 Current Legislation	17
1.4 This Thesis	19

CONTENTS

2 Methods of Detection of Tritium In Water	21
2.1 Tritium Detection State-of-the-Art	21
2.2 The TRITIUM Project	25
3 Design Principles and Components of TRITIUM	29
3.1 Detector System Overview	29
3.2 TRITIUM Detector	31
3.2.1 Interaction of Particles with Matter	31
3.2.2 Plastic Scintillators	35
3.2.3 Light Detection in Photosensors	42
3.2.4 Electronic Readout	59
3.3 Water Purification System	68
3.3.1 Objectives	68
3.3.2 Design of the Water Purification System	69
3.4 Background Rejection System	71
3.4.1 Passive Shield (Lead)	73
3.4.2 Active Shield (Cosmic Veto)	74
4 TRITIUM Monitor R&D	81
4.1 R&D for the Scintillating Fibers	81

4.1.1	Surface-Conditioning Method of Scintillating Fiber.	82
4.1.2	Light Collection Characterization of BCF-12 Scintillating Fibers	99
4.2	Characterization of the SiPM	111
4.3	Characterization of the Water Purification System	121
4.4	Characterization of the Cosmic Veto	124
5	TRITIUM Detector Prototypes	133
5.1	First Prototypes	134
5.1.1	TRITIUM-IFIC-0	134
5.1.2	TRITIUM-IFIC-1	140
5.2	Latest TRITIUM Prototypes	145
5.2.1	TRITIUM-Aveiro	146
5.2.2	TRITIUM-IFIC-2	152
5.3	Experimental Results in Arrocampo Dam	163
5.4	Modular TRITIUM Detector for In-Situ Tritium Monitoring	165
6	Simulations	169
6.1	Geant4 Environment	169
6.2	Simulations for the design of the TRITIUM Detector	171
6.2.1	The Tritiated Water Source	171

CONTENTS

6.2.2	Energy Deposition and Light Output of Scintillating Fibers	173
6.2.3	Optimization of the Fiber Length	177
6.2.4	Fiber Diameter	180
6.2.5	Effect of the PMMA windows	181
6.3	Simulations of the TRITIUM Monitor	182
6.3.1	Simulation of the TRITIUM-IFIC-2 Prototype	183
6.3.2	Lead Shield and Cosmic Veto	187
7	Present Status and Summary of the Results of the TRI-TIUM Project	195
8	Conclusions and Prospects	205
Appendices		
A	Electronics for the SiPM Characterization	211
B	Water Purification System	215
C	Preparation of Tritiated Water Sources	221
D	Electronic System of TRITIUM-Aveiro prototype	223

List of Figures

1.1	Annual average distribution of the radioactive dose received by the population [Thea].	2
1.2	Networks of automatic and sampling stations managed by the spanish CSN. a) Measurement locations of the REA [Cona]. The white box is the daily average of the gamma dose and the green box is the monthly average of the gamma dose. b) Measurement locations of the REM [Conb]. Blue dots are locations near nuclear facilities, and green dots are locations uniformly distributed throughout the country.	5
1.3	(Above) Tritium energy levels [Inta]. (Below) Graphic representation of tritium decay [Wor20b].	9
1.4	Energy spectrum of tritium electrons [Lin20].	10
1.5	Tritium sampling locations around Cofrentes NPP.	13

LIST OF FIGURES

1.6 Tritium activity levels in surface water around Cofrentes NPP from January 2006 to November 2019. a) 6 km upstream. b) 1 km downstream. c) 5 km downstream. The white points are the detection limits and the green points are the measured activity when this is above the detection limit [Conb]. The maximum level of tritium measured since January 2, 2006 is around 32 Bq/L.	14
1.7 Tritium activity levels in groundwater around Cofrentes NPP from January 2006 to November 2019 [Conb]. a) 1 km upstream from the NPP. b) 1 km downstream from the NPP.	15
2.1 a) Arrocampo dam and Almaraz Nuclear Power Plant. b) Tagus river along Spain and Portugal.	26
3.1 Scheme of the scintillator detector.	31
3.2 Domain regions of the three most probable types of interactions of gamma rays with matter. The lines show the values of Z and $h\nu$ where two interaction processes are equally likely [Kno99].	33
3.3 Jablonsky diagram [Kno99].	37
3.4 Stokes shift [Kno99].	38
3.5 Emission spectrum of BCF-12 scintillating fibers of Saint-Gobain [SGC21a].	40
3.6 Photon collection in a single clad fiber [SGC21a].	41
3.7 Scheme of a PMT [Kno99].	45

3.8	Quantum efficiency spectrum for the PMT used in TRITIUM R&D studies (R8520-406) [K.K19].	46
3.9	Hamamatsu commercial voltage divider electronic circuit with negative (up) and positive (below) supply high voltage [K.K19].	47
3.10	Electronic scheme of the voltage divider circuit used for working with PMTs without internal gain).	48
3.11	Scheme of a APD and electrical symbol used [OSI].	50
3.12	SiPM output pulses displayed on oscilloscope, model MSO44X from Tektronix [Tek21]. Several height pulses are observed, associated to a different number of SiPM pixels fired at the same time. The persistence function of the oscilloscope is used.	51
3.13	(a) Electronic scheme of a SiPM and (b) output current of a SiPM as a function of the reverse voltage. As shown, the quenching is an essential working mechanism of SiPMs [Sen17].	53
3.14	Photon detection efficiency (PDE) spectrum for SiPM S13360-**75 models [HAM16].	57
3.15	Schemes of the different electronic for measuring with PMTs. a) Employed when only one PMT is used. b) Employed when two PMTs are used in time coincidence. c) Employed when four PMTs are used in time coincidence.	61
3.16	Different possibilities when time coincidences with PMTs are done. a) Event detected in only one PMT, one detector. b) Event detected in two PMTs, one detector. c) Event detected in two PMTs, other detector. d) Event detected in all PMTs, both detector.	64
3.17	Signal amplified and logical gate (input signals of MCA). . .	65

LIST OF FIGURES

3.18	Different parts of PETsys system [PET].	66
3.19	a) Electronic board used to provide the SiPM bias voltage and to read the SiPM output signal. b) Electronical scheme in which this PCB is based.	68
3.20	Scheme of water purification system of TRITIUM.	70
3.21	a) Lead Bricks b) and c) Two layers for the lead bricks of the shield.	74
3.22	a) Scheme of the aluminium structure of the shield; b) The lead shield partially mounted.	75
3.23	Cosmic veto and Tritium-IFIC-2 prototype in an aluminum mechanical structure developed at IFIC.	75
3.24	Hard cosmic events detected with the cosmic veto of TRITIUM: a) Real coincidence event, b) randomly coincidence envent that may mimic a hard cosmic event.	76
3.25	Hard cosmic muon rate at different depths with respect to the sea level (10^0) [Szu15].	77
3.26	Emission energy spectrum of the plastic scintillator from Epic-Crystals used for the cosmic vetos [Epi20].	78
3.27	Different layers used to wrap the cosmic veto detectors. a) Scintillator without coating. b) PTFE coating. c) Aluminium coating. c) d) Black tape coating.	79
4.1	Unsuccessful results of using commercial techniques for cleaving the scintillating fibers a) Fiber end deformation b) Fiber end cracks. Pictures taken with the microscope PB 4161 from EUROMEX.	83

LIST OF FIGURES

4.2	Plastic fiber cleaver developed in TRITIUM experiment.	84
4.3	Fiber end after cleaving process using the home-made cleaver. Pictures taken with the microscope PB 4161 from EUROMEX.	85
4.4	Manual polishing method implemented by Thorlabs.	86
4.5	Result of the polishing process. a) Fiber end after cleaving b) Fiber end after cleaving and manual polishing with Thorlabs technique. Pictures taken with the microscope PB 4161 from EUROMEX.	87
4.6	Polishing machine developed for TRITIUM.	88
4.7	Components of the fiber polishing machine. a) Polishing table. b) Fiber with ballast metal piece. c) Horizontal screws and PMMA plate. d) A movement switch with its cables in- serted inside its holding piece.	89
4.8	Electronic system of Polishing machine.	91
4.9	Setup used to test the effect of the fiber polishing on light transmission to the PMTs. This setup is placed in a dark test box for the measurements.	92
4.10	Energy spectra recorded with polished and unpolished fibers for the background of the natural radioactivity.	93
4.11	Energy spectra recorded with polished and unpolished fibers. a) for the ^{60}Co source b) for the ^{90}Sr source	95

LIST OF FIGURES

4.12 Schematic representation of the wetting properties of a flat surface (gray) in contact with a drop of liquid (blue). The wetting property is characterized by the angle formed between the surface of both objects. The smaller angle, the better wetting property of the material. [San]	96
4.13 Energy spectra of the background before and after the cleaning process.	97
4.14 Energy spectra obtained before and after the cleaning process using a radioactive source of a) ^{137}Cs and b) ^{90}Sr	98
4.15 Setup used for fiber characterization.	100
4.16 Emission spectrum measured in the laboratory for the LED model 435-03 from Roithner LaserTechnik GmbH Company.	101
4.17 PMT photocurrent as a function of the first dynode voltage. Error bars are included but they are too small to be visible.	102
4.18 Number of photons measured by the PMT as a function of the polarization current of the LED. a) Response of the PMT in the intensity range of tritium events. b) Response of the PMT in the range 0 – 2500 photons/ns. Error bars are included but they are too small to be visible.	104
4.19 Number of photons/ns reaching the PMT for Uncladded fibers. Error bars are included but they are too small to be visible.	106
4.20 Number of photons/ns reaching the PMT for ten samples. a) Single clad fibers, b) Multi-clad fibers. Error bars are included but they are too small to be visible.	107

4.21 Average number of photons per ns versus LED current for 10 samples of each fiber type (uncladded, single clad and multi-clad fibers). Error bars are included but they are too small to be visible.	109
4.22 I-V curves measured for the SiPM model Hamamatsu S13360-1375 with the bias voltage applied in a) forward direction b) reverse direction. The measurements were taken at $T = 25^\circ\text{C}$ and humidity $H = 45\%$	113
4.23 Above) Trigger signal (green) and SiPM output pulses (yellow). Below) SPS spectrum obtained by integrating and histogramming the SiPM output pulses. This measurement was done at 25°C , $V_{bias} = 53.98$ and humidity of $H = 60\%$	115
4.24 ROOT analysis performed to obtain the SiPM gain. a) Fit of the SPS spectrum to various Gaussian functions. b) Charge of successive number of pixels as a function of the number of pixels fired. Error bars are within point size. This experience was carried out at $T = 25^\circ\text{C}$, $V_{bias} = 53.98$ V and humidity of $H = 45\%$	116
4.25 Dependence of the SiPM gain with the a) Temperature b) Bias voltage.	118
4.26 SiPM gain measured as a function of the temperature after implementation of the gain stabilization method.	120
4.27 Reference points used for veto mapping.	125
4.28 Measurement of a radioactive source ^{137}Cs with the TRI-TIUM cosmic detector with and without wrapping.	126

LIST OF FIGURES

4.29 Bidimensional graph of the count rate (Mapping) measured with two different TRITIUM cosmic detectors using a radioactive source of ^{60}Co	127
4.30 Counting rate a) as a function of high voltage for fixed thresholds and b) as function of thresholds for fixed high voltage. in semilogaritmic scale	129
4.31 Energy spectrum measured with the cosmic veto.	130
4.32 Measurement of the cosmic veto for several distances between the two scintillators. Above) Energy spectrum of the cosmic veto for several distance. Below) Fit of the cosmic veto rate versus distance to a second degree polynomial.	131
5.1 a) Metallic piece of the fiber bundle. b) and c) Bundle of 35 fibers, the length of which is 20 cm, used in TRITIUM-IFIC-0 prototype.	135
5.2 TRITIUM-IFIC-0 Prototype.	136
5.3 a) Fiber bundle in PMMA vessel b) illumination test of the bundle to visualize the light loss due to the fiber curvature.	137
5.4 Energy spectra measured with TRITIUM-IFIC-0 prototype. a) Signal and background energy spectra. b) Tritium energy spectrum.	139
5.5 PTFE structure used to arrange the fibers of TRITIUM-IFIC-1 prototype in a matrix of 8×8	141
5.6 PTFE vessel of TRITIUM-IFIC-1 prototype.	142
5.7 A general view of TRITIUM-IFIC-1 prototype.	143

5.8 Energy spectra measured with TRITIUM-IFIC-1 prototype. a) Signal and background energy spectra. b) Tritium energy spectrum.	144
5.9 TRITIUM-Aveiro prototype.	147
5.10 PTFE structure and fiber bundle used in TRITIUM-Aveiro prototype.	147
5.11 Measurement of the background with TRITIUM-Aveiro pro- totype shielded with different layers of lead, A) without shield- ing, B) with a lead shield of 2.5 mm thickness and C) with two lead shields of 2.5 mm thickness each one [Aze22]. . . .	150
5.12 Measurements of the background and tritium liquid source (with an activity of 29.8 kBq/L) performed with the TRITIUM- Aveiro prototype and integrated during a minute [Aze22]. a) Counts per minut measured as a function of time. b) Distri- bution of the acquired data.	151
5.13 Measurements of the background and tritium liquid source (with an activity of 29.8 kBq/L) performed with the TRITIUM- Aveiro prototype and integrated during one hour [Aze22]. . .	153
5.14 TRITIUM-IFIC-2 prototype (A) and active veto (E) within the metallic structure (D).	154
5.15 a) TRITIUM-IFIC-2 PTFE vessel. b) TRITIUM-IFIC-2 PTFE vessel with PVC caps in which a groove is made for the cable connection to the SiPM.	155
5.16 Light transmission spectrum of a 5 mm thick PMMA plate, measured at ICMOL laboratory.	156
5.17 Graphical User Interface (GUI) of PETsys.	157

LIST OF FIGURES

5.18 Energy spectra measured with TRITIUM-IFIC-2 prototype. a) Signal and background energy spectra. b) Tritium energy spectrum.	158
5.19 a) Single photon distribution measured with TRITIUM-IFIC- 2 prototype. b) Tritium energy spectrum measured with TRITIUM-IFIC-2 prototype in photons detected per event. .	160
5.20 Signal and background rates for a long time measurement. .	161
5.21 Minimum detectable activity, MDA, as a function of the num- ber of TRITIUM-IFIC-2 prototypes read out in parallel for an integration time of 10 min (blue line) and 1 h (black line). The dotted red line indicates the goal of the TRITIUM pro- ject, 100 Bq/L.	162
5.22 Background measured with the TRITIUM-Aveiro prototype during its installation in Arrocampo dam [Aze22].	163
5.23 A schematic design of the TRITIUM detector.	166
5.24 A TRITIUM monitor design based on the TRITIUM-IFIC-2 prototype.	167
6.1 Energy distribution of a) simulated tritium decays b) Initial energy of tritium decays that reach the scintillating fibers (red histogram) compared to all simulated tritium events (blue histogram) [Aze20].	172
6.2 a) Transversal cut of simulated scintillating fiber (yellow) and tritium source (green) with various tritium decays (red dots) b) Distribution of the radial distance between the position where the tritium decay takes place and the surface of the scintillating fiber [Aze20].	174

- 6.3 Distribution of the initial energy of tritium events that reach the scintillating fibers (blue histogram) and the energy deposited in these fibers (red histogram) [Aze20]. 175
- 6.4 Energy distribution of photons produced in the scintillating fiber, without the Birks coefficient (red histogram) and with the Birks coefficient of $k_B = 0.126 \text{ mm/MeV}$ (blue histogram)[Aze20]. 176
- 6.5 Number of photons produced versus the energy deposited in the scintillating fibers when a)the Birks coefficient is not considered ($k_B = 0$) b) the Birks coefficient is $k_B = 0.126 \text{ mm/MeV}$ [Aze20]. 177
- 6.6 Number of photons produced in the fiber per tritium event for all tritium events that reach the fiber (blue histogram) and for only tritium events producing photons detected in coincidence by photosensors (red histogram) [Aze20]. 178
- 6.7 Simulations of counts integrated over 60 min, normalized to the same active area and taken over a week for a fiber length of 1 m (dashed lines) and 20 cm (solid lines) and two different activities, 0.5 kBq/L (blue lines) and 2.5 kBq/L (red lines) [Aze20]. 179
- 6.8 Comparison of the energy deposition by cosmic rays in scintillating fibers of 1 mm and 2 mm diameter. 181
- 6.9 Distribution of photons reaching the PMMA windows. The red histogram corresponds to the photons guided by fibers and the blue histogram to photons traveling in the water [Aze20]. 182

LIST OF FIGURES

6.10 Distribution of the scintillating fibers in the simulations of the Tritium-IFIC-2 prototype.	183
6.11 Simulation of Tritium-IFIC-2 prototype. PMTs (black), the optical grease (blue), PMMA windows (white), tritiated water (green) and scintillating fibers (yellow).	184
6.12 Tritium electron detected in the simulated TRITIUM-IFIC-2 prototype. The path of the optical photons is represented by green lines and the position in which they are absorbed is represented by red and blue dots (absorbed in water or PMT, respectively).	185
6.13 Photons detected by both PMTs per tritium event in the simulated TRITIUM-IFIC-2 prototype.	186
6.14 a) Simulated of tritium counts measured with a TRITIUM-IFIC-2 prototype, using an integration time of 10 min, during three months of measurements (13248 measurements for each activity). b) Distribution of these counts for each activities.	188
6.15 Simulation of the distribution of the tritium counts obtained with a TRITIUM-IFIC-2 prototype for different tritium activities during three months of measurements and three different integration times: a)10 min (13248 measurements), b) 30 min (4416 measurements) and c) 60 min (2208 measurements).	189
6.16 Simulaton of the distribution of the tritium counts during three months using an integration time of 10 min (13248 measurements) for different tritium activities and different number of TRITIUM-IFIC-2 modules: a) 1, b) 5 and c) 10. . .	190

6.17 Resolution of the TRITIUM-IFIC-2 prototype as a function of the. a) Integration counting time using 1 TRITIUM-IFIC 2 module. b) Number of modules, using an integration counting time of 10 min.	191
6.18 Total cosmic ray events detected by the TRITIUM-IFIC-2 prototype (from 10^5 generated cosmic events), which are misidentified as tritium events by the TRITIUM-IFIC-2 prototype in three different shielding configurations. The first configuration (bin 1) corresponds to a TRITIUM-IFIC-2 prototype without the background rejection system. The second configuration (bin 2) corresponds to adding the passive shield and the third configuration (bin 3) corresponds to the full shield of passive and active cosmic veto.	194
A.1 The three PCBs used for SiPM characterization a) The PCB 1 used to connect up to 8 SiPMs inside the black box. b) The PCB 2 used to sum and amplify the output signals of the SiPMs. c) The PCB 3 used to rearrange the input and output signals of the system. d) The LED emission spectrum.	213
B.1 Scheme of the water purification system.	216
B.2 Different stages of filtration of the water purification system. a) The gross filtering stage. b) The fine filtering stage. c) The super-fine filtering stage.	216
B.3 a) Doble phase reverse osmosis stage. b) Containers used to gather the output water of the water purification system. . .	217
B.4 Siemens PLC displays for the remote control of the water purification system.	218

LIST OF FIGURES

B.5	Picture of the water purification system.	219
B.6	Raw, reject and pure water obtained with the water purification system.	219
D.1	a) The electronic scheme of the PCB designed to power the PMTs of Aveiro prototype b) The graphical user interface developed to control the prototype.	224
D.2	Electronic scheme that process and analyze the signal of the TRITIUM-Aveiro prototype.	225
D.3	Graphical user interface used to manage the counter system.	226
D.4	a) Tritium event accepted as veto has not detected it. b) Background event rejected because veto has fired.	227

List of Tables

LIST OF TABLES

2.2	Results of scintillator detectors developed for experiments for tritiated water detection. This table shows for the quoted studies the efficiency of the detector (ε_{det}), its active surface (F_{sci}), its specific efficiency, defined as efficiency normalized to active surface ($\eta_{det} = \varepsilon_{det}/F_{sci}$), and MDA.	24
3.1	Critical angles associated to different interfaces between polystyrene, $n_0 = 1.6$, and other materials.	42
3.2	Properties of BCF-12 fibers from Saint-Gobain Inc. [SGC21a].	43
3.3	Characteristics of SiPM S13360-1375 and S13360-6075 from Hamamatsu Photonics [HAM16].	56
3.4	Classification of natural radioactive series [The96, Eva95]. The information displayed for each radioactive series is the multiplicity of the mass number, the name of the series, the primary and final element, and the half-life of the primary element.	73
3.5	Properties of plastic scintillators from Epic-Crystals used for the cosmic vetos [Epi20].	78
4.1	Mean and standard deviation (due to the fiber position in the setup) of the number of photons per nanosecond that reach the PMT for 0.1 mA LED intensity.	105
4.2	Number of collected photons per nanosecond versus LED intensity for the different type of fibers. The errors shown here are the standard deviation of the ten measured samples. . .	108
4.3	Relative standard deviation, $\sigma_{sys}^{rel}(\%)$, versus LED intensity for the different fiber types.	108

4.4	Relative standard deviations (σ_{sys}^{rel} , $\sigma_{sys-pos}^{rel}$ and σ_{sys-SF}^{rel}) measured in this test.	109
4.5	Number of the collected photons versus LED intensity for 10 different fibers of 10 cm length.	110
4.6	Collection efficiencies CE_{10}	111
4.7	Chemical components measured in the raw water sample. . .	122
4.8	Measurements of the conductivity for several samples of water.	123
4.9	Measurements of the tritium activity for several samples of both raw and purified water.	124
5.1	Contes per segon obtinguts per al prototip TRITIUM-IFIC-0.	138
5.2	Counting rate obtained with the TRITIUM-IFIC-1 prototype.	142
5.3	Counting rates measured by TRITIUM-IFIC-2 prototype. . .	157
5.4	Mean value and standard deviation of the counts of fourteen background measurements. Minimum net counts obtained by applying the Currie's Law, L_C and N_D	161
6.1	Difference in activity that can be resolved for the TRITIUM-IFIC-2 prototype, for different integration times and different number of modules.	187

LIST OF TABLES

Chapter 1

Introduction

1.1 Tritium and Nuclear Energy

Radioactivity is the process by which an unstable atomic nucleus decays through the emission of particles. This process is present in the Universe since the Big Bang. The formation of the Earth from the remains of supernova explosions explains why the different layers that make up the Earth contain radioactive elements.

Humanity has always been exposed to ionizing radiation, both from the Earth's crust radioactivity and cosmic rays (external natural irradiation). The human body also contains radioactive elements such as ^{3}H , ^{14}C and ^{40}K , introduced into it through food, water ingestion and air inhalation (internal natural irradiation).

As it can be seen in Figure 1.1, most of the radioactive dose received by the population is due to both internal and external natural radioactivity, the effective dose¹ of which is estimated to be 2.42 mSv/yr as

¹The effective dose is the radioactive dose absorbed by the population, weighted by

1.1. TRITIUM AND NUCLEAR ENERGY

shown in Table 1.1.




Figure 1.1 – Annual average distribution of the radioactive dose received by the population [Thea].

Radiation source	Eff. dose (mSv/yr)	Typical range (mSv/yr)
Cosmic (external)	0.39	0.3 – 1.0
Terrestrial (external)	0.48	0.3 – 0.6
Inhalation (internal)	1.26	0.2 – 10
Ingestion(internal)	0.29	0.2 – 0.8
Total	2.42	1 – 12.4

Table 1.1: Annual average distribution of the effective dose received by the population due to natural radioactivity [Theb, Conc].

Since the discovery of radioactivity by Henri Becquerel in 1896, lots of nuclear-based technologies were developed and applied to various fields such as Energy, Chemistry, Biology, Technology, Medicine, Industry, etc. Due to nuclear applications, a number of anthropogenic radioactive sources have emerged in society, resulting in radioactive elements released into the environment. It can be noticed in Figure 1.1 that the most important part

the radiosensitivity of each organ or tissue.


of the dose received by the population from artificial sources comes from medical practice. The growth of knowledge and the development of measurement techniques of radioactivity have provided evidence of the harmful effects of radioactivity in living organisms. This lead to the necessity of controlling the radiation exposed to the population keeping it under safe limits. To accomplish that purpose, several organizations were created to propose recommendations for radiological protection to the different state organisms and governments at the international level. The main ones are:

1. The International Commission of Radiological Units and Measurements (ICRU) [Intc] was created during the first International Conference of Radiology, held in London in 1925, to define concepts and units, necessary to quantify the negative effects of radioactivity.
2. The International Commission on Radiological Protection (ICRP) [Intb] was created in 1928 by the International Society of Radiology (ISR) [Intd]. The ICRP aims to make recommendations and to provide guidance on different aspects of protection against radioactivity. The ICRP does not have the legal capacity to enforce its recommendations, but these are widely included in the legislation of most countries.
3. The United Nations Scientific Committee on the Effects of Atomic Radiation (UNSCEAR) [Theb] was created in 1955 with the goal of estimating and reporting the levels and effects of ionizing radiation on the population and the environment. These estimates are taken into account by governments worldwide to establish their safety standards.
4. The International Atomic Energy Agency (IAEA) [Thea] was created in 1957 to promote the peaceful use of nuclear energy and to avoid its use for military purposes such as nuclear weapons. Although established independently from the United Nations through its own international treaty, the IAEA reports regularly to both the United Nations and the Security Council.

1.1. TRITIUM AND NUCLEAR ENERGY

5. The European Atomic Energy Community (EURATOM), created in 1957, is an international organization ruled by the EURATOM treaty. Its objective is to coordinate research programs for the peaceful use of nuclear energy and the sharing of knowledge, infrastructure and funding of nuclear energy.
6. The Nuclear Safety Council (CSN) [Conc] of Spain, created in 1980, is the authority in Spain for nuclear safety and radiation protection and has the objective of protecting employees, the general population and the environment from the harmful effects of ionizing radiation from anthropogenic origin. For this goal, the CSN ensures that nuclear and radioactive facilities are operated safely and establishes the preventive and corrective measures to be applied in radiological emergencies. The CSN manages two detectors networks to control the levels of radioactivity in the environment and to assess the impact of radioactive facilities:
 - (a) The network of automatic stations REA (Red de Estaciones Automáticas) [Cona]. The REA consists of several gamma detectors, distributed as indicated in Figure 1.2a, that measure the radioactive dose in real time. The REA is employed for real-time detection of radiological issues to enable taking prompt safety measures.
 - (b) The network of sampling stations REM (Red de Estaciones de Muestreo) [Conb]. The REM consists of a collection of points, shown in Figure 1.2b, from which samples are taken and measured in a laboratory. About twenty laboratories integrate this network. The objective of the REM is to characterize the concentration and evolution of radioisotopes present in the radioactive background of Spain and to quantify the impact of radioactive facilities on the environment.

The goal of the TRITIUM project is to develop a monitor capable



1.1. TRITIUM AND NUCLEAR ENERGY

of automatically measuring low levels of tritium in water in quasi-real time². This monitor is intended to be finally included in the REA.

Tritium is one of the radioactive isotopes routinely measured in REM tests. Tritium is detected through the low-energy electrons produced in its beta decay, mainly using the Liquid Scintillation Counter Technique (LSC). Due to the limitations of the current tritium detection techniques, described in section 2.1, the TRITIUM project was recently proposed with the objective of building a tritium detector based on scintillating fibers in contact with the water sample. The photons produced in these scintillating fibers are read out by photosensors, either photomultiplier tubes (PMTs) or silicon photomultipliers (SiPMs).

The TRITIUM collaboration is an international consortium of 6 institutions from 3 European countries: Portugal, France and Spain. The final emplacement of the TRITIUM monitor is a site close to the Arrocampo dam (Extremadura, Spain), the water of which is used for the cooling system of the Almaraz nuclear power plant (NPP), located 4 km upstream from the Arrocampo dam.

The monitor will be used to ensure that the tritium levels of the Arrocampo dam water are below the legal limit of 100 Bq/L specified in the EURATOM Directive 2013/59/Euratom [EUR14]. In addition, this will confirm the correct operation of the Almaraz NPP, since an increase of tritium activity released could indicate a malfunctioning of the reactor.

Tritium is one of the most abundantly produced radioisotope in a NPP, as it was verified in the United States Department of Energy (DOE) [Ber98b, Ber98a], in several research facilities in China [Hou18] and in places close to them (ground, surface and waste water).

Tritium is produced in the nuclear reactor cooling water system of

²Quasi-real time is an approximation of real-time measurements. It means a relatively small time, like ten minutes.

NPP by neutron capture of deuterium existing in the heavy water (D_2O), semi-heavy water (HDO) or deuterium created by neutron capture in light water (H_2O). All these processes have a large probability of happening due to the huge neutron flux, of the order of $10^{14} \text{ n cm}^{-2}\text{s}^{-1}$ in the nuclear reactor [?]. Tritium is finally released partially or totally into the environment in a quantity that depends on the reactor type, as shown in Table 1.2. The most common form in which tritium is released into the environment is HTO [Hou18].

Reactor type	Gaseous discharge (GBq/y)	Liquid discharge (GBq/y)
PWR	$3.70 \cdot 10^3$	$2.59 \cdot 10^4$
BWR	$1.85 \cdot 10^3$	$3.70 \cdot 10^3$
HWR	$7.40 \cdot 10^5$	$1.85 \cdot 10^5$
GCR	$7.40 \cdot 10^3$	$1.11 \cdot 10^4$

Table 1.2: Emission of tritium per year from different types of nuclear reactors: Pressurized Water Reactor (PWR), Boiling Water Reactor (BWR), Heavy Water Reactor (HWR) and Gas-Cooled Reactor (GCR) [Hou18].

NPPs are operational since more than 60 years and, nowadays, they are essential for providing a large part of the electric power used all over the world (more than 20% in Spain [Red19] and more than 10% in the world [Int14]). Although the Spanish government is planning to progressively shut all NPPs down, there are other countries like China [Eur16] or United States [Ene19] that promote their use. NPPs are a profitable investment since they are one of the cheapest source of energy production. Their energy production rate is stable as does not depend on meteorological parameters. Moreover, NPPs do not emit greenhouse gases. Although there are alternative energy sources which are being developed quickly (photovoltaic, wind, tidal energy, etc.), as well as other concepts of energy production and saving (local production, energy efficiency, smart cities, etc.), they are currently not enough to cover the population needs. However, NPPs have some important drawbacks such as contamination of fresh water from uranium

1.2. TRITIUM PROPERTIES AND RADIOLOGICAL HAZARDS

mining, nuclear waste, nuclear proliferation and risk of radioactive contamination from accidents as happened in the past: Chernobyl, Fukushima and Three Mile Island [Wor20a]. In any case, world nuclear energy production is most likely not going to be stopped in the next decade. In fact, the United States Energy Information Administration (EIA) expects a future increase of nuclear energy production [Dr.20]. Therefore, safety is not a negotiable aspect and there must be a development in the safeguards, like alarm systems, that warn us of any malfunction of a NPP.

The objective of the TRITIUM project is to ensure that the level of tritium in water is below the Spanish legal limit. This monitor could be used in many different places with radioactive facilities like the future fusion power plants³, nuclear research facilities⁴ or tracking the pathway of tritium discharges to ground water [Saw00].

1.2 Tritium Properties and Radiological Hazards

Tritium is the only radioactive isotope of hydrogen present in the environment. Tritium was produced artificially for the first time in 1934 in neutron capture on deuterium by Ernest Rutherford, Mark Oliphant and Paul Harteck [Oli34] and was isolated in 1939 by Luis Walter Alvarez and Robert Cornog [Alv39], who discovered that tritium is radioactive.

Tritium is a radioactive element with a half-life time of $T_{1/2} = 12.32$ years. It has one proton and two neutrons and decays exclusively through β radiation to the ground state of the ^3_2He isotope of helium, which is a stable nuclei, through the process,

³The International Thermonuclear Experimental Reactor, ITER, will need up to several tens of kilograms of tritium to function, which corresponds to various TBq of activity.

⁴Tritium is one of the main emission from nuclear research facilities [Fer19, Bro].




Figure 1.3 – (Above) Tritium energy levels [Inta]. (Below) Graphic representation of tritium decay [Wor20b].



In Figure 1.3, the scheme of tritium energy levels is shown. In this decay it is not possible to detect the neutrino because of its extremely weak interaction with matter ($\sigma \approx 10^{-44} \text{ cm}^2$) [Val07] and, since ${}^3\text{He}$ has a much larger mass than electrons and neutrinos, the energy carried by the daughter nucleus is very small. Therefore, the detection of tritium is only feasible through its decay electron.

The energy released in the tritium decay is $Q_\beta = 18.6 \text{ keV}$, shared between the decay products. Therefore, the energy spectrum of the decay electrons is a continuum with a maximum value of 18.6 keV, as shown in Figure 1.4. This energy spectrum has an average of 5.7 keV and the most likely energy is around 4.5 keV. Tritium is the radioactive isotope with the lowest energy released in β decay [Dep16]. Consequently, the β particle emitted has a very short mean free path, given in Table 1.3. This short mean free path is a major issue in tritium detection, as the electron detection requires a highly sensitive detector. Tritium electrons have a low penetration in the human body and they are easily stopped by clothes

1.2. TRITIUM PROPERTIES AND RADIOLOGICAL HAZARDS

or laboratory gloves, resulting in a low radiological hazard from external exposure. Nevertheless, the danger of tritium increases when it is ingested or inhaled since it binds and undergoes the same chemical reactions as hydrogen.




Figure 1.4 – Energy spectrum of tritium electrons [Lin20].

Tritium is naturally produced in the environment through the interaction of cosmic rays with elements of the upper atmosphere like nitrogen $^{14}\text{N}(\text{n}, ^3\text{H})^{12}\text{C}$ [Dep16] and oxygen $^{16}\text{O}(\text{n}, ^3\text{H})^{14}\text{N}$ [Hai14]. Around 99% of cosmogenic tritium forms water (HTO) and reaches the Earth's surface as rain with an estimated production rate of $4 \cdot 10^6$ Ci/yr ($1.48 \cdot 10^8$ GBq/yr), producing a tritium concentration of 0.6–1.2 Bq/L in precipitation [Hou18, Dep16].

Tritium can be produced artificially in the environment from different anthropogenic sources [Hou18, Dep16]. There is a large amount of

	Penetration Depth	
Energy	5.7 keV	18.6 keV
Material		
${}^3_1\text{H}_2$	0.26 cm	3.2 cm
Air	0.036 cm	0.45 cm
Water, soft tissue (solid matter with a density of $1 \text{ g} \cdot \text{cm}^{-3}$)	0.42 μm	5.2 μm

Table 1.3: Penetration depth of decay electrons of mean (5.7 keV) and maximum (18.6 keV) energies in different media (tritium gas, air at STP and water) [Bla91].

tritium which was produced in military nuclear explosions between 1945 and 1975, with an estimated total production of $8 \cdot 10^9 \text{ Ci}$ ($2.96 \cdot 10^{11} \text{ GBq}$), a part of which remains to the date. In these nuclear explosions, tritium was produced mainly from the nuclear reactions ${}^{14}\text{N}(\text{n}, {}^3\text{H}){}^{12}\text{C}$ and ${}^2\text{H}(\text{n}, \gamma){}^3\text{H}$. Tritium is produced by commercial producers of radioluminescent and neutron generator devices ($1 \cdot 10^6 \text{ Ci/yr}$), nuclear power and defense industries (around $2 \cdot 10^6 \text{ Ci/yr}$) and several research facilities and nuclear reactors for energy production ($2 \cdot 10^6 \text{ Ci/GWyr}$). The production cross sections of the relevant processes are shown in Table 1.4.

Source	Origin	Nuclear reaction	Cross section (b)
${}^2_1\text{H}$	Water coolant	${}^2_1\text{H}(\text{n}, \gamma){}^3_1\text{H}$	$5.2 \cdot 10^{-4}$
${}^3_2\text{He}$	Helium coolant	${}^3_2\text{He}(\text{n}, \text{p}){}^3_1\text{H}$	5330
${}^6_3\text{Li}$	Moderator	${}^6_3\text{Li}(\text{n}, \alpha){}^3_1\text{H}$	940
${}^{10}_5\text{B}$	Moderator, control rods	${}^{10}_5\text{B}(\text{n}, 2\alpha){}^3_1\text{H}$	3835

Table 1.4: Most common nuclear reactions of artificial tritium production [Hou18].

Tritium levels in water of the environment, excluding the current

1.2. TRITIUM PROPERTIES AND RADIOLOGICAL HAZARDS

anthropogenic radioactive sources, are between 1 and 4 Bq/L, larger than expected from cosmogenic background levels (0.6 – 1.2 Bq/L) [Cal12]. This is attributed to nuclear weapon tests. Tritium levels in rivers around a NPP are between 1 and 10 Bq/L and even between 20 and 50 Bq/L at the water discharge site of NPPs [Cal12], where the produced tritium is partially or totally released into the environment, mainly in HTO form.

The effect of NPPs on tritium levels in the environment can be observed in the REM data, for example for the case of Cofrentes NPP. The tritium level is measured in three different places along the Jucar river, marked on the map shown in Figure 1.5. P1 is located on the river 6 km upstream from the NPP, and P2 and P3 are located 1 and 5 km downstream, respectively. The level of tritium measured in these three locations is shown as a function of time in Figures 1.6a, 1.6b and 1.6c respectively. In these figures, the detection limit and the measured activity are plotted with white and green dots, respectively. The measured activity is only displayed when it is larger than the corresponding detection limit. The tritium level in the river is larger near the discharge of the NPP and decreases 4 km downstream, as can be seen from these data. Two additional measurements of the tritium level in groundwater are included, points S1 and S2 on the map in Figure 1.5, located 1 km upstream and downstream from the NPP, respectively. Both tritium levels are shown in Figures 1.7a and 1.7b, respectively, where it can be observed that they are below the detection limit. It is important to note that, although environmental tritium level is affected by the NPP in the case of Cofrentes, these levels are below the maximum allowed limit. The maximum level of tritium measured since January 2, 2006 is around 32 Bq/L, below the limit of 100 Bq/L recommended by the Euratom 2013 directive.

Tritium can be absorbed in our body by inhalation and ingestion. Tritium is present in three different chemical forms, gaseous tritium (mainly HT), tritiated water (mainly HTO) and organically bound tritium (OBT):








Figure 1.5 – Tritium sampling locations around Cofrentes NPP.

1. Gaseous tritium, usually found mixed in the air, is the least harmful form since less than a $(3 - 5) \cdot 10^{-3} \%$ is absorbed by the human body, which is negligible [Dep16]. However, gaseous tritium can be transformed into tritiated water, more harmful from the radiological point of view [Dep16], through the oxidation and exchange reactions by

Oxidation :



Exchange



(1.2)

2. Tritiated water, called tissue free water tritium, TFWT, is found in drinking water and food. This type of tritium molecule has a large impact since the 99% of it is absorbed [Dep16]. The biological life-time of tritiated water corresponds to the water cycle in the body, around 9.5 days ($\pm 50\%$), during which tritium remains in our body [Dep16, Cal12, Mas21, Lee18]. As in the case of water, the biological life-

1.2. TRITIUM PROPERTIES AND RADIOLOGICAL HAZARDS




Figure 1.6 – Tritium activity levels in surface water around Cofrentes NPP from January 2006 to November 2019. a) 6 km upstream. b) 1 km downstream. c) 5 km downstream. The white points are the detection limits and the green points are the measured activity when this is above the detection limit [Conb]. The maximum level of tritium measured since January 2, 2006 is around 32 Bq/L.



Figure 1.7 – Tritium activity levels in groundwater around Cofrentes NPP from January 2006 to November 2019 [Conb]. a) 1 km upstream from the NPP. b) 1 km downstream from the NPP.

1.2. TRITIUM PROPERTIES AND RADIOLOGICAL HAZARDS

time of tritiated water depends on various external parameters such as temperature, humidity, drinking habits, etc. and can be reduced by the use of diuretics [Dep16].

3. Organically bound tritium (OBT), normally found in food, forms a covalent bond with carbon molecules in organs. This form corresponds to 5 – 10 % of tritium absorbed in the body. Although OBT is less absorbed in the body than tritiated water, it can be more dangerous since it has a longer biological life time, that varies from twenty to more than fifty days [Mar72, Lee18], depending on the type of bond that tritium forms, either OBT exchange (e-OBT), an unstable bond that can be eliminated by metabolic processes, or tightly OBT (t-OBT), a stable bond that cannot be eliminated by metabolic processes [Cal12, Mas21, PF81, Mar72].

Tritium can cause the same effects than X-rays or γ rays, such as DNA mutations or cell death. In the worst cases, tritium can produce the loss of the functionality of the organ or the development of tumors. In fact, the consequences of tritium radiation may be worse than similar doses of γ radiation since its biological efficiency⁵ is two or three times higher [Str93].

In summary, tritium is a naturally occurring radioactive element. It affects health of living organisms if these are excessively or chronically exposed to tritium. Because of that, several countries have developed a legislation to manage the release of tritium into the environment and to ensure that tritium levels are safe for living organisms.

⁵The biological efficiency is used to quantify the damage produced in the living cells due to an external radiation.

1.3 Current Legislation

Due to the radiological risk of tritium, the current legislation limits the release of tritium into the environment, ensuring that the levels are below a safe value for public health.

The guidelines to limit the radioactive elements in drinking water for many countries are based on the radiation protection methodology developed by the ICRP [Int91] and the recommendations from WHO [Wor17]. The objective of the international radiation methodology is to protect people and the environment from the negative effects of ionizing radiations but allowing beneficial activities that involve a reasonable radiation exposure. This is based on three main points, which are:

1. The justification: The benefit from radiological exposure must outweigh the detriment to health that it causes.
2. The ALARA principle ("As Low As Reasonably Achievable"): The radiological exposure must be kept as low as possible considering social and economic factors.
3. The dose limitation: Limit that must never be exceeded.

While the ICRP recommends a maximum dose of 1 mSv/yr, excluding the natural background and medical interventions, the WHO is more conservative, recommending a maximum dose of 0.1 mSv/yr, which corresponds to less than 5% of the annual dose due to background radiation, 2.42 mSv/year. The guideline reference level of each radionuclide in drinking water, GL, is usually calculated from these recommendations as,

$$GL(\text{Bq/L}) = \frac{RDL}{DCF \cdot q} \quad (1.3)$$

where RDL is the reference dose level in Sv/yr, DCF is the dose conversion

1.3. CURRENT LEGISLATION

factor (the value provided by ICRP for tritium is $1.8 \cdot 10^{-11}$ Sv/Bq [Int96]) and q is an estimation of the annual volume of drinking water consumed by a person (normally assumed two liters per day, 730 L/yr). The GL calculated for tritium in drinking water according to the ICRP and WHO recommendations is 76 103 Bq/L and 7 610 Bq/L respectively. This means that tritiated water with activities below these values is considered not harmful for health. Based on these recommendations, the national organizations develop their own legislation limits of exposure to radionuclides. In Spain, the responsible organization for this commitment is the CSN. Most of the countries in the world implement the RDL of 0.1 mSv/yr recommended by the WHO. The legal limit for tritium in drinking water in this case is 7 610 Bq/L but it is often approximated in different ways. Some countries like Switzerland [Dep17] or some organizations like the WHO [Wor17] take this value as 10 000 Bq/L. Others like some territories of Canada, such as Ontario and Québec, truncate this value to the first number 7 000 Bq/L [Ont94, Hyd16]. There are other countries, like Russia, which use the much more accurate approximation value of 7 700 Bq/L [Int07]. Other countries, like Australia, prefer to implement the RDL of 1 mSv/yr recommended by the ICRP, which corresponds to 76 103 Bq/L [Aus21]. Finland takes the ICRP recommendations but uses only half of this value, 0.5 mSv/yr, rounded to a legal limit of 30 000 Bq/L for tritium in drinking water [Nuc93]. There are two different exceptions to these recommendations:

1. Most of the USA states, like California, establish a RDL of 4 mrem (0.04 mSv), which corresponds to a legal limit of 20 nCi/L (740 Bq/L) [Off07]. This value was proposed by the United States Environmental Protection Agency (EPA) as a result of an analysis carried out on the available data [Uni00].
2. Most of the EU countries, such as France, Germany or Spain, consider a GL of 100 Bq/L, which is one of the most restrictive limit in the world [Ins18, Bun06, Con13]. This value arises from the consideration that tritium is an indicator of the presence of other radionuclides more

dangerous than tritium. These limits are fixed by the EURATOM Council Directive [Eur13].

All limits mentioned in this section are summarized in table 1.5.

Country/Agency	GL (Bq/L)
ICRP	76 103
WHO	10 000
Switzerland	10 000
Canada	7 000
Russia	7 700
Australia	76 103
Finland	30 000
United States	740
European Union	100

Table 1.5: Legal limit of tritium in drinking water (GL) established in several countries.

1.4 This Thesis

The objective of this thesis is to design, build and commission an automatic station for real-time monitoring of low tritium activities in water. This is mainly focused on the development and optimization of the TRITIUM prototypes and the active veto. This thesis is divided into eight chapters structured as follows:

1. **Chapter 1** provides a brief introduction to tritium detection, reports some important properties of tritium, and discusses the current legislation that limits tritium levels for human consumption in many countries around the world.

1.4. THIS THESIS

2. **Chapter 2** describes the state-of-the-art of tritium detection and introduces the TRITIUM project.
3. **Chapter 3** outlines the different parts of the TRITIUM monitor, which are the water purification system, the background rejection system (consisting of a lead shield and a active veto) and the tritium detector.
4. **Chapter 4** reports the calibrations of the different parts of the TRITIUM monitor and describes the developments aimed at improving the efficiency of tritium detection.
5. **Chapter 5** details the geometrical configuration of the different prototypes built in the TRITIUM project and the measurements taken with them.
6. **Chapter 6** details the Monte Carlo simulations performed in the TRITIUM project and shows the results obtained.
7. **Chapter 7** summarizes and discusses the most important results achieved by the TRITIUM collaboration.
8. **Chapter 8** Summarize the main results of this PhD work and discusses the future of the TRITIUM project.

Chapter 2

Methods of Detection of Tritium In Water

2.1 Tritium Detection State-of-the-Art

Measurement of tritium activity is one of the routine environmental controls that are carried out in the vicinity of nuclear research facilities and nuclear power plants during their energy production lifetime. This measurement is carried out with different available technologies according to the state of the art of tritium detection. The most employed techniques are summarized in Table 2.1.

Nowadays, the most used technique for measuring tritium in water is liquid scintillator counting (LSC). This technique consists of mixing a liquid sample (some milliliters for environmental measurements or less for higher activities) with liquid scintillator. This mixture is usually made in a ratio of 50:50 but it depends on the detection system and on the activity of the samples [AH99, Hof92a]. In this technique, the β particles emitted from the sample excite the molecular energy levels of the liquid scintillator

2.1. TRITIUM DETECTION STATE-OF-THE-ART

	LSC	IC	Calorimetry	BIXS
Measured quantity	Scintillation photons	Ionization current	Heat	X-rays
MDA	\sim Bq	10 – 100 kBq	\sim GBq	\sim MBq
Sample state	Liquid	Gas, vapor	All	All

Table 2.1: State-of-the-art tritium detection techniques. This table shows the measured quantity, the minimum detectable activity (MDA) and the sample form for four different techniques, liquid scintillator counting (LSC), ionization chamber (IC), calorimetry and beta induced X-ray spectrometry (BIXS).

which promptly decays emitting several photons with a well-known energy (fluorescence), usually in the visible spectrum. Finally, these photons are detected with photosensors which convert the optical signal into a measurable electrical charge. The liquid scintillator technique has a very good detection sensitivity for low activity levels of tritiated water (< 1 Bq/L) [Pal07] but has the disadvantages of long measurement time (up to 2 days) and production of chemical waste, since liquid scintillators contain toluene which is toxic. In addition, the LSC technique requires special staff for sampling, chain of custody and laboratory analysis which require economic and time resources. In order to overcome these difficulties, efforts were made to build a tritium monitor based on LSC which have not achieved a low enough MDA [Sig94].

The ionization chamber technique (IC) consists of a gas chamber filled with gas (sample), which contains electrodes that collect the ionization current produced by the β radiation in the gas. This is a simple and fast system, but it has a high MDA (> 10 kBq) and requires samples in a state of gas or steam [Khe02, Che13]. The IC technique also requires sample conditioning, chain of custody and laboratory analysis.

The calorimetry method is based on the measurement of the heat generated in the detection medium (normally platinum) [Ale11, BD13]. The disadvantages of this technique are its high MDA (of the order of a GBq) and the requirement of a long measurement time (2 days or more).

The Beta Induced X-ray Spectrometry (BIXS) is based on the measurement of the bremsstrahlung radiation produced by the tritium decay electrons, by a NaI(Tl) crystal coupled to a PMT [Mat07, Mat08] or silicon drift detector (SDD) [Nie15]. The limitation with this technique is its high MDA (of the order of MBq).

There are additional methods for tritium detection, although they are less employed or less developed, each one with its own advantages and limitations. For example, the avalanche photodiode (APD) cannot be used in contact with water [Sha97], the mass spectrometry needs to store the sample during several months [JB10] and the cavity ring spectroscopy requires a special optical configuration that is not possible outside a laboratory [Bra15].

All the above techniques are offline methods that need a long time for sample collection, shipment to a laboratory and activity measurement. Therefore, they cannot be used for in-situ monitoring of tritium in water. The liquid scintillation technique is the only one with a MDA smaller than the requirement of 100 Bq/L of tritium in water established by the EURATOM directive.

The purpose of the TRITIUM project is to develop an alternative method, based on solid scintillators, that allows to accomplish the requirements of in-situ monitoring of levels as low as 100 Bq/L in quasi-real time. There are several studies with solid scintillators so far:

1. The study by M. Muramatsu, A. Koyano and N. Tokunaga in 1967 used a scintillator plate read out by two PMTs in coincidence [Mur67].

2.1. TRITIUM DETECTION STATE-OF-THE-ART

2. The study by A. A. Moghissi, H. L. Kelley, C. R. Phillips and J. E. Regnier in 1969 used one hundred plastic fibers coated with anthracene powder and read out by two PMTs in coincidence [Mog69].
3. The study by R. V. Osborne in 1969 used sixty stacked scintillator plates read out by two PMTs in coincidence [Osb70].
4. The study by A. N. Singh, M. Ratnakaran and K. G. Vohra in 1985 used a scintillator with several holes read out by PMTs in electronic coincidence [Sin85, Rat00].
5. The study by K. J. Hofstetter and H. T. Wilson in 1991 tested different shapes of scintillator plastics like several sizes of beads, fibers, etc. The best result obtained for solid plastic scintillators was a tritium detection efficiency, ε_{det} , of the order of $10^{-3}(\text{Ls}^{-1}\text{kBq}^{-1})$ [Hof92b, Hof92c].

Reference	$\varepsilon_{det} \times 10^{-3}$ $\text{L kBq}^{-1}\text{s}^{-1}$	F_{sci} cm^2	$\eta_{det} \times 10^{-6}$ $\text{L kBq}^{-1}\text{s cm}^{-2}$	MDA kBq L^{-1}
[Mur67]	0.39	123	3.13	370
[Mog69]	4.50	> 424	< 10.6	37
[Osb70]	12	3000	4	37
[Sin85]	41	3000	13.7	< 37
[Hof92b]	2.22	~ 100	< 22.2	25

Table 2.2: Results of scintillator detectors developed for experiments for tritiated water detection. This table shows for the quoted studies the efficiency of the detector (ε_{det}), its active surface (F_{sci}), its specific efficiency, defined as efficiency normalized to active surface ($\eta_{det} = \varepsilon_{det}/F_{sci}$), and MDA.

The results of those studies are summarized in Table 2.2. As the active surface of the plastic scintillator (F_{sci}) varies largely with the detector type, the specific detector efficiency (η_{det}), which is the intrinsic efficiency normalized to its active surface, is used to compare the results. Finally,

the MDA in those studies are of the order of a few tens of kBq/L. The development of a detector with a much lower MDA is thus essential to comply with the EURATOM directive of 100 Bq/L of tritium in water for human consumption.

2.2 The TRITIUM Project


As a conclusion of section 2.1, the current techniques cannot be used for tritium monitoring in quasi-real time since they have either a high MDA or they work in off-line mode. To overcome these limitations, the TRITIUM project [Tri], with the title of "Design, construction and commissioning of automatic stations for quasi-real time monitoring of low radioactive levels of tritium in water", was proposed. The TRITIUM collaboration is an international consortium of six institutions from three European countries: The University of Aveiro, in Portugal, the University of Bordeaux and the Centre National de la Recherche Scientifique (CNRS, Section Aquitaine-Limousin), in France and the University of Extremadura, the Junta de Extremadura and the University of Valencia, in Spain.

This project was funded by the Interreg Sudoe program of the European Economic Community in the 2016 call, with reference number SOE1/P4/EO214. The purpose of this project is the development of an automatic station for in-water tritium monitoring, in situ and in quasi-real time. The tritium detector consists of a bundle of scintillating fibers in contact with the water sample which detect the tritium decay electrons. These fibers are read out with photosensors (PMTs or SiPM). The specific efficiency obtained by Moghissi et al. for scintillating fibers is sufficiently high to justify our choice of scintillating fibers as a detection medium. Additional elements are used to improve the tritium detection sensitivity such as a water purification system, which prepares the water sample before introducing it in the detector for tritium measurement, and a cosmic veto

2.2. THE TRITIUM PROJECT



(a)



(b)

Figure 2.1 – a) Arrocampo dam and Almaraz Nuclear Power Plant. b) Tagus river along Spain and Portugal.

and a passive shielding, which reduce the natural radioactive background of the tritium detector. Several electronic modules which control the different parts of the monitor, analyze the tritium measurement and send an alarm if the configured limit (100 Bq/L) is exceeded.

A crucial problem is to distinguish tritium signals from the background because tritium events have low energy (\sim keV) and fall in an energy range of the spectrum where background events are significant. To reduce the background of TRITIUM monitor, coincidence techniques are employed.

The TRITIUM monitor will be installed in the Arrocampo dam, Almaraz (Spain), displayed in Figure 2.1, where the Almaraz NPP releases the water from its secondary cooling circuit. This NPP has two nuclear reactors of PWR type. Arrocampo dam is located near the Tagus river, shown in Figure 2.1b, which is the longest river in Spain, with a length of 1007 km. This river, shown in Figure 2.1a, rises in Aragon (Spain) and flows into the Atlantic Ocean through Lisbon (Portugal). The water of this river is used for agriculture and drinking water by both Spanish and Portuguese people. For this reason, an international cooperation is necessary in order to control and maintain the quality of the Tagus river water.

Each institution of the TRITIUM collaboration is dedicated to the development of a different part of this project:

1. The University of Extremadura group has developed and installed the water purification system to produce water with very low conductivity, $\sigma \approx 10 \mu\text{S}/\text{cm}$ (two orders of magnitude less than raw water, $1000 \mu\text{S}/\text{cm}$). This purification process is very important for two reasons. On the one hand, for maintaining the TRITIUM detector pristine, which is critical for its long-term functionality. On the other hand, to reduce the natural background since several natural radioactive isotopes present in this water (except tritium), such as ^{40}K and natural radioactive series, are removed. This system is described in section 3.3.
2. The French group has developed the passive shielding for the detector. This shielding is made of lead with low intrinsic activity in order to reduce the external natural background of the system. This shielding is presented in section 3.4.1.
3. The Aveiro and Valencia groups have collaborated for designing, developing and building four different prototypes of the TRITIUM detector and active vetos for reducing cosmic events. These prototypes and vetos are described in chapter 5 and section 3.4.2, respectively. These groups have also carried out simulations of the detector, which are reported in chapter 6.

The important characteristics required for the TRITIUM detector are:

1. *Compactness.* This is an important requirement because in the place where the detector is planned to be installed there is little space. Compactness also allows portability and cost reduction.
2. *Modularity.* The modularity of the TRITIUM detector is important for flexible geometrical configuration and for improving its tritium detection sensitivity. Modularity also facilitates construction and maintenance.

2.2. THE TRITIUM PROJECT

3. *Thin active volume and large active area.* The mean free path of β particle from tritium decay is very short. Thus, a thin detector active volume is needed. In practice, an active thickness beyond the mean free path of the tritium electrons only contributes to background. In addition, as reported in section 2.1, the efficiency of this type of detector scales with the active area, so it is crucial to design a detector with the largest possible active area.
4. *High detection efficiency for tritium.* As the tritium activities to be measured are very low, the loss of tritium events strongly affects the accuracy of measurements.
5. *High specificity to tritium.* The monitor must be able to distinguish tritium signals from other radioactive decays in the sample.
6. *Quasi-real time response.* It is crucial that the system operates in quasi-real time (1 h or less) in order to detect any anomalous tritium release as fast as possible.
7. *Ruggedness.* The final goal of the project is to install an automatic system working during a number of years requiring only occasional intervention of specialized operators. Therefore, a rugged monitor is required.

In order to measure in quasi-real time, it is needed to work *in situ*, that is, in the same place where the water sample is taken. Working *in situ* has some advantages such as: 1) Cheap running cost, since sampling process, chain of custody, etc. are eliminated. 2) Quasi-real time measurements. 3) Safe monitoring since personal dose is reduced. 4) Changes in activity can be detected quickly.

Chapter 3

Design Principles and Components of TRITIUM

3.1 Detector System Overview

The objective of the TRITIUM project is the design, development, construction and commissioning of an automatic station for real-time monitoring of low levels of tritium in water. To achieve this aim, the TRITIUM collaboration has developed a monitor consisting of several parts, listed below:

1. The TRITIUM detector, described in chapter 5, is based on several modules read out in parallel. Each module consists of hundreds of plastic scintillating fibers, which are in contact with the water sample measured, read out by two coincident photosensors. The photosensors considered are photomultiplier tubes (PMT) and silicon photomultipliers (SiPM) (section 3.2).
2. The water purification system (section 3.3) that prepares for measurement the water sample, taken from the Arrocampo dam. This system

3.1. DETECTOR SYSTEM OVERVIEW

removes all the organic particles dissolved and all the particles with a diameter greater than $1 \mu\text{m}$ without affecting the tritium content of the sample. This system is important for two reasons: First, because the mean free path of tritium in water is very short, 5 to $6 \mu\text{m}$, hence it is essential to avoid organic and mineral depositions onto the fiber surface since this would prevent the tritium decay electrons from reaching the fibers. Second, minerals dissolved in water may contain radioactive isotopes like ^{40}K , which would increase the background. As the activity limit to be measured is low (down to 100 Bq/L), background reduction is crucial.

3. The background rejection system (section 3.4) has two different parts. The first one is a passive shield, consisting of a lead castle inside which the TRITIUM detector is located. This castle is employed to suppress the background of natural radioactivity and cosmic rays with energies up to 200 MeV/nucleon. The second part is an active veto, consisting of two plastic scintillating plates located inside the passive shield, above and below the tritium detector, which are read out by photosensors. The goal of this active veto is to suppress the remaining high energy events ($> 200 \text{ MeV}$) from cosmic rays that cross the passive shield and contribute to the background. The technique employed to suppress their contribution consists of reading the tritium detector in anti-coincidence with the active veto.
4. A readout electronic system which allows the acquisition and processing of the data, in order to provide an alarm signal in case the tritium level measurement within a short interval of time exceeds the required limit of 100 Bq/L.

The TRITIUM system is planned to be part of the network of automatic stations, REA.

3.2 TRITIUM Detector

As discussed in section 2.1, the TRITIUM monitor consists of a chain of three main elements, plastic scintillating fibers, that produce scintillating photons in response to a tritium electron decay, the photosensor, that detects the photons produced in the scintillator and produces an electronic pulse than gives information on the detected photons, and the electronic system, which is in charge of processesing and analyzing the electronic pulse given by the photosensor. A scheme of a scintillation detector setup is shown in Figure 3.1.




Figure 3.1 – Scheme of the scintillator detector.

3.2.1 Interaction of Fast Electrons and Photons with Matter

The interaction of particles with matter is discribed in this section, focusing on the particles and energy range relevant for this thesis, electrons (0 – 18 keV), photons in the visible range (approx. 380 – 750 nm) and γ rays from the background and high energy cosmic rays.

Electrons have charge, so their interaction with matter is mainly

3.2. TRITIUM DETECTOR

through the orbital atomic electrons by the Coulomb force. The electron trajectory is much more tortuous than that of heavier particles because of its small mass. Furthermore, these electrons lose a significant amount of energy in each collision. The specific energy loss, defined as $S = -\frac{dE}{dx}$, gives the energy loss of the particle per unit of path length. In the case of electrons, the total energy loss has two main contributions, the collisions (elastic and inelastic) and the radiative processes (bremsstrahlung), which are roughly proportional [Kno99, Leo94]:

$$\frac{dE}{dx} \approx \left(\frac{dE}{dx} \right)_c + \left(\frac{dE}{dx} \right)_{br}; \quad \frac{\left(\frac{dE}{dx} \right)_{br}}{\left(\frac{dE}{dx} \right)_c} \approx \frac{EZ}{700} \quad (3.1)$$

where E is the energy of the electron in MeV and Z is the atomic number of the absorbing material. Due to this energy loss, electrons penetrate a material to a depth where they have lost their kinetic energy. This distance, known as range, is quoted for tritium electrons in Table 1.3.

The material chosen for the detection of tritium decay electrons is organic plastics since, due to its low density, the backscattering process is reduced, optimizing their detection. It has been chosen in the form of fibers in order to increase the active area and, therefore, the efficiency of the detector.

As photons do not have charge, their possible interactions with matter are photoelectric effect, Compton effect, coherent scattering and pair production. The probability of each process, displayed in Figure 3.2, depends on the energy of the photon, $E_\gamma = h\nu$, and on the atomic number of the material, Z . The optical photons have a wavelength between 400 and 700 nm, that corresponds to energies of the order of the eV. Therefore, pair production does not play any role for optical photons since this requires a

photon energy of at least 1.022 MeV.




Figure 3.2 – Domain regions of the three most probable types of interactions of gamma rays with matter. The lines show the values of Z and $\hbar\nu$ where two interaction processes are equally likely [Kno99].

The photoelectric effect occurs when a photon interacts with an orbital electron in the material, losing all its energy. This energy is absorbed by an electron that is ejected from the atom (ionization). The energy of the resulting electron, E_e , is [Kno99, Leo94]:

$$E_e = E_\gamma - E_b \quad (3.2)$$

where E_b is the binding energy of the electron in this material. The probability of this effect depends on the number of available electrons in matter through the atomic number Z , and the energy of the electron according to the expression [Kno99]:

3.2. TRITIUM DETECTOR

$$(Pr)_{Ph-eff} \approx \frac{Z^n}{E_\gamma^{3.5}} \quad (3.3)$$

Thus, the photoelectric effect is most probable for elements with high atomic number. This is the reason why this type of elements are the best shields against gamma radiation and why the passive shield of TRITIUM monitor consists of lead bricks (section 3.4.1).

The Compton effect occurs when a photon interacts with an orbital electron of the material, transferring part of its energy to the electron, which is scattered at an angle θ with respect to the direction of the incident photon. If the electron binding energy is neglected, the energy transferred to it, E_e , is given by [Kno99, Leo94]:

$$E_e = \frac{\frac{E_\gamma^2}{m_0 c^2} (1 - \cos\theta)}{1 + \frac{E_\gamma^2}{m_0 c^2} (1 - \cos\theta)} \quad (3.4)$$

where m_0 is the rest mass of the electron and c is the speed of the light in the vacuum. The probability of the Compton effect is proportional to the atomic number, Z , and decreases with the energy of the photon. As it can be seen in Figure 3.2, for photon energies in the visible spectrum (of the order of eV), the Compton effect is only likely for very light materials ($Z < 4$). For heavier materials the photoelectric effect is dominant.

In the coherent scattering, the atom is neither excited nor ionized and the photon conserves its energy in the collision. Coherent scattering is probable for photons with low energies and materials with high atomic numbers.

Finally, in the pair production process, the photon is converted in

an electron and a positron.

$$\gamma \longrightarrow e^- + e^+ \quad (3.5)$$

As can be seen in Figure 3.2, this is the dominant interaction process for high energy photons, which are the photons produced by cosmic rays that can affect the TRITIUM detector.

3.2.2 Plastic Scintillators

Scintillators are materials widely employed for radiation detection in nuclear physics. Scintillators convert kinetic energy of the incoming particles into light which can be detected and quantified. Light emission is produced due to the photon de-excitation of atoms of fluorescent molecules in the material.

Light production is linear with energies for a wide energy range of incoming particles. Scintillators should have good optical properties, such as being transparent to the wavelength of their own emission and having a refractive index close to that of photosensor windows in order to optimize optical coupling and light transmission. Photon emission in scintillators is a statistical process that follows a Poisson distribution.

Scintillators can be organic or inorganic. Inorganic scintillators normally have a high atomic number and density, so their light output is high. For these reasons they are suitable for gamma-ray spectroscopy. Organic scintillators are generally fast and they are used for charged particles and neutron detection. This section is focussed on organic scintillators since they are the ones used in the TRITIUM detector. Organic scintillators are based on fluorescent molecules dissolved in a base solvent, usually aromatic hydrocarbons as $C_{18}H_{14}$, $C_{24}H_{22}N_2O$ or $C_{15}H_{11}NO$ with an average atomic number between 3.5 and 5. The fluorescent molecules of organic scintil-

3.2. TRITIUM DETECTOR

lators have a π -electron structure. The energy levels of their electrons are commonly illustrated with a Jablonsky diagram, shown in Figure 3.3. This diagram shows the fundamental singlet states, S_{0i} , the excited singlet states, S_{jk} , and the excited triplet states, T_{lm} . The energy difference between S_1 and S_0 states is around 3 to 4 eV, which corresponds to the visible photon emission. As shown in the figure, each energy state is split in close sublevels separated around 0.15 eV. This fine energy structure is due to excitations of molecular vibrational modes tagged by the second index of the energy states. As the energy levels and sublevels have an energy larger than the thermal energy, 0.025 eV, electrons are in the ground state S_{00} at STP. When a particle deposits its kinetic energy in a scintillator, the valence electrons are excited very fast to higher singlet energetic states (times of the order of picoseconds) and are quickly de-excited to the first singlet excited state, S_{10} , through non-radiative processes known as internal conversion. These electrons can de-excite to the fundamental singlet state, S_{00} , through three different physical mechanisms:

1. Prompt fluorescence (process A in Figure 3.3), where the electron in the S_{10} level is de-excited to a sublevel of the ground state S_{0i} , emitting a photon. This process happens immediately after the excitation of the scintillator molecules (of the order of nanoseconds after excitation). Each scintillator has a characteristic emission spectrum that defines its response due to the fluorescence mechanism.

Organic scintillators are practically transparent to their own fluorescence emission because scintillating photons have less energy than the excitation energy. This effect is called Stokes shift and it is represented in Figure 3.4. The intensity of the fluorescence emission in an organic scintillator versus time is the combination of two exponential functions, one associated with the lifetime of the level, τ (of the order of nanoseconds), and the other associated with the energetic level population, τ_1 (of the order of picoseconds) [Kno99].




Figure 3.3 – Jablonsky diagram [Kno99].

$$I = I_0 (e^{-t/\tau} - e^{-t/\tau_1}) \quad (3.6)$$

2. Phosphorescence, where the electron that is in the first singlet excited state crosses to a triplet excited state (process B in Figure 3.3). Such a transition process is called "intersystem crossing". The triplet state is a metastable state with a longer lifetime than fluorescence, of the order of milliseconds after scintillator excitation.
3. Delayed fluorescence, which occurs when an electron is in a triplet excited state but its transition to the ground state is forbidden. In this case, the electron interacts with another electron in a similar state, falling to the first singlet state and quickly de-exciting to the ground state.

3.2. TRITIUM DETECTOR




Figure 3.4 – Stokes shift [Kno99].



This emission has the same emission spectrum as the prompt fluorescence, but with a longer lifetime.

As the prompt fluorescence light produces the scintillator signal, the detector design should optimize its collection and detection and reduce other possible physical mechanisms like phosphorescence or delayed fluorescence. One of the most important parameters that characterizes the scintillator is the scintillation yield¹, defined as the the number of photons emitted per unit of absorbed energy. This yield depends on the type of particle and on other mechanisms that do not produce prompt fluorescence light, like phosphorescence, delayed fluorescence, and non radiative processes like internal conversion. The scintillator yield is normally quoted by the manufacturer

¹The scintillation yield is a way of expressing the efficiency of the scintillator in converting the energy deposited by the particle into photons.

for mips².

Plastic scintillators are easy to machine to any desired shape. The chosen shape for TRITIUM detector is the fiber, specifically, commercial fibers BCF-12 from Saint-Gobain Crystals Inc [SGC21a]. This type of fiber was chosen as the result of a comparative study [Alb17] among some of the best-known commercial manufacturers. The BCF-12 fibers consist of a scintillating polystyrene core with the possibility of being covered by one or two polymethylmethacrylate (PMMA) claddings.

When a particle deposits all or part of its kinetic energy in the scintillating fiber, photons are produced in the fiber core as a result of the fluorescence process. The number of photons produced depends on the scintillating yield and its value is around 2.4% for the BCF-12 fibers, which means that a scintillation yield of about 8000 photons per MeV is produced for a mip. For instance, for tritium electrons of 18.6 keV, these fibers release 148 or less photons, as electrons of these energies are not mips. The emission spectrum of the fibers employed in this work, is shown in Figure 3.5.

The scintillation light is guided to the sensitive part of the photo-sensor. A single photon produces a signal with a probability called quantum efficiency. Fibers (and scintillators in general) use the optical property of Snell's law [Bor19] to guide their photons to the ends of the fibers. The guiding mechanism is determined by the interface between the core and the surrounding material. When a photon hits this interface, it is refracted (and therefore lost) following the Snell equation, 3.8 [Bor19].

$$n_0 \sin\theta_0 = n_1 \sin\theta_1 \quad (3.8)$$

where θ_0 is the incident angle formed by the photon and normal to the surface of in the first medium, with refractive index n_0 and θ_1 is the refraction

²The MIP, Minimum Ionized Particles, is a particle that has the speed that generates minimum ionization.

3.2. TRITIUM DETECTOR




Figure 3.5 – Emission spectrum of BCF-12 scintillating fibers of Saint-Gobain [SGC21a].

angle formed by the photon and normal to the second medium with refractive index n_1 . If the surrounding material has a lower refractive index than the core of the fiber, as it is the case with scintillating fibers, there exist a critical angle, θ_c , beyond which photons will be totally reflected ($\theta_1 = 90^\circ$) and therefore kept within the fiber as illustrated in Figure 3.6:

$$\theta_c = \text{asen} \left(\frac{n_1}{n_0} \right) \quad (3.9)$$

The trapping efficiency or photon collection efficiency is defined as the efficiency of the scintillator to guide photons. For BCF-12 fibers with optical clad this efficiency is between 3.44% and 7% per meter of fiber (depending on where the emission point and is minimum on the fiber axis and maximum near the core-clad interface). Therefore, from the 148 photons initially created by a tritium decay electron detected with the maximum energy, 18.6 keV, and assuming a light yield of 8000 photons/MeV according to the manufacturer, only 52 photons are guided along the 20 cm fiber

length of the TRITIUM detector, considering the maximum trapping efficiency (7%) and assuming a linear dependence with the length of the fiber. Thus, the output signal is weak and is in the energy range of the spectrum where electronic noise is already significant. As described in the following chapters, a great effort was made to minimize electronic noise by different techniques. In Figure 3.6, the light collection in a fiber is illustrated.




Figure 3.6 – Photon collection in a single clad fiber [SGC21a].

The cladding material has a higher refractive index than air or water. Due to that, the cladding is useful for protecting the core surface from dirt or aggressive external agents that may reduce the light collection but at the cost of increasing the critical angle and its corresponding loss of light. Three different cases are shown in Table 3.1, where the cladding effect is illustrated.

As can be seen, the trapping efficiency of uncladded fibers BCF-12 surrounded by water or air is larger than for cladded fibers. However, in the practice, it is difficult to achieve a perfect air-core or water-core interface, and this affects light collection. As commercial claddings are thicker ($30 \mu\text{m}$) than the mean free path of tritium decay electrons in water (around

3.2. TRITIUM DETECTOR

Material	Refractive index	critical angle ($^{\circ}$)
Air	1	42.98
Water	1.33	62.47
Cladding of PMMA	1.49	76.26

Table 3.1: Critical angles associated to different interfaces between polystyrene, $n_0 = 1.6$, and other materials.

5 μm), cladded fibers are not an option for the TRITIUM detector. Hence, special attention is needed for achieving a good enough water-core interface. To achieve this goal a special method was developed in the ICMOL laboratory for preparing fibers for tritium detection, described in section 4.1.1. The relevant parameters of the scintillating fibers used for the TRITIUM detector are given in Table 3.2.

3.2.3 Light Detection in Photosensors

The scintillating photons created in the core of the fiber and guided to its ends are detected by photosensors. Photosensors have a sensitive part that is optimized to detect photons in a range of energy (usually in the visible range) with a certain probability, called quantum efficiency. The photosensors produce an electronic signal that carries information about the detected photons such as their number, detection time, etc. There are many available photosensors that rely on various physical processes, such as photomultiplier tubes (PMTs), silicon photomultipliers (SiPM) or Charge-coupled devices (CCD).

The optimization of the efficiency of a scintillation detector is essential. To do so, the emission spectrum of the scintillator (Figure 3.5 for the fibers used) must overlap as much as possible with the detection efficiency spectrum of the photosensor. The detection efficiency spectrum of

Property	Value
Core material	Polystyrene
Core refractive index	1.60
Density (g/cm ³)	1.05
Cladding material	Acrylic (PMMA)
Cladding refractive index	1.49
Cladding thickness	3%
Numerical aperture	0.58
Trapping efficiency	3.44% minimum
No. of H atoms per cc (core)	$4.82 \cdot 10^{22}$
No. of C atoms per cc (core)	$4.85 \cdot 10^{22}$
No. of electrons per cc (core)	$3.4 \cdot 10^{23}$
Radiation lenght (cm)	42
Emission peak (nm)	435 (Blue)
Decay Time, (ns)	3.2
1/e Length (m)	2.7
Scintillator yield (# γ /MeV)	~ 8000
Operating Temperature	$-20^{\circ}C$ to $50^{\circ}C$

Table 3.2: Properties of BCF-12 fibers from Saint-Gobain Inc. [SGC21a].

3.2. TRITIUM DETECTOR

a photosensor gives the probability of detecting photons as a function of wavelength. The efficiency of a detector is proportional to the product of the emission and the detection efficiency spectra and is largest when both spectra match.

The requirements imposed on the photosensor of the TRITIUM detector are fast response, high gain and high photodetection efficiency. Two different proposals for the TRITIUM detector are investigated, SiPMs and PMTs. Both meet these requirements since they are very fast (of the order of ns), have high gain (of the order of 10^6) and have a high photodetection efficiency (around 50% for SiPMs and 30% for PMTs). Each proposal has its own advantages. SiPMs are more robust and need a lower supply voltage (of the order of 50 V) than PMTs (of the order of 1000 V). Furthermore, due to this difference in the supply voltage, SiPMs have smaller cost per channel than PMTs. However, PMTs, which are the conventional choice, have lower dark count rate than SiPMs and a much lower dependence of gain with temperature.

Photomultiplier Tubes (PMTs)

Photomultiplier tubes are employed as photosensors in nuclear physics since decades. They detect the scintillating photons that reach its sensitive part, the photocathode, and produce an electronic signal, large enough to be easily measured. In Figure 3.7 a schematic drawing of a PMT is given. The PMTs consists of a vacuum tube that has a glass window through which photons can penetrate. The electrons created in the photocathode travel in vacuum. The signal production has two phases:

1. In the photocathode, photons are converted into photoelectrons through the photoelectric effect. The photocathode consists of a thin layer of material, of the order of nanometers, deposited on the inner surface of the PMT window. The material of the photocathode is chosen

CHAPTER 3. DESIGN PRINCIPLES AND COMPONENTS OF TRITIUM




Figure 3.7 – Scheme of a PMT [Kno99].

to optimize the probability of producing photoelectric effect with the scintillating photons. The PMTs used in different R&D setups of the TRITIUM experiment in the University of Valencia are the model R8520-406 from Hammatsu [K.K19] and the material of their photocathode is Bialkali³.

The response of the PMT to long wavelengths is very small, mainly because photon energy is not enough to produce a photoelectric effect or the emitted photoelectron does not have enough energy to overcome the material work function. The response of the PMT at short wavelengths is very weak due to absorption in the window material, quartz in our case. Thus, the response of the PMT has a strong dependence on the energy of the photon. The quantum efficiency (QE) spectrum, shown in Figure 3.8 for the PMTs mentioned above, is defined as the ratio of the number of photoelectrons produced at the cathode of the PMT and the number of photons reaching it.

The maximum value of the PMT quantum efficiency is usually between 20% and 30% [Kno99] (slightly less than 30% for the PMTs employed by us). The emission spectrum of the scintillating fibers used, Figure

³The bialkali material is based on the elements $^{121}_{51}\text{Sb}$, $^{85}_{37}\text{Rb}$ and $^{132}_{55}\text{Cs}$

3.2. TRITIUM DETECTOR




Figure 3.8 – Quantum efficiency spectrum for the PMT used in TRITIUM R&D studies (R8520-406) [K.K19].

3.5, matches the quantum efficiency spectrum of the PMTs used, Figure 3.8, and the positions of both peaks are very close, 435 nm and 420 nm for fibers and PMT respectively. Because of that, the intrinsic efficiency of the TRITIUM detector is maximized.

2. As the number of photoelectrons produced in the photocathode is very small, an electron multiplication stage is employed to obtain an electronic signal of sufficient size to be processed by the electronic system. The amplification stage is based on three elements, focusing electrodes, dynodes and anode, which are metallic plates with a shape and position designed to optimize the collection and multiplication of electrons. A high voltage (HV) is applied to the PMT which is distributed between all these elements, including the photocathode, with the help of a voltage divider. A positive HV, grounded in the photocathode, is convenient for measuring PMT currents, and a negative HV, grounded in the anode, gives a faster response. The electronic

CHAPTER 3. DESIGN PRINCIPLES AND COMPONENTS OF TRITIUM

scheme of the electron multiplication stage (with negative supply HV) of Hamamatsu is shown in Figure 3.9.




Figure 3.9 – Hamamatsu commercial voltage divider electronic circuit with negative (up) and positive (below) supply high voltage [K.K19].

Focusing electrodes guide the photoelectrons to the first dynode. They have a collection efficiency (CE) defined as the ratio of the number of photoelectrons reaching the first dynode and leaving the photocathode. The value of the CE depends on the bias voltage and, normally, it has a maximum of 80%. The dynodes produce the electron multiplication. A voltage difference between adjacent dynodes accelerates the electrons and produce their multiplication. The multiplication factor of each dynode, δ , is usually around 5 and depends on the HV.

3.2. TRITIUM DETECTOR

If all dynodes have the same gain, the overall gain of a PMT with N dynodes is given by [Kno99]:

$$G_{PMT} = CE \cdot \delta^N \quad (3.10)$$

and is of the order of 10^6 , strongly dependent on the applied HV.

The multiplication stage adds an uncertainty to the measurement. Working without gain allows us to count the number of photons that reach the PMT. This can be done by short-circuiting all the dynodes and the anode and collecting the signal directly from the first dynode. This special multiplication stage, shown in Figure 3.10, was used for fiber characterization.




Figure 3.10 – Electronic scheme of the voltage divider circuit used for working with PMTs without internal gain).

The output pulse of a PMT has a width of the order of tens of nanoseconds. The multiplication process can be described as a Poisson statistical process. For each electron in the first dynode, G_{PMT} new electrons are created with a variance of $\sqrt{G_{PMT}}$.

CHAPTER 3. DESIGN PRINCIPLES AND COMPONENTS OF TRITIUM

The output signal of a PMT is linear with the number of photons that reach its sensitive part up to a saturation limit, at which the linearity is lost. This limit depends on the PMT characteristics.

The photocathode may emit electrons in absence of any scintillation light. This signal, called dark current, I_{DC} , can arise due to thermoionic emission. For the PMTs employed in this work, this value is around 2 nA according to their data sheet.

Silicon Photomultiplier Array (SiPMs array)

The Silicon Photomultiplier (SiPM), also called Multi-Pixel Photon Counter (MPPC), is a kind of photosensor based on semiconductor materials, developed in the last two decades. SiPMs are replacing progressively conventional PMTs in many experiments and applications. They have outstanding photon counting capabilities at the single photon level with higher photo-detection efficiency than PMT and they have similar gain. SiPMs have, in addition, several advantages as insensitiveness to magnetic fields, low operating voltage, compactness (they may have down to 1 mm²) and ruggedness. The only drawback with respect to the PMTs is their high dark count rate (between 100 kHz and 1 MHz).

SiPMs are formed by a matrix of Avalanche Photodiodes (APDs) connected in parallel and operating in Geiger mode. APDs, the scheme of which is shown in Figure 3.11, are based on p-n junctions⁴ made with special techniques to achieve a good contact between both surfaces.

The voltage at which the SiPM starts operating in Geiger mode is called the breakdown voltage, V_{BD} . At lower voltages, SiPMs work in proportional mode in which the signal of each APD is proportional to the

⁴A p-n junction is a junction of a p+ and n+ layer, which are a tetravalent material doped with a trivalent or pentavalent material respectively, creating sublevels in the forbidden energy gap.

3.2. TRITIUM DETECTOR




Figure 3.11 – Scheme of a APD and electrical symbol used [OSI].

energy deposited but their gain is lower than in Geiger mode. The experimental measurement of the breakdown voltage, described in section 4.2, is an important measurement to characterize a SiPM, since properties of SiPMs, as the gain, depend on the overvoltage, V_{OV} . The overvoltage is the voltage applied to the SiPM above its breakdown voltage and this is expressed as:

$$V_{bias} = V_{BD} + V_{OV} \quad (3.11)$$

These APDs, called pixels when they are part of a SiPM, are connected in parallel and the output signal of the SiPM is the sum of all of them. If the photon flux is low enough, each SiPM pixel detects only one photon and its output signal is similar compared to other pixels of the same SiPM, regardless of the energy deposited, with some difference because of the uncertainty due to the SiPM manufacturing process and the statistical nature of photoelectron production. Therefore, the charge of the output signal when n pixels are simultaneously fired is n times the charge of a single pixel, as can be checked in Figure 3.12. Due to this property, the number of detected photons is linearly proportional to the value of the output signal

area. In addition, as the detected photons are proportional to the incident photons when the SiPM are working in the linearity range, after an accurate calibration of SiPM gain, described in section 4.2, the linearity of the SiPM output signal versus the number of incident photons and, therefore, the deposited energy of tritium events, is recovered.




Figure 3.12 – SiPM output pulses displayed on oscilloscope, model MSO44X from Tektronix [Tek21]. Several height pulses are observed, associated to a different number of SiPM pixels fired at the same time. The persistence function of the oscilloscope is used.

If the photon flux is high (typically several thousands of photons per event) more than one photon will impinge on the same pixel, but the output signal would be that of one only detected photon. This effect, known as saturation, produces a loss of linearity of the output signal. However, this effect is not important for the TRITIUM detector since its scintillating signals are far from producing so many photons.

Different sizes of the SiPM pixel can be chosen⁵. For the same

⁵Pixel sizes for commercial SiPMs are 25, 50 or 75μm [Div16a], [Div16b], [Div16c]

3.2. TRITIUM DETECTOR

active area of the SiPM, the smaller pixels allow the SiPM to have more pixels, which implies a higher dynamic range, at the cost of reducing its quantum efficiency. As the TRITIUM detector signals have few photons, the SiPMs used have the largest pixel size as we are far from the limit of dynamic range and quantum efficiency is a critical parameter for tritium detection.

The SiPM can be modeled as an electric circuit, shown in figure 3.13a, in which, due to the charge distribution in the depletion zone, a capacitance is induced by the SiPM. This is schematized as a reverse biased diode in parallel with a capacitor of capacitance C_d , as shown in Figure 3.13a. When the pixel detects a photon, the capacitor is discharged, creating an output current (electronic pulse).

In addition, each pixel of a SiPM has a quenching resistance⁶ in serie, R_q , that stops the avalanche current produced when this pixel is fired, creating a time limited electronic pulse. When the discharge is produced, a current flows through the resistance, reducing the reverse voltage seen by the diode below the breakdown voltage. Then, the current that flows through the diode is stopped and the voltage within the diode is reset to the bias voltage. This pixel is ready to detect a new photon again. This behaviour is schematically shown in Figure 3.13b.

The recovery of the bias voltage within the SiPM pixel after photon detection is characteristic of a RC circuit, described by the equation:

$$V_{bias}(t) = V(t_0) \left(1 - e^{-t/\tau}\right) \quad (3.12)$$

where τ is the recovery time constant of the system, given by $\tau = C_d \times R_q$. In section 4.2 the capacitance C_d and the quenching resistance R_q are measured and the recovery time constant extrapolated from both.

⁶The tipical value of this quenching resistance for commercial SiPMs is around 500 kΩ




Figure 3.13 – (a) Electronic scheme of a SiPM and (b) output current of a SiPM as a function of the reverse voltage. As shown, the quenching is an essential working mechanism of SiPMs [Sen17].

SiPM gain (typically of the order of 10^6) is defined as the number of charges produced when a single pixel is fired. This can be measured from the SiPM Single Photon Spectrum (SPS), which is the spectrum obtained when the SiPM output signal is integrated (charge) and histogrammed. The experimental measurement of the SPS and the calculation of the gain is presented in section 4.2. It has to be taken into account that the SiPM gain is highly dependent on temperature, which cannot be controlled with sufficient sensitivity (less than 1°C) in the final location of the TRITIUM monitor. Therefore, a gain stabilization method was implemented to compensate for the temperature effect. This method is detailed in section 4.2.

An important parameter for the SiPM used in the TRITIUM project is the photon detection efficiency, PDE. This is defined as the probability of recording the electrical pulse produced by a photon that hit the SiPM. The PDE of a SiPM consists of a product of three different parameters, the fill factor (FF), which is the ratio between the active area of the SiPM and its total area, the quantum efficiency (QE), which is the probability of producing a photoelectron when a photon hits the SiPM and the probability

3.2. TRITIUM DETECTOR

that the generated electron or hole produces an avalanche, P_{av} .

$$PDE = FF \times QE \times P_{av} \quad (3.13)$$

Likewise PMTs, SiPMs produce pulses that are unrelated with any incident photon, called the dark current. The pulse rate of these events is called dark current rate and it depends on temperature. At temperatures around 25°C, these pulses are mainly produced by the thermal generation, i.e., when the temperature produce a thermal energy allowing electrons from the valence band to overcome the forbidden band and go up to the conduction band. The dark current signal is identical to the signal produced by a single photon, so they cannot be discriminated. Therefore, it is very important to determine the magnitude of the dark current in the tritium signal from the detector.

Electrons contained in an avalanche of a SiPM pixel emit secondary optical photons⁷. These optical photons can reach other pixels, producing new avalanches. This effect, called optical cross-talk, produces photoelectrons that add to those truly induced by incident photons, and hence leads to an overestimation of the number of photons detected. The probability of producing an optical crosstalk event depends on the number of electrons produced in the avalanche (gain) and, therefore, on the temperature and the overvoltage. This probability at the overvoltage recommended at 25°C by the manufacturer is typically less than 10%.

The PDE, dark count rate and crosstalk are not measured yet since a different setup, shown in reference [Yah13], is needed. These parameters will be measured for the SiPM model used in the final version of TRITIUM monitor.

⁷Around 20 secondary optical photons are emitted in each SiPM output pulse with gains of the order of 10^6 [Spi97]

CHAPTER 3. DESIGN PRINCIPLES AND COMPONENTS OF TRITIUM

Due to imperfections existing in the cristal lattice of a SiPM, called traps, an electron of an avalanche can be captured and released after a characteristic time, τ_a . If this characteristic time is longer than the pixel recovery time, typically 3τ , this electron can trigger a new avalanche which will be seen as a new event. These events, called afterpulses, are often emitted around $1 \mu\text{s}$ after the photon-incident pulses. The afterpulse probability was not measured since it is not relevant for the TRITIUM project. The reason is that the TRITIUM detector makes time coincidences using 10 ns time windows. At this level, the afterpulse probability is negligible since it normally happens $1 \mu\text{s}$ after the SiPM output pulse.

The initial SiPM candidate for TRITIUM project and the one which was characterized is the model S13360-1375 from Hamamatsu Photonics [HAM16] because this model has interesting characteristics and properties, shown in Table 3.3. This model was mainly chosen due to its large pixel size, $75 \mu\text{m}$, which implies a high PDE and a high gain, both important parameters for the TRITIUM project due to the low activity to be detected and to the small signals produced by tritium events. High PDE and high gain are achieved at the cost of reducing the dinamic range, which is not an issue due to the small photon signals expected from tritium events in the scintillating fibers.

These parameters quoted in Table 3.3, are typical values provided by the manufacturer, Hamamatsu photonics. They can vary significantly from one SiPM to another of the same model. Thus, it is convenient and sometimes necessary to measure them. Some of these measurements for TRITIUM are reported in section 4.2.

This SiPM was also chosen because, as it can be observed in Figure 3.14, its maximum PDE is reached at $\lambda_{p,SiPM} = 450 \text{ nm}$, which is very close to the peak of the emission spectrum of the scintillating fibers used, $\lambda_{p,fiber} = 435 \text{ nm}$.

3.2. TRITIUM DETECTOR

Parameter	S13360-1375	S13360-6075
Series	S13360	S13360
Model	1375	16075
Pixel Pitch (μm)	75	75
Effective photosensitive area (mm^2)	1.3×1.3	6.0×6.0
Number of pixels	285	6400
Fill factor	82%	82%
Refractive index of windows material	1.55	1.55
Operating temperature range ($^\circ\text{C}$)	$[-20, 60]$	$[-20, 60]$
Spectral response range, λ (nm)	[320, 900]	[320, 900]
Peak sensitivity wavelength, λ_p (nm)	450	450
PhotoDetection Efficiency, PDE, $\lambda = \lambda_p$ (%)	50	50
Dark counts, Typical/Maximum (kcps)	90/270	2000/6000
Terminal capacitance, C_t (pF)	60	1280
Gain, M,	$4 \cdot 10^6$	$4 \cdot 10^6$
Breakdown Voltage, V_{BD} (V)	50.97	53
Cross talk probability(%)	7	7
Temperature coefficient ΔTV_{op} (mV/ $^\circ\text{C}$)	54	54

Table 3.3: Characteristics of SiPM S13360-1375 and S13360-6075 from Hamamatsu Photonics [HAM16].




Figure 3.14 – Photon detection efficiency (PDE) spectrum for SiPM S13360-**75 models [HAM16].

3.2. TRITIUM DETECTOR

This SiPM was later replaced by the model S13360-6075 from Hamamatsu Photonics [Div16c], whose properties are also listed in Table 3.3. The only difference between both models is their larger active area ($6 \times 6 \text{ mm}^2$), which is the largest active area of commercial SiPMs of Hamamatsu, that allows to read more scintillating fibers. This improvement is achieved at the price of a higher dark count rate (typically 2 Mcps). Finally, arrays of this SiPM model are commercially available and were chosen for the TRITIUM detector prototypes built at IFIC.

Although TRITIUM detector uses SiPM matrices, the characterization has been carried out at the level of a single SiPM to learn about the values of the SiPM parameters and to test the gain control method.

Photosensors in TRITIUM

There exist two different proposals for the photosensors employed in the TRITIUM monitor, PMTs and SiPM arrays. Each type of photosensor has advantages and disadvantages and must be experimentally tested to ensure the most suitable option. PMTs are used in the TRITIUM prototypes developed by Aveiro experimental group while SiPM arrays are used in the TRITIUM prototypes developed at IFIC, in Valencia.

PMTs with and without gain have also been used in Valencia to perform various laboratory measurements such as R&D studies with fibers, characterization of the active veto and test measurements of the TRITIUM prototypes developed.

The IFIC experimental group of TRITIUM has chosen the SiPM matrix option for the TRITIUM photosensor option for its advantages over PMTs, which are compactness and robustness, necessary to work for several years without supervision, its larger efficiency for the detection of photons in the visible range, critical parameter for the TRITIUM monitor, and its

economic price, which are cheaper than PMTs not only the photosensor itself, but also the electronic system necessary to feed them and process and analyze their output signal. However, the SiPM arrays have a higher dark count rate compared to the PMTs, which is a relevant disadvantage for the purpose of TRITIUM monitor since low activities of tritium are intended to be measured.

3.2.4 Electronic Readout

The electronic system is in charge of collect, processing and stores the output signals of photosensors (raw data) that have to be further analized. This electronic system depends on the type of output information and on the detector configuration used.

This section details the electronic readout used for the TRITIUM detector when SiPM arrays are used (PETsys). This section also shows the electron systems used for the laboratory characterization tests and I&D, in which a single SiPMs and one or several PMTs was used.

It is important to note that the electronic systems used for laboratory testing will not be used to read the TRITIUM detector in the final location, Arrocampo dam. For this task, as there are two different porposals, two electronic systems are used; the PETsys system are used when the TRITIUM detector use SiPM arrays and an especific electronic system has been developed, designed and tested by Aveiro experimental group is used to read the TRITIUM detector when PMTs are employed. This electronic system is explained in Appendix D.

3.2. TRITIUM DETECTOR

Electronics for PMTs

PMTs were used in TRITIUM experiment for two main objectives. On the one hand, to determine the amount of incident photons that reach the PMT photocathode, which is important to characterize fibers, and, on the other hand, to measure the energy of events, which allows us to discriminate events according to their origin, obtaining an energy spectrum of tritium events in water from laboratory prototypes.

To know the amount of photons that reach the photocathode, as explained above, the PMT should work without internal gain since it introduces a large uncertainty in the measurement. For that end, the homemade electron multiplication stage of Figure 3.10 is employed.

As the electrons are not multiplied, the output pulse of the photosensor is very small (currents of the order of tens of nanoamperes) and a special readout system is needed. The chosen system is Keithley 6487 Pi-coammeter/Voltage Source [KEI], a commercial system from Keithley. This system has some useful options such as automatic baseline correction, the ability to read currents of the order of picoamperes and the possibility of carrying out mathematical operation on the signal, such as the average of N measurements with the associated statistical error, where N is programmable by the user ($N = 100$ in all our studies).

To determine the energy of the events, the gain of the PMT has to be restored by removing the short-circuit of the electron multiplication stage. The number of PMTs used simultaneously was one, two or four, depending on the setup. A simplified scheme of the electronic chain employed in each case is shown in Figures 3.15a, 3.15b and 3.15c, based on various NIM modules⁸.

⁸The Nuclear Instrumentation Module (NIM) is a standard specification convention for electrical and mechanical parameters defined in electronic modules used in experimental nuclear and particle physics.




Figure 3.15 – Schemes of the different electronic for measuring with PMTs.
 a) Employed when only one PMT is used. b) Employed when two PMTs are used in time coincidence. c) Employed when four PMTs are used in time coincidence.

3.2. TRITIUM DETECTOR

The PMTs were biased in all the cases by TC 952 High Voltage Supply from Tennelec [Cam], which has four channels. If two or more configurations are needed, a second voltage supply HV Power Supply N 1130-4 from Wenzel Elektronik company [Wen] with 4 additional channels, was employed. As it can be seen in the figures, there are two different lines followed by the PMT output signals, the amplification line, used to create an energy spectrum, and the time coincidence line, used to make time coincidences. Therefore, an analogic FAN IN-OUT module was used to duplicate the input signal. The module employed was the Quad linear FAN IN-OUT MODEL 740 from Philips Scintific [Phi], which has four channels. One output signal was used as the input for the amplification part and the second output was used as input for the time coincidence electronics.

1. The amplification line, which is the same for the three configurations, provides the energy information and is based on two steps;
 - (a) The output signal is integrated by a preamplifier, which gives an output signal with a height proportional to the charge of the input pulse. This signal has a long tail⁹ produced by the preamplifier capacitance. The preamplifier used was "MODEL 9326 FAST PREAMP" from ORTEC [ORTd].
 - (b) The output signal from the preamplifier is lead to the amplifier which gives a gaussian shaped output signal. The amplifier modules were 575A and 671 from ORTEC [ORTb, ORTc]. An example of the output signal for 575A module is shown in Figure 3.17, green color.
2. The time coincidence line contains the time information and gives the gate that triggers coincident signals of both PMTs. This line consists of the following branches,

⁹The length of the tail is, $\tau = RC$, where R is the input resistance and C is the capacitance used. It is the typical output signal in RC circuits.

- (a) The output signal of the FAN IN-OUT module of each PMT is introduced into a discriminator module that gives a logic signal of -1.2 V height and of 240 ns width when a given threshold is exceeded. The discriminators employed are Octuple Constant-Fraction Discriminator CF8000 module from ORTEC [ORTe] and 4 channels discriminator model 84 from CAEN [CAE91].
- (b) Time coincidences are required to ensure that detected events come from the scintillating fibers and to remove external light and dark current. The two logic signals given by the discriminator from the two PMTs that read a detector are introduced in a coincidence module which generates an output signal of -1.4 V height and of 20 ns width, when both inputs are in time coincidence. The modules used were Coincidence Unit Model 465 from LeCroy [LeC] and Coincidence Type N6234 from CERN-NP [CERa].
- (c) Time coincidence of two different detectors (4 PMTs, configuration 3.15c) was also studied, which is useful to remove background due to hard cosmic radiation. To do so, a coincidence step similar to the previous one must be applied. The two single detector coincidence signal are checked for coincidence.

Some examples are shown in Figure 3.16 for time coincidences of two detectors (4 PMTs). There, four logical signals are shown, two of them (channel one and two, yellow and green respectively) come from two PMTs reading the first detector and the other two signals (channels three and four, color orange and violet respectively) come from PMTs reading the second detector.

- i. In Figure 3.16a only one PMT (channel two) detected an event. It means that the event is likely not produced in the scintillator. In this case, no output signal is generated.
- ii. In Figures 3.16b and 3.16c two PMT signals of one of the detectors are generated but the other detector gives no signal.

3.2. TRITIUM DETECTOR




Figure 3.16 – Different possibilities when time coincidences with PMTs are done. a) Event detected in only one PMT, one detector. b) Event detected in two PMTs, one detector. c) Event detected in two PMTs, other detector. d) Event detected in all PMTs, both detector.

This event is discarded.

- iii. In Figure 3.16d the four signals are generated and, consequently, the output signal is generated and the event is recorded.
 - (d) The logical output signal, is introduced in the Gate and Delay Generator, model 416A of the company ORTEC [ORTa], which gives a positive logical signal, called time windows, shown in Figure 3.17, orange color, with a height of 8 V and width of $2 \mu\text{s}$. This module is used to delay the time windows until it overlaps with the energy signal as it is shown in Figure 3.17, orange signal.

As a final output of the electronics, a logical and analogical signals are obtained, shown in Figure 3.17, which are recorded by the MCA 8000D,

Pocket MCA from AMPTEK [Amp]. The analogical signal has information about the energy of the event and this is the signal which information is saved for later analysis. The logic signal (output from the Gate and Delay Generator module) indicates when the amplified signal must be saved.



Figure 3.17 – Signal amplified and logical gate (input signals of MCA).

Electronical system for SiPMs

The SiPMs in the TRITIUM experiment are arranged in matrices of 4×4 . The electronic system chosen to process and analyze the output signals of the SiPM arrays is PETsys [PET], displayed in Figure 3.18, which is a commercial system prepared to work with SiPM matrices from Hamamatsu. PETsys provides time and energy digitalization, including the charge integrations QDCs¹⁰ and TDCs¹¹, resulting in a complete acquisition and digitization system capable of working with up to 1024 SiPM. This system

¹⁰charge-to-digital converter

¹¹time-to-digital converter

3.2. TRITIUM DETECTOR

consists of a basic board to which 16 different SiPM matrices can be connected with up to 64 SiPM per matrix. This number of channels is needed in the TRITIUM project because, as shown in section 5.4, the TRITIUM monitor consists of a large number of SiPM matrices with 16 channels per matrix.



Figure 3.18 – Different parts of PETsys system [PET].

Although the capacity provided by PETsys should be enough for the requirements of the TRITIUM project, TRITIUM is a modular detector with scalable sensitivity. This means that, if an improvement of TRITIUM limits is needed to improve its sensitivity or to further reduce the background, more photosensors would be needed. Therefore, the electronics should be able to increase its capacity in a scalable way. This requirement is fulfilled by PETsys since it has an additional module, called Clock and Trigger, to which up to sixteen different PETsys basic boards can be connected. These sixteen PETsys basic boards are read in parallel, giving a

total system capacity of reading 256 SiPM matrices (16384 SiPMs¹²).

PETsys software is based on C++ and Python scripts to drive the main tasks required, such as time coincidence options between SiPM (or even SiPM matrices) or energy discrimination. This software is open source, giving the possibility to modify the current scripts or to develop others with additional functions. PETsys has a time resolution better than 30 ps which is one of the best time resolutions of commercial systems available and its price is around 10€/ channel, which is cheaper than similar electronic systems.

As reported in section 4.2, the SiPM matrix temperature is an important parameter. The PETsys system has the ability to monitor the temperature of the SiPM matrices and ASICS employed to control them. Temperature monitoring is important to ensure the correct functioning of both photosensors and system. PETsys has the possibility of developing new scripts to implement the stabilization method of the SiPM gain reported in section 4.2.


Some characterization measurements were carried out using the PETsys system to ensure that the system works properly but the SiPM characterization was carried out at the level of a single channel (individual SiPM). The reason is that the output information of PETsys is already integrated and digitized, so it does not allow the SiPM to be calibrated. Therefore, to characterize a SiPM, a different electronic system was used to read up to eight different SiPMs. This system consists of a PCB that provides the SiPM bias voltage and reads the SiPM output signal. An example of the electronic scheme (provided by Hamamatsu) in which this PCB is based is shown in Figure 3.19.

The PCB was feed at ± 6 V using the voltage source ISOTECH, model IPS-4303 [IT] and the SiPM was feed using the electrometer KETH-

¹² $1024 \cdot 16 = 16384$



(a)



(b)

Figure 3.19 – a) Electronic board used to provide the SiPM bias voltage and to read the SiPM output signal. **b)** Electronical scheme in which this PCB is based.

LEY, model 6517B [Keh], that achieves a resolution of 1 mV, low enough to ensure that this voltage variations does not affect the SiPM gain. The output signal of this PCB is connected to an oscilloscope, model WwaveRunner 625Zi from TELEDYNE LECROY [TEL17] that records the data which were subsequently analized by ROOT¹³ scripts.

3.3 Water Purification System

3.3.1 Objectives

The water samples, which will be introduced into the TRITIUM detector to be measured, are taken directly from the Tajus river, 4 km downstream from the place where the Almaraz Nuclear Power Plant releases the cooling water. This sample, as it was verified by a detailed analysis shown in section

¹³ROOT is a framework for data processing, based on C ++ and object-oriented technology, developed at CERN and widely used in nuclear and particle physics.

CHAPTER 3. DESIGN PRINCIPLES AND COMPONENTS OF TRITIUM

4.3, contains many dissolved elements such as minerals, organic deposits, and living matter dissolved in the water. These dissolved items need to be deleted for several reasons:

1. The mean free path of tritium electrons in water is around $5 \mu\text{m}$ and even less in solid materials like organic material. Tritium decay electrons have to reach the fiber to be detected and, consequently, the detector must be kept very clean. If the analyzed water sample contains particles that may be deposited on the fibers, a layer of matter could be formed, preventing tritium decay electrons from reaching the fibers and reducing drastically the tritium detection efficiency.
2. The tritium monitor does not have any spectrometric capabilities that could be used to distinguish tritium from other radioactive elements from minerals dissolved in the water.

The water purification system was designed to remove organic matter and mineral particles with a size of up to $1 \mu\text{m}$. Hence, this filtering should keep unchanged the tritium level in the water.

3.3.2 Design of the Water Purification System

The requirements of the water purification system are:

1. A high degree of purification of the water sample extracted from the dam, reducing its conductivity by approximately two orders of magnitude (from $1000 \mu\text{S}/\text{cm}$ to $10 \mu\text{S}/\text{cm}$).
2. Low maintenance cost and manpower.
3. Software-based management of the system.

3.3. WATER PURIFICATION SYSTEM

The LARUEX laboratory in Extremadura, one of the six members of the TRITIUM collaboration, has designed, developed and built the water purification system, the scheme of which is shown in Figure 3.20.




Figure 3.20 – Scheme of water purification system of TRITIUM.

This system is installed in the Arrocampo dam and consists of four different stages:

1. The raw water from the Tagus river passes through two different filters, the first made of silex-anthracite and the second of garnet, with which a rough filtering is made (the largest particles are eliminated). This system has two identical parallel lines and implements a self-cleaning functions which consist of injecting purified water in the opposite direction.
2. The outlet water sample of the first stage, called fine filtration stage, passes through a $20\ \mu\text{m}$ filter (formed by a synthetic mesh) and activated charcoal filters (one per line) that removes chlorine and iron particles present in the water sample.

3. The outlet water of the second stage passes through a super-fine filtering consisting of a $1 \mu\text{m}$ filter, formed of a dense polypropylene mesh and UV lamps. The filter removes all the particles up to diameters of $1 \mu\text{m}$ and UV lamps sterilize water, eliminating bacteria and microscopic life.
4. Finally, the water is introduced in the last stage, double-phase reverse osmosis, that reduces the conductivity of the water to about $10 \mu\text{S}/\text{cm}$ with only one module of reverse osmosis, enough for the needed conditions.

As a result of the purification process, besides the pure water that is introduced into the TRITIUM detector, a rejection water is produced, which contains the particles extracted from the pure water that results in conductivities greater than the original water.

The water purification system is able to process up to $0.850 \text{ m}^3/\text{h}$ with a single line operating or $1.480 \text{ m}^3/\text{h}$ with both, greatly outperforming the requirements of the tritium detector.

The software used for remote controlling the water purification system is Siemens Programmable Logic Controller (Siemens PLC), that gives information such as the state of the valves, the reading of pressure probes and the amount of water production in real time.

The appendix B contains several pictures of different parts of this system, installed in Arrocampo dam.

3.4 Background Rejection System

The aim of the background rejection system is to reduce the radioactive and cosmic background that affects to the TRITIUM monitor. The TRITIUM

3.4. BACKGROUND REJECTION SYSTEM

project follows the ALARA principle for the tritium activity measurement, that is, to measure tritium activity "as low as reasonably achievable". The detection limit of tritium activity is set by the uncertainty in the activity of the background of the natural radioactivity measured by the TRITIUM detector, since tritium activities with differences from the background below this uncertainty cannot be identified. Therefore, the background uncertainty must be reduced as much as possible. The total uncertainty is the quadratic sum of all the different uncertainties related to the measurement, i.e., the statistical uncertainty¹⁴, σ_{st} , the systematic uncertainty¹⁵, σ_{si} , etc. Because of the Poissonian nature of the process, the statistical uncertainty is given by the square root of the measured activity, A_m , which can be reduced by minimizing detected background events.

$$\sigma_T^2 = \sigma_{st}^2 + \sigma_{si}^2; \quad \sigma_{st;bak} = \sqrt{A_{m;bak}} \quad (3.14)$$

The background rejection system of the TRITIUM monitor reduces the background activity measured by the TRITIUM detector, minimizing the statistical component of the background uncertainty.

The background of TRITIUM has two different sources. On the one hand, radioactive elements that are present in the crust of the Earth, mainly ^{40}K and elements from the four different natural radioactive series, shown in Table 3.4. On the other hand, the cosmic ray radiation. The primary cosmic radiation, of extra-terrestrial origin, is composed of high-energy particles, mainly protons and α particles, which interact with the Earth's atmosphere and generate a shower mainly composed by muons, electrons, photons and neutrons.

Cosmic radiation depends on several parameters like the longitude, latitude, and the solar activity cycle. The spatial distribution of cosmic rays,

¹⁴Uncertainty due to the statistical nature of the radioactivity process

¹⁵uncertainty due to the manufacturing process of the detectors

CHAPTER 3. DESIGN PRINCIPLES AND COMPONENTS OF TRITIUM

Mass Num.	Series	Primary	Half life (y)	Final
4n	Thorium	^{232}Th	$1.41 \cdot 10^{10}$	^{208}Pb
4n+1	Neptunium	^{237}Np	$2.14 \cdot 10^6$	^{209}Pb
4n+2	Uranium-Radium	^{238}U	$4.51 \cdot 10^9$	^{206}Pb
4n+3	Uranium-Actinium	^{235}U	$7.18 \cdot 10^8$	^{204}Pb

Table 3.4: Classification of natural radioactive series [The96, Eva95]. The information displayed for each radioactive series is the multiplicity of the mass number, the name of the series, the primary and final element, and the half-life of the primary element.

mainly muons, follows a $\cos^2(\theta)$ distribution with the zenith angle.

Two different techniques are employed for background suppression:

1. The soft background component, with energy below 200 MeV, is stopped by a lead castle, described in section 3.4.1,
2. The hard background component, with energy greater than 200 MeV, is much more difficult to stop and the technique employed is the use of a cosmic veto in anti-coincidence with the TRITIUM detector, reported in section 3.4.2.

3.4.1 Passive Shield (Lead)

The soft background component is suppressed by a lead shield inside which the TRITIUM detector is placed. This lead shield is efficient for suppression of particles with energies below 200 MeV/nucleon, that originates from the Earth's natural radioactivity and the soft component of cosmic radiation. This lead shield consists of 158 lead bricks of 25 mm thickness and low intrinsic radioactivity. The bricks are chevron shaped, as shown in Figure 3.21a, specially designed for a perfect fit and easy assembly. As can be seen

3.4. BACKGROUND REJECTION SYSTEM

in Figures 3.21b and 3.21c, these lead bricks are arranged in two layers with a total thickness of 50 mm. The junction of the inner layer lead bricks is shielded by a lead brick of the outer layer to avoid any leak of radiation.




Figure 3.21 – a) Lead Bricks b) and c) Two layers for the lead bricks of the shield.

A special aluminum structure, shown in Figure 3.22, was designed by mechanical engineering department of CENBG to support the total weight of 2.4 tons of the lead bricks.

The internal room of the lead shield is divided in two parts, as exhibited in Figure 3.22. The larger one has internal dimensions of $90.5 \times 41 \times 51$ cm³ and is used to place the TRITIUM detector. The smaller one, of dimensions of $33 \times 41 \times 51$ cm³, contains the Data Acquisition (DAQ) system of the detector. The external dimensions of the lead shield are $148 \times 60 \times 70$ cm³; its total weight is 2.5 tons.

3.4.2 Active Shield (Cosmic Veto)

As hard radiation cannot be stopped by a moderate lead thickness, cosmic vetos are employed, which consist of at least two complementary detectors in coincidence that reject events simultaneously detected in both of them.

CHAPTER 3. DESIGN PRINCIPLES AND COMPONENTS OF TRITIUM




Figure 3.22 – a) Scheme of the aluminium structure of the shield; b) The lead shield partially mounted.

As shown in Figure 3.23, the two complementary detectors are placed one above and the other below the TRITIUM detector. The distance between both detectors, 34.2 cm for the latest prototype developed at IFIC, is set by the dimension of the detector to be placed inside.




Figure 3.23 – Cosmic veto and Tritium-IFIC-2 prototype in an aluminum mechanical structure developed at IFIC.

A hard cosmic event crossing simultaneously both cosmic detectors is schematically sketched in figure 3.24a. Each cosmic detector has two photosensors, so the electronic configuration given in Figure 3.15c is used

3.4. BACKGROUND REJECTION SYSTEM

to make time coincidences. The TRITIUM detector is read out in anti-coincidence with the cosmic veto to reject the hard cosmic events from the tritium measurement. The expected hard cosmic rate at sea level for muons is $7 \times 10^{-3} \text{ cm}^{-2}\text{s}^{-1}\text{sr}^{-1}$ [ea20, SAG12], as shown in the plot of Figure 3.25. As time coincidences are triggered by logical gates of about 10 ns, the probability of recording two different hard cosmic events in temporal coincidence, one in each detector, as drawn in Figure 3.24b, are negligible.




Figure 3.24 – Hard cosmic events detected with the cosmic veto of TRITIUM: a) Real coincidence event, b) randomly coincidence event that may mimic a hard cosmic event.

The vetos are made of a plastic scintillator block from Epic-Crystal [Epi20]. Its properties are given in Table 3.5 and its energy emission spectrum is displayed in Figure 3.26.

The energy spectrum has a peak very close to that of the scintillating fibers used, so the same photosensors are used to read them out.




Figure 3.25 – Hard cosmic muon rate at different depths with respect to the sea level (10^0) [Szu15].

The dimensions of the scintillator blocks are $45 \times 171 \text{ cm}^2$ with a thickness of 1 cm. They are wrapped by three different layers, PTFE sheets, aluminum and black tape, as shown in Figure 3.27. These layers prevent external photons from reaching the plastic scintillator and prevent photons generated by the scintillator from escaping before reaching the photosensor. Two $2.5 \times 2.5 \text{ cm}^2$ windows are made on the wrapping to allow coupling of the photosensors.

Considering the expected hard cosmic rate of $7 \times 10^{-3} \text{ cm}^{-2}\text{s}^{-1}\text{sr}^{-1}$ at sea level, and taking into account that the solid angle of the veto detectors is $\omega = 0.5434$, calculated by integrating the solid angle of one scintillator on the other, and that the area of the veto is 765 cm^2 , the expected hard cosmic rate on the TRITIUM cosmic vetos is 2.909 event/s. This estimation is used in section 4.4 to determine the detection efficiency of the cosmic veto.

3.4. BACKGROUND REJECTION SYSTEM

Property	Value
Base material	Polystyrene
Growth method	Polymeric
Density (g/cm ³)	1.05
Refractive index	1.58
Soften temperature (°)	75-80
Light output (Anthracene)	50-60%
H/C ratio	1.1
Emission peak (nm)	415 (Blue)
Decay Time, (ns)	2.4
Hygroscopic	No

Table 3.5: Properties of plastic scintillators from Epic-Crystals used for the cosmic vetos [Epi20].




Figure 3.26 – Emission energy spectrum of the plastic scintillator from Epic-Crystals used for the cosmic vetos [Epi20].




Figure 3.27 – Different layers used to wrap the cosmic veto detectors. a) Scintillator without coating. b) PTFE coating. c) Aluminium coating. d) Black tape coating.

3.4. BACKGROUND REJECTION SYSTEM

Chapter 4

TRITIUM Monitor R&D

The characterization of the different parts of the TRITIUM monitor, including scintillating fibers, SiPMs, the water purification system and the background rejection system, are described in this chapter. This characterization is crucial to understand the behaviour of the different parts and the measurements results of the monitor. Furthermore, several developments were made to improve fundamental parameters of the TRITIUM monitor components to enhance its sensitivity to low levels of tritium in water.

4.1 R&D for the Scintillating Fibers

Experimental measurements of the plastic scintillating fiber parameters relevant for tritium detection, such as collection efficiency and the systematic uncertainty, are reported in this section. These parameters are involved in the measured tritium activity. Thousands of scintillating fibers are used in the TRITIUM detector which were prepared and conditioned prior to characterization studies or tritium detection. Various mechanical and electronic devices were developed to automatically prepare large number of fibers sim-

ultaneously.

4.1.1 Surface-Conditioning Method of Scintillating Fiber.

Different methods of surface-conditioning of scintillating fibers were used for the TRITIUM detector. These are methods of cleaving, polishing and cleaning the scintillting fibers.

Cleaving Method of Scintillating Fibers.

The first step in TRITIUM design was to choose the fiber length for a given fiber diameter (1 or 2 mm) at which the signal of tritium events is optimized. On the one hand, long fibers are suitable because fewer fibers are needed to achieve the same TRITIUM detector efficiency as short fibers, reducing the price of the TRITIUM detector since fewer electronic channels are needed. On the other hand, in long fibers, scintillating photons are reflected on the fiber boundaries many times before reaching the photosensors, which may produce a deterioration in the tritium signal. To determine the optimal fiber length, several simulations, described in section 6.2.3, were carried out using Geant4 [GEA], a particle and nuclear physics simulation package based on C++. It was concluded that the optimal fiber length for mesuring tritium in water is around 20 cm, which is the fiber length used in TRITIUM prototypes developed at IFIC and it is also the length used for most of the characterization studies carried out in TRITIUM. As our Saint-Gobain fibers are longer than 20 cm, an effective cleaving technique had to be developed with strict requirements on the cleaving quality of the fiber ends since this greatly affects the transmission of photons and, consequently, the detection efficiency of the TRITIUM detector. The cleave must be done perpendicular to the fiber axis and with small uncertainty in the cleaving position, in order to achieve a good end-surface quality that enables optimal




Figure 4.1 – Unsuccessful results of using commercial techniques for cleaving the scintillating fibers a) Fiber end deformation b) Fiber end cracks. Pictures taken with the microscope PB 4161 from EUROMEX.

coupling to the photosensor. It is also important that the fiber integrity be preserved, without cracks or deformations that contribute to the loss of photons.

Cleaving the plastic fibers is a current challenge. There are many different techniques such as milling, laser cleaving, focused-ion-beam, blade cleaving, etc. The blade cleaving technique was chosen for TRITIUM because of its mechanical simplicity and because it preserves the integrity of plastic fibers. Many commercial devices based on blade cleaving, such as the one provided by Thorlabs with a diamond tipped blade [Tho06], or others similar to guillotine designed for industrial fiber optics [Ind], were tested in an extensive study with unsuccessful results [Alb17]. As it can be seen in Figures 4.1, commercial techniques produce deformations, cracks and imperfections so they do not fulfill the quality standard required for the detector.

Because commercial devices are not suitable for polymer fibers, a cleaving device, shown in Figure 4.2, was designed, built and tested at IFIC

4.1. R&D FOR THE SCINTILLATING FIBERS




Figure 4.2 – Plastic fiber cleaver developed in TRITIUM experiment.

laoratory.

This device consists of an aluminium plate with fourteen grooves used for lodging the fibers and a thin razor blade, attached to a mobile piece, which is used to cleave them. The perpendicular cleave, which is one of the requirements, can be ensured since the moving piece, to which the blade is attached, is set perpendicular to the fiber axis. The blade used is a typical commercial razor blade, of 0.1 mm thickness, which is the thickness that gave the best results. The blade was positioned with a 5° inclination with respect to the horizontal axis since it was found in several studies that this helps to obtain a less aggressive and cleaner cleave [SR15, Law06]. As it can be seen in Figure 4.3, the integrity of the fiber is preserved since this is not deformed and a perpendicular cut is achieved when the plastic fiber cleaver is used. It can be noticed some tears in the clad. Although it does not affect the tritium project since uncladded fibers are used, it was verified under the microscope that it only occurs at the end of the fiber. It is verified in section 4.1.2 that these tears in the fiber cladding practically do not affect the photon collection of the fiber.

An additional parameter that could affect the cleaving quality of the fiber ends is the temperature of both fiber and blade. A study was carried out in which both were subject to different temperatures from room temperature to 110 degrees. No significant conclusions were obtained [Alb17]. Thus, the cleaving process was carried out at room temperature to

make the cleaving process easier.




Figure 4.3 – Fiber end after cleaving process using the home-made cleaver. Pictures taken with the microscope PB 4161 from EUROMEX.

A second L-shaped aluminium plate with grooves was attached to the first one (see Figure 4.2) to set precisely the length of the fibers to 200 mm, with an uncertainty of ± 1 mm.

Polishing Method of Scintillating Fibers.

As can be seen in Figure 4.3, a slightly darkened zone at the bottom of the fiber is observed in most of the cases. This is an unavoidable effect of the cleaving process on plastic fibers, which generates non polished end-surfaces. To remove that, a polishing process implemented by Thorlabs was applied [Tho06].

Manual Polishing Method.

4.1. R&D FOR THE SCINTILLATING FIBERS

The Thorlabs polishing method, shown in Figure 4.4, consists on a kit based on a special fiber connector from Thorlabs which is used for rubbing the fibers with five different polishing papers made out of aluminum oxyde grains, with a decreasing grain size, $30\ \mu\text{m}$, $20\ \mu\text{m}$, $12\ \mu\text{m}$, $5\ \mu\text{m}$ and $0.3\ \mu\text{m}$, describing on the paper a shape of an 8 during 2 minutes (approximately 120 movements).




Figure 4.4 – Manual polishing method implemented by Thorlabs.

The result obtained after polishing is shown in Figure 4.5b, where it can be noted that the darkened zone has completely disappeared and the fiber end is uniformly transmitting light, which favors optimal coupling of the scintillating fibers to the photodetectors and transmission of scintilating photons.

Automatic Polishing Machine.

The main drawback of the manual polishing method is that it takes more than 10 minutes to polish each fiber, an unaffordable time to polish




Figure 4.5 – Result of the polishing process. a) Fiber end after cleaving b) Fiber end after cleaving and manual polishing with Thorlabs technique. Pictures taken with the microscope PB 4161 from EUROMEX.

thousands of fibers needed for the TRITIUM detector (see section 5.4). This is why an automated polishing process has been developed within this thesis work. The goal of this effort was to ensure a better light coupling and transmission of light of the scintillating fibers to the photosensors.

A machine was designed, built and tested in the laboratory for automatically polishing of up to one hundred plastic scintillating fibers at the same time and it is easily scalable to larger number of fibers.

This automatic polishing machine, displayed in Figure 4.6, consists of two main parts: 1) A polishing table, where the fibers are polished 2) The electronics, based on Arduino technology, that operates the movement of the polishing paper:

1. The polishing table, shown in Figure 4.7a, is composed of two parts, a static part, where the fibers are fixed, and a movable part on bottom of the previous one, where the polishing papers are fixed. It was decided to establish the polishing movement on the plate with the polishing

4.1. R&D FOR THE SCINTILLATING FIBERS




Figure 4.6 – Polishing machine developed for TRITIUM.

sheets, because of its lighter weight and in order to avoid possible damaging movements to the fibers.

The static part (the fiber holder plate), shown in Figure 4.7a, consists of a plastic piece built with a 3D printer and locked to the system by four vertical screws. There are two nuts on each screw used to set the relative height and the inclination of fibers relative to the polishing papers. This piece contains one hundred holes in which a hundred fibers are lodged.

As the fibers are too light (0.16 g) to make by gravity the necessary pressure on the polishing paper, a plastic belt and a piece of metal with a weight of about 1.5 g were attached to the individual fibers, as shown in Figure 4.7b, to increase their contact pressure, in a similar way as with the manual polishing connectors.

The movable part of the polishing table consists of a flat PMMA plate of $18 \times 18 \text{ cm}^2$ to which the polishing paper is attached. This




Figure 4.7 – Components of the fiber polishing machine. a) Polishing table. b) Fiber with ballast metal piece. c) Horizontal screws and PMMA plate. d) A movement switch with its cables inserted inside its holding piece.

part is locked to structure [IGU] that contains two horizontal screws, perpendicular to each other, which allow its movement in the XY plane (horizontal plane), as shown in Figure 4.7c.

The polishing system contains several subminiature switches with high repeat accuracy, model DB1 6A250, mounted on a piece made with a 3D printer, shown in Figures 4.7a, 4.7c and 4.7d, which are used to find the origin of coordinates when the system is reinitiated and to stop the movable part when the end of the path is reached.

2. The electronics, shown in Figure 4.8, which controls the automatic

4.1. R&D FOR THE SCINTILLATING FIBERS

movement of the polishing paper, is based on Arduino technology. It consists of two stepper motors controlled by an Arduino UNO [ARD] that uses a CNC shield [OSO17] in which two different drivers are connected to control each of this stepper motors.

The stepper motor is a type of DC motor in which a full rotation is divided into a number of equal steps. This, it is manufactured with a number of steps per revolution, corresponding to a given stepping angle. The stepper motor used for the polishing machine are model NEMA ST4209S1404-A [Nan06], with bipolar voltage of 2.77 V_{DC} , 1.33 A maximum current and a stepping angle of 0.9° (400 steps/rev). They can be operated with or without a position sensor for feedback control. These stepper motors are used to move the horizontal screws on which the PMMA plate that hold the polishing paper is attached.

Drivers are controllers that allow to manage stepper motors in a simple and safe way as they are used to limit the current supplied to the motors. Choosing the right controllers, with the power and the stepping mode required for the chosen stepper motors, is crucial. This is because overpowering them could rapidly be damaging, while an inadequate stepping would result in inaccurate movements of the mobile part of the polishing paper.

Several drivers were successively considered and tested: the most widely used driver Pololu A4988 [All11] (35 V , 2 A and 16 steps), the driver DRV8825 (45 V , 2.5 A and 32 steps) and the TMC2208 [Int19] (35 V , 2.5 A and 256 steps) with more microstepping modes, which results in more accurate and smooth movements. This later includes a StealthChop function with which the driver operates in silence mode for low motor velocities. It is seen that the power provided by each stepper is enough to correctly move the stepper motors. Therefore, owing to these features, the TMC2208 driver is the one used for the control of the stepper motors since it produces the most accurate and smooth movement. The provided current to the motors is limited by

the driver and the excess will be transformed into heat that has to be dissipated for the correct functioning of the drivers.

Indeed, overheating of the drivers may cause loss of steps, producing wrong movements or even destroying the driver. Therefore, a cooling system is needed to ensure the correct operation of the polishing system. The cooling system, shown in Figure 4.8, consists of a copper heat sink¹ in contact with both controllers and a fan, used to prevent heat accumulation inside the electronics box. The cooling power can be improved by using a PELTIER cell.




Figure 4.8 – Electronic system of Polishing machine.

Finally, this polishing machine is controlled by a Raspberry Pi computer board [Ras] using the Universal G-code Sender software, a graphical

¹The copper is one of the best thermal conductor at STP




Figure 4.9 – Setup used to test the effect of the fiber polishing on light transmission to the PMTs. This setup is placed in a dark test box for the measurements.

interface based on the GRBL package [GRB]. There are several useful functions loaded in this way. I pre-programmed functions such as "HOME" with which the system, using the switches, finds its origin of coordinate every time the system is turned on. The software also has the possibility of loading a file containing the G-code to be executed. In the fiber polishing machine, the 120 movements required for each polishing paper.

Experimental Test.

Finally, this machine was tested with twenty uncladded scintillating fibers of 15 cm length. These fibers were arranged in a bundle and were coupled at each end to two PMTs, as shown in Figure 4.9, which were read out in coincidence. The electronic scheme shown in Figure 3.15b was used to process and analyze these signals and an energy spectrum was obtained. The goal of the test was to quantify the improvement in the relative light transmission of the scintillating fibers due to the polishing process.




Figure 4.10 – Energy spectra recorded with polished and unpolished fibers for the background of the natural radioactivity.

This experiment was carried out inside a special light-tight box, called black box, to ensure that the detected photons are generated by the scintillating fibers. The background was measured before and after applying the polishing process, shown in Figure 4.10.

As it can be seen in this figure, the energy spectrum after applying the polishing process is shifted to the right, which means that the detected events have more energy than before the polishing process (more photons per event reach the PMTs). In addition, this improvement in the photon collection efficiency of the scintillating fibers allows more events to be detected, which can be quantified by a parameter F defined as,

$$F = \frac{A_P - A_{NP}}{A_{NP}} \quad (4.1)$$

where A_P and A_{NP} are the integrals of the energy spectrum measured after and before the polishing process, respectively. An improvement of detected events of almost a factor two was achieved with respect to the measurement

4.1. R&D FOR THE SCINTILLATING FIBERS

made before polishing.

These test were repited using two radioactive sources, an encapsulated ^{60}Co source with gamma emissions of 1173.2 keV and 1332.5 keV and an activity of 715 Bq, and a ^{90}Sr beta source with a maximum beta energy of 545.9 keV and an activity of 17.8 kBq. The radioactive sources were placed next to the fiber bundle, in the middle of it (at 7.5 cm from each PMT) and the energy spectra was recorded for both radioactive sources, which are shown in Figure 4.11.

Again, it can be appreciated that both energy spectra are shifted to the right after polishing, obtaining an improvement of almost a factor two with respect to the spectra before polishing.

In summary, with the polishing machine, the photon collection efficiency of the fibers was improved (mainly due to the improvement of the interface between fibers and PMTs). It is very important to achieve a high detection efficiency as the expected number of photons per tritium event is quite low, less than 20 as it has been demonstrated with simulations and experimental measurements.

Cleaning Method of Scintillating Fibers.

The tritium events only produce tens of photons in the scintillating fibers, so it is very important to detect as many photons as possible. As it is demonstrated in the light collection characterization of scintillating fibers, subsection 4.1.2, the quality of the interface between the core of uncladded fibers and the environment (tritiated water in the case of TRITIUM detector) affects conspicuously the photon collection efficiency. To improve the quality of the interface, a fiber cleaning process was implemented, aiming to remove external particles deposited on the fibers, such as dust and fat that worsen the photon collection efficiency. Through this cleaning process,




Figure 4.11 – Energy spectra recorded with polished and unpolished fibers.
a) for the ^{60}Co source b) for the ^{90}Sr source

4.1. R&D FOR THE SCINTILLATING FIBERS

the wetting property of the fibers is improved, that is to say the capacity of its surface to attract water, as illustrated in Figure 4.12. This implies an increase of the contact surface between the fibers and water, which prevents air molecules from attaching to them, and produces a uniform water clad around them.




Figure 4.12 – Schematic representation of the wetting properties of a flat surface (gray) in contact with a drop of liquid (blue). The wetting property is characterized by the angle formed between the surface of both objects. The smaller angle, the better wetting property of the material. [San]

This cleaning process was developed and carried out in the clean room of ICMOL laboratory². Three different glass beakers were used, one filled with alkaline soap, another with pure water (conductivity of the order of $10 \mu\text{S}/\text{cm}$) and the third with isopropanol. The fibers are first rubbed with gloved hands with alcalin soap during 5 minutes, then placed in the first beaker which is placed in an ultrasonic bath at 17 kHz frequency during 3 minutes. Then, the fibers are cleaned with a constant flow of water during 5 minutes and they are placed in the second beaker for ultrasonic bath during 3 minutes and then placed in the third beaker for ultrasonic bath during another 3 minutes. Finally the fibers are dried with a flow of gas N_2 and kept in clean conditions until their introduction into the module vessel of TRITIUM detector.

²ICMOL, *Instituto de Ciencia Molecular*, is a research institute located in the *Parc Científic* of the University of Valencia.

The improvement in the light collection of the scintillation fibers after this cleaning process was measured using a bundle of twenty unclad- ded fibers of 15 cm length that have undergone this cleaning process. This bundle of fibers was arranged in the setup described in Figure 4.9 and the energy spectra were measured, before and after cleaning the fibers. Similar to the polishing machine test, this measurements was done first for the background, Figure 4.13, and then using two radioactive sources; a ^{90}Sr beta source, already used in the polishing machine test, and an encapsulated ^{137}Cs source with gamma emissions of 661.7 keV and an activity of 500 Bq activity, Figures 4.14. A higher gain was used in this case to optimize the number of channels used of the MCA (the digital multichannel analyzer). A shift of the spectrum to higher energies is observed in all the cases for the clean fibers, with respect to the spectra obtained before cleaning, showing an improvement in photon collection efficiency of the fibers. A similar equation to 4.1 was used quantify the improvement achieved with the cleaning process. Although no improvement in the detected events was observed for the background measurement, an improvement of about 26% and 35% was obtained for ^{90}Sr and ^{137}Cs respectively.






Figure 4.13 – Energy spectra of the background before and after the cleaning process.

4.1. R&D FOR THE SCINTILLATING FIBERS



(a)



(b)

Figure 4.14 – Energy spectra obtained before and after the cleaning process using a radioactive source of a) ^{137}Cs and b) ^{90}Sr .

4.1.2 Light Collection Characterization of BCF-12 Scintillating Fibers

The characterization of uncladded BCF-12 fibers from Saint-Gobain, which are the fibers selected for the TRITIUM experiment is described in this section. These fibers are compared to single clad and multiclaid BCF-12 fibers to quantify the influence of the clad in the relevant parameters of the scintillating fibers. Although commercial clads are too thick for the TRITIUM experiment, a low thickness clad could be developed. For example, clads with a thickness of the order of tens of nanometers could be achieved by deposition by evaporation in vacuo.

The difference between these three types of fibers is that uncladded fibers only consist of a polystyrene core with a refractive index of 1.60, whereas single clad fibers have an acrylic clad (PMMA) of $30\ \mu\text{m}$ thickness and a refractive index of 1.49. Multiclad fibers have a second fluor-acrylic clad of $10\ \mu\text{m}$ thickness and a refractive index of 1.42. As it was explained in section 3.2.2, the clad affects the photon collection efficiency of the fiber and prevents the fiber core from being damaged due to harsh environments.

This characterization was carried out for single scintillating fibers and consists of a comparative study of the uncertainty in the fiber response that will affect the tritium measurement of the TRITIUM detector. In addition an estimation of the photon collection efficiency of the fibers types mentioned above was done. The magnitude considered for the characterization was the rate of photons reaching the active area of the photosensor with increasing light input at the entrance of the fiber. To measure this magnitude, a calibrated PMT (Hamamatsu R8520-06SEL) with 29.76% quantum efficiency (quantum efficiency average of the wavelength region of interest). The voltage divider circuit which whortcut the PMT dynodes (see section 3.2.3) was used to polarize the PMT and mesure its photocurrent using a Picoammeter (Keithley 6487 picoammeter/voltage source).

4.1. R&D FOR THE SCINTILLATING FIBERS

The photon rate reaching the photocathode is calculated from,

$$N^o \gamma / \text{sec} = \frac{(I_{PMT} - I_{DC})}{q_e \cdot QE \cdot CE} \quad (4.2)$$

where I_{PMT} is the output current of the PMT when it detects photons and I_{DC} is the dark current. This equation takes into account the quantum efficiency of the PMT, QE , which is 0.2976 por the PMT used, and the capture efficiency in the dynodes CE , equal to 1 since the signal is read directly from the photocathode. In addition, it is assumed that each detected photon only generates one electron, the charge of which is q_e .

A simplified scheme of the setup is shown in Figure 4.15.




Figure 4.15 – Setup used for fiber characterization.

This setup consists of a home-made optical board, on which a LED and a the PMT are placed precisely in front of each other at an appropriate distance. A LED (LED435-03 from Roithner LaserTechnik GmbH [Roi10]),

with an emission spectrum similar to that of the scintillating fibers, was used. The emission spectrum of the LED, given in Figure 4.16, was measured using a spectrometer and fitted to a Gaussian function. The LED emission peak is at 433.9 nm with a σ of 7.85 nm. The LED is feeded in current mode to achieve a linear dependence of the light emision on the current used to feed it. The fiber of 20 cm long was placed between the LED and the PMT, closely coupled to them at each of its end-surfaces, using optical grease [Sai]. Two collimators were used to ensure that only photons emitted from the LED were detected by the PMT. Two conectors (FH-ST³ connectors from RoHS company [|]) were used to fasten the fiber to the system.




Figure 4.16 – Emission spectrum measured in the laboratory for the LED model 435-03 from Roithner LaserTechnik GmbH Company.

Measurement Conditions.

Before characterizing a fiber several tasks had to be performed to check that the black box is light-tight enough and to check that the PMT response is linear in the studied range of photons intensities.

³FH-ST is a quick assembly connector for 1 mm diameter plastic optical fiber, POF

4.1. R&D FOR THE SCINTILLATING FIBERS

A light leak in the dark box would produce a background larger than the signal. To check the light-tightness of the dark box, the PMT dark current were measured before and after covering the setup using a special black blanket from Thorlabs [Thob], that prevents external photons from entering the system. No statistically significant differences were observed between covered and uncovered setup, which indicates the black box is sufficiently light tight.

The optimal voltage supply to the PMT was obtained by finding the voltage plateau at which the electron collection efficiency in the first dynode was practically 100% ($CE = 1$ in equation 4.2). In absence of fibers, the PMT output current was measured for different PMT supply voltages, between 0 and 500 V, first with the LED OFF (PMT dark current) and then with the LED feed at 1 mA. The number of photons detected by the PMT (difference between both spectra) is plotted in Figure 4.17. As it can be seen, the plateau starts at voltages higher than 150 V. The chosen voltage for the characterization was 250 V.




Figure 4.17 – PMT photocurrent as a function of the first dynode voltage. Error bars are included but they are too small to be visible.

Finally, the linear response of the PMT was verified. The LED was powered in current mode with intensities ranging from 0 to 10 mA, the linearity of which was previously tested in the laboratory. This was tested in the range of the number of photons expected for a tritium event (a few tens of photons per tritium event, which gives tens of photons per nanosecond) and in a broader range, around two thousand five hundred photons per nanosecond, interesting in the case of higher tritium activities. The linearity test was performed without fibers coupled to the PMT. Several collimators were used to reduce the amount of photons that reach the PMT. The results in low and high illumination cases are shown in Figures 4.18. As it can be seen, no saturation in the PMT response is observed.

Results of the Characterization of Scintillating Fibers

The tasks of cleaving and polishing the fibers add a small dispersion in the individual scintillating fiber response to the intrinsic dispersion from fabrication. This generates an uncertainty, σ_{sys-SF} , which is the contribution of the fibers to the total uncertainty in the tritium activity measured by the TRITIUM detector. The setup shown in Figure 4.15 was used to measure this uncertainty, in which has to be taken into account that the position of the connectors that lock the fiber in the experimental setup produces an additional systematic uncertainty, $\sigma_{sys-pos}$, in the measurement. Since both uncertainties are independent, the total systematic uncertainty is given by:

$$\sigma_{sys} = \sqrt{\sigma_{sys-SF}^2 + \sigma_{sys-pos}^2} \quad (4.3)$$

The uncertainty due to the fiber position has to be quantified to extract σ_{sys-SF}^2 from the total systematic uncertainty. Two different experiments were designed, the first giving only the systematic uncertainty ($\sigma_t = \sigma_{sys}$), and the second to obtain the total uncertainty. Then, σ_{sys-SF}^2 is given by,




Figure 4.18 – Number of photons measured by the PMT as a function of the polarization current of the LED. a) Response of the PMT in the intensity range of tritium events. b) Response of the PMT in the range 0 – 2500 photons/ns. Error bars are included but they are too small to be visible.

$$\sigma_{sys-SF} = \sqrt{\sigma_{sys}^2 - \sigma_{sys-pos}^2} \quad (4.4)$$

The test designed to measure $\sigma_{sys-pos}$ consisted in preparing one fiber of each type (uncladded, single clad and multiclad), all with 1 mm diameter and 20 cm length, using the conditioning process reported in section 4.1.1. Each fiber was locked in the setup, and measurements of the PMT photocurrent with a fixed LED intensity, polarized at 1 mA were made. These measurements were repeated ten times with a given fiber, removing and putting on the fiber each time. The mean, \bar{x} , and the standard deviation of the PMT photocurrent for each fiber type are shown in Table 4.1 where the relative standard deviation, $\sigma_{sys-pos}^{rel}$, defined by equation 4.5, is also included.

$$\sigma_{sys-pos}^{rel} = \frac{\sigma_{sys-pos}}{\bar{x}} \quad (4.5)$$

Fiber type	Mean (ph/ns)	$\sigma_{sys-pos}$ (ph/ns)	$\sigma_{sys-pos}^{rel}$ (%)
Uncladded	524.09 ± 0.01	17.65	3.37
Single Clad	1071.70 ± 0.01	9.07	0.85
Multiclad	949.93 ± 0.03	9.91	1.04

Table 4.1: Mean and standard deviation (due to the fiber position in the setup) of the number of photons per nanosecond that reach the PMT for 0.1 mA LED intensity.

As it can be noticed, the clad significantly improves the light collection efficiency of the fibers, showing larger signals for single clad fibers and multiclad fibers than for uncladded fibers. The reason could be that the interface between the core of the fiber and its clad is better controlled for single-clad and multi-clad fibers than for uncladded fibers, where the interface is provided by the environment (air or water in the case of TRITIUM). External conditions, as dirt, may produce noticeable interface fluctuations. Concerning the statistical error of the measurement, it is three orders of

4.1. R&D FOR THE SCINTILLATING FIBERS

magnitude smaller than the systematic uncertainties previously mentioned ($\sigma_{sys-pos}$ and σ_{sys-SF}) so it was negligible.

To determine the total uncertainty, ten different samples of each fiber type were prepared and each fiber was measured under the same conditions as above. This measurement was done for four different LED emission intensities (0.05, 0.1, 0.15 and 0.2 mA). The results for uncladded fibers are plotted in Figure 4.19, where it can be seen that, although each fiber shows a very linear trend with increasing LED emission intensity, a dispersion in the fiber response is clearly observed. Similar results were obtained for single clad and multiclad fibers, displayed in figures 4.20a and 4.20b, respectively.






Figure 4.19 – Number of photons/ns reaching the PMT for Uncladded fibers. Error bars are included but they are too small to be visible.

The average number of collected photons versus LED intensity and the relative standard deviation for each type of fiber are given in Tables 4.2 and 4.3 respectively, and are plotted in Figure 4.21, where they can be compared.



(a)



(b)

Figure 4.20 – Number of photons/ns reaching the PMT for ten samples.
 a) Single clad fibers, b) Multi-clad fibers. Error bars are included but they are too small to be visible.

4.1. R&D FOR THE SCINTILLATING FIBERS

Led Int. (mA)	Uncladded (ph/ns)	Single Clad (ph/ns)	MultiClad (ph/ns)
0.05	245 ± 11	384 ± 33	377 ± 15
0.1	572 ± 26	923 ± 74	871 ± 35
0.15	915 ± 39	1485 ± 120	1397 ± 55
0.2	1267 ± 55	2054 ± 166	1933 ± 76

Table 4.2: Number of collected photons per nanosecond versus LED intensity for the different type of fibers. The errors shown here are the standard deviation of the ten measured samples.

Led Int. (mA)	Uncladded (%)	Single Clad (%)	MultiClad (%)
0.05	4.38	8.66	3.97
0.1	4.59	8.02	3.97
0.15	4.34	8.07	3.95
0.2	4.36	8.10	3.93
Mean	4.42	8.21	3.96

Table 4.3: Relative standard deviation, σ_{sys}^{rel} (%), versus LED intensity for the different fiber types.

As it can be noticed in Figures 4.19 and 4.20, the fiber response is quite linear and single clad and multiclad fibers have stronger signals than uncladded fibers (a factor two in the case of single clad), which indicates, as already observed in Table 4.1, that the clad has a significant effect on the fiber collection efficiency. It can also be observed in Table 4.3 that the relative standard deviation, σ_{sys}^{rel} , does not vary with the LED intensity. The highest uncertainty was found for the single-clad fibers, despite of their higher light collection. This is most probably due to the cleaving process during which cracks in the clad may appear as it can be observed in Figure 4.3. As can be observed in Table 4.3, this damage seems to be reduced when a second clad is used, which enhances the mechanical resistance of the fiber.

An average of the three relative standard deviation quoted in this




Figure 4.21 – Average number of photons per ns versus LED current for 10 samples of each fiber type (uncladded, single clad and multi-clad fibers). Error bars are included but they are too small to be visible.

section, σ_{sys}^{rel} , $\sigma_{sys-pos}^{rel}$ and σ_{sys-SF}^{rel} , are given in Table 4.4. As it can be noticed, the smallest relative standard deviation was found for uncladded fibers, which means that the damage from this process occurs mainly in the fiber clad, as illustrated in Figure 4.5 where it can be seen the clad break due to the cleaving process. It was checked under microscope that this damage only occurs at the end of the fiber. Also, the largest relative standard deviation is obtained for single clad fibers, which indicates that the second clad increases the resistance of the fiber to the conditioning process.

Fiber type	σ_{sys}^{rel} (%)	$\sigma_{sys-pos}^{rel}$ (%)	σ_{sys-SF}^{rel} (%)
Uncladded	4.42	3.37	2.86
Single Clad	8.21	2.17	7.92
Multiclad	3.96	1.04	3.82

Table 4.4: Relative standard deviations (σ_{sys}^{rel} , $\sigma_{sys-pos}^{rel}$ and σ_{sys-SF}^{rel}) measured in this test.

In summary, the relative statistical deviation due to the fiber con-

4.1. R&D FOR THE SCINTILLATING FIBERS

ditioning process was quantified for the different fiber types. It was found that the use of a fiber cladding improves the efficiency of photon collection but at the cost of worsening the standard deviation. Larger uncertainties (a factor two) in the light collection was observed in single clad fibers compared to multiclads and uncladded ones. This may be due to the damage in the clad produced during the cleaving process of these fibers. Therefore, it was chosen not to use a clad for the fibers used in the TRITIUM detector.

Finally, the absolute photon collection efficiency in 10 cm of scintillating fibers, CE_{10} , was measured for each type of fiber. To measure it, ten different samples of 10 cm length were prepared for each fiber type and similar measurements of the photons collected were performed, which are summarized in Table 4.5.

Led Int. (mA)	Uncladded (γ/ns)	Single-clad (γ/ns)	Multi-clad (γ/ns)
0.05	318 ± 61	550 ± 71	480 ± 84
0.1	736 ± 143	1270 ± 164	1111 ± 193
0.15	1184 ± 232	1984 ± 231	1777 ± 307
0.2	1645 ± 324	2507 ± 208	2338 ± 350

Table 4.5: Number of the collected photons versus LED intensity for 10 different fibers of 10 cm length.

The collection efficiency of 10 cm fiber length, CE_{10} , was calculated by comparing these photons collected to those measured for a fiber length of 20 cm. It is quite similar to the expected value considering an exponential attenuation of the signal in length as follow [Leo94].

$$N_{ph}/\text{ns}(x) = N_{ph}/\text{ns}(x_0) \times e^{-(x-x_0)/L} \quad (4.6)$$

$$CE_{10} = \frac{N_{ph}/\text{ns}(20 \text{ cm})}{N_{ph}/\text{ns}(10 \text{ cm})} = e^{-10/L} = 96\% \quad (4.7)$$

where L is the absorption length provided by the manufacturer, $L = 270$ cm. A lower collection efficiency has been obtained compared to the expected value for each type of scintillating fiber. This is likely due to blemishes and dirt on the fiber surface and a less than perfect interface between the fiber and the PMT used.

Fiber type	CE_{10} (%)
UnCladded	76 ± 8
Single Clad	78 ± 6
Multiclad	83 ± 7

Table 4.6: Collection efficiencies CE_{10} .

4.2 Characterization of SiPM

The characterization of some of the most relevant parameter of the SiPM model Hamamatsu S13360-1375 are detailed in this section, which was the first choice for the TRITIUM monitor photosensor. The most relevant SiPM parameters are its breakdown voltage, V_{BD} , the gain of the SiPM and its dependences with the operating voltage and temperature, $G_{SiPM}(V_{bias}, T)$, and the temperature coefficient, e . Additional parameters were measured and used to verify the accuracy of the characterization such as the quenching resistance, R_q , the pixel capacitance, C_d , and the terminal capacitance, C_t . Other relevant parameters for the TRITIUM monitor are the PDE, which can affect to the minimum detectable activity, MDA, the dark count rate and the crosstalk probability, which can generate false counts interpreted as tritium counts by the TRITIUM detector. They were not measured since it was not possible with the current setup. It is expected to be measured for the S13360-6075 model, the latest proposal for the TRITIUM detector, where all the relevant parameters will be experimentaly determined using a different experimental setup, described in appendix A. The afterpulse

4.2. CHARACTERIZATION OF THE SiPM

probability was not measured since, as it is explained in seccion 3.2.3, its probability is negligible when time coincidence windows of 10 ns are used.


The SiPM characterization is carried out inside of a climatic chamber, model CCM 81 from DYCOMETAL [DYC]. This climatic chamber allows to control the temperature and humidity with a precision of 0.1°C and 0.1% respectively. In addition, this chamber is a Faraday cage. A special black blanket [Thob] was used to prevent external photons from reaching the SiPM.

First, the quenching resistance and the breakdown voltage of the SiPM were obtained from the measurement of the output current generated by the SiPM as a function of its bias voltage applied in forward and reverse direction, respectively. The output current of the SiPM was directly measured using the Keithley 6487 Picoammeter/Voltage Source [KEI]. The LabView sofware was used to take the data. The currents-voltage curves are shown in Figure 4.22.


As can be seen, when the bias voltage is applied in forward direction (Figure 4.22a) the output current of the SiPM does not flow until the potential difference between the n and p layers is reached, which is approximately $V_0 = 0.7$ V for silicon photosensors, close to the value experimentally obtained, $V_0 = 0.5$ V. When the current starts to flow, the intensity is linear with the applied voltage. The equivalent resistance, R_{eq} , was determined from,

$$I = \frac{1}{R_{eq}}V; \quad \frac{1}{R_{eq}} = \sum_{i=1}^N \frac{1}{R_{qi}} = \frac{N}{R_q} \quad (4.8)$$

and R_{iq} are the quenching resistance of each pixel of the SiPM in parallel which have the same value, R_q . A value of $R_q = 360.56 \pm 0.07$ kΩ was obtained from a linear fit to the data (Figure), which is in agreement with the typical values given by Hamamatsu.



(a)



(b)

Figure 4.22 – I-V curves measured for the SiPM model Hamamatsu S13360-1375 with the bias voltage applied in a) forward direction b) reverse direction. The measurements were taken at $T = 25^\circ\text{C}$ and humidity $H = 45\%$.

4.2. CHARACTERIZATION OF THE SiPM

The breakdown voltage, V_{BD} , was obtained from the reverse bias voltage plot (Figure 4.22b). This is the point at which the SiPM begins to operate in avalanche mode, which can be calculated from the maximum of the function

$$f = \frac{1}{I} \frac{dI}{dV} \quad (4.9)$$

The value obtained, $V_{BD} = 51.02$ V, is in agreement with the value provided by Hamamatsu, Table 3.3.

To measure the SiPM gain, G_{SiPM} , the electronic board described in section 3.2.4 with an amplification factor of $F_{amp} = 170$ was used. An incoherent light source, LED435-03 from Roithner LaserTechnik GmbH [Roi10], described in section 4.1.2, was used to illuminate the SiPM with a low enough flux of $\lambda = 435$ nm photons. The SiPM output signal shows various well-defined pulse heights, shown in Figure 4.23, corresponding to the number of pixels simultaneously fired. The single photon spectrum, SPS, is plotted in Figure 4.23. This spectrum was obtained by integrating and histogramming the SiPM output pulses with time window wide enough to contain the full charge of the pulse. The time window used in these measurements was $t_w = 500$ ns. The light source provides a trigger signal for the measurement, represented in green line in Figure 4.23.

The well-separated peaks in the SPS spectrum correspond to the charge produced by a different number of fired pixels. The first peak in the spectrum is the pedestal, which is the charge measured when no pixel is fired. This peak is caused by the electronic noise of the system. The second peak corresponds to one fired pixel and so on. The SiPM gain, G_{SiPM} , can be obtained from the SPS spectrum from the equation,

$$G = \frac{\overline{\Delta Q}(V \cdot s)}{F_{amp}(V/A) \times e^-(C)} \quad (4.10)$$

where e^- is the electron charge and $\overline{\Delta Q}$ is the average peak distance in the




Figure 4.23 – Above) Trigger signal (green) and SiPM output pulses (yellow). Below) SPS spectrum obtained by integrating and histogramming the SiPM output pulses. This measurement was done at 25°C , $V_{bias} = 53.98$ and humidity of $H = 60\%$.

SPS spectrum, corresponding to the charge released by a fired pixel.

To obtain the value of $\overline{\Delta Q}$ a macro was written in ROOT [CERb]. This macro finds and extract the background (the output signals of the SiPM different to the pedestal when it is not illuminated by a LED), which is crucial in some cases like high temperatures or high bias voltages since it can hide its peaks. After that, this macro find all peaks in the SPS spectrum and fits each one to a Gaussian function, shown in Figure 4.24a. The value and error of the charge produced by multiple fired pixels are obtained from the centroid and the sigma of the different fitted Gaussian functions. The obtained charges are fitted to the number of fired pixels, Figure 4.24b.

Up to 10 simultaneously fired pixels were obtained with a relative uncertainty of the charge measurement of less than 2%. The slope of the straight line in Figure 4.24b corresponds to $\overline{\Delta Q}$.

For the case studied, which corresponds to a temperature of 25° and a bias voltage of 53.96 V (overvoltage around 3 V), the value obtained for the SiPM gain is $G_{SiPM} = (4.11 \pm 0.04) \cdot 10^6$, very close to the value




Figure 4.24 – ROOT analysis performed to obtain the SiPM gain. a) Fit of the SPS spectrum to various Gaussian functions. b) Charge of successive number of pixels as a function of the number of pixels fired. Error bars are within point size. This experience was carried out at $T = 25^\circ\text{C}$, $V_{\text{bias}} = 53.98$ V and humidity of $H = 45\%$.

provided by Hamamatsu, Table 3.3.


A method for the SiPM gain stabilization against variations due to the temperature was implemented. This is necessary for the TRITIUM project since the temperature in the final location of the tritium detector cannot be controlled with the precision required to avoid variations of the SiPM gain. This method consists in compensating for variations in the SiPM gain, caused by variations of temperature, by controlled variations of the bias voltage. For this task, first, the dependence of the SiPM gain with the temperature and bias voltage was measured. The SiPM gain was measured at several temperatures from 15°C to 41°C in steps of 2°C, which is expected to be the temperature range in the final location. The bias voltage was $V_{bias} = V_{BD} + 3$. The SiPM gain was measured at several overvoltages from 1 V to 5 V in steps of 0.2 V. The temperature was $T = 25^\circ\text{C}$. Both measurements are shown in Figure 4.25.

As can be seen, an excellent linear trend is obtained for both cases. The parameters of the linear fit obtained are,


$$\begin{aligned} G_{SiPM} &= a \cdot T + b; & G_{SiPM} &= c \cdot V_{bias} + d \\ a &= (-82.53 \pm 1.59) \cdot 10^3; & c &= (137.72 \pm 1.50) \cdot 10^4 \\ b &= (617.65 \pm 4.53) \cdot 10^4; & d &= (-762.16 \pm 8.13) \cdot 10^5 \end{aligned}$$

In addition, the breakdown voltage, V_{BD} , and the terminal capacitance, C_t , can be obtained from the linear fit of the SiPM gain as a function of the bias voltage, V_{bias} . Both parameters can be obtained from the definition of the SiPM gain and taking into account that the charge produced in a pixel is proportional to the capacitance of the pixel and the difference voltage in the SiPM, V_{OV} ,

$$G_{SiPM} = \frac{Q_{pixel}}{e^-} = C_d \frac{V_{bias} - V_{BD}}{e^-} = c \cdot V_{bias} + d \quad (4.11)$$



(a)



(b)

Figure 4.25 – Dependence of the SiPM gain with the a) Temperature b) Bias voltage.

where C_d is the pixel capacitance.

From the linear fit obtained in Figure 4.25b, a value of $V_{BD} = 50.98 \pm 0.59$ V and $C_d = 220.63 \pm 2.41$ fF are obtained. The terminal capacitance of the SiPM can be calculated assuming all pixels in parallel, $C_t = N_p \times C_d = 62.88 \pm 0.69$ pF. Both magnitudes, the breakdown voltage and the terminal capacitance, are in agreement with the values provided by Hamamatsu, Table 3.3.

Finally, the value of the bias voltage to be applied to compensate for the variation in the SiPM gain due to a variation of the temperature can be obtained by applying variations to linear relations:

$$G_{SiPM} = a \cdot T + b \longrightarrow \partial G_{SiPM} = a \partial T$$

$$G_{SiPM} = c \cdot V_{bias} + d \longrightarrow \partial G_{SiPM} = c \partial V_{bias}$$

Therefore, the total variation of the SiPM gain, which is produced by the variation of both parameters, must be cancel:

$$\partial G_{SiPM,tot} = \partial G_{SiPM}(T) + \partial G_{SiPM}(V_{bias}) = 0$$

$$\partial G_{SiPM}(V_{bias}) = -\partial G_{SiPM}(T) \longrightarrow c \partial V_{bias} = -a \partial T$$

$$\partial V_{bias} = -\frac{a}{c} \partial T = e \partial T$$

where the parameter $e = 59.9 \pm 1.3$ mV/°C is the ratio of a and c and agrees with the value of the temperature coefficient provided by Hamamatsu, Table 3.3. Finally, integrating this expression, we obtain:

$$\int_{V_i}^{V_f} \partial V_{bias} = e \int_{T_i}^{T_f} \partial T \longrightarrow \Delta V_{bias} = e \Delta T \quad (4.12)$$

This equation gives the variation of the voltage ΔV_{bias} that keeps the SiPM gain when a variation in the temperature happens, ΔT . More useful is to know the bias voltage V_{bias} to be applied as a function of the temperature T . For this, it is necessary a reference case. In this case, the reference case

4.2. CHARACTERIZATION OF THE SiPM

considered is $V_i = V_{ref} = V_{BD} + 3$ V = 53.98 V and $T_i = T_{ref} = 24^\circ\text{C}$, at which the gain is $4.2 \cdot 10^6$ (experimentally determined). Thus, we get:

$$(V_{bias} - V_{ref}) = e(T - T_{ref})$$

$$V_{bias}(\text{V}) = 59.93 \cdot 10^{-3} \cdot T(\text{ }^\circ\text{C}) + 52.54 \quad (4.13)$$

Finally, this temperature through bias voltage compensation was tested. The temperature was varied from 21°C to 29°C and the bias voltage was modified according to the equation 4.13. The value of the SiPM gain obtained as a function of the temperature is shown in Figure 4.26.




Figure 4.26 – SiPM gain measured as a function of the temperature after implementation of the gain stabilization method.

A red dotted line is included, indicating the value of the SiPM gain to be kept. As it can be seen, the slope of the linear fit, parameter p_1 , is three orders less than the constant, parameter p_0 , so it can be depreciated and a constant dependence can be accepted. Furthermore, all measured points are in agreement with the initially value measured for the SiPM gain

(red line). Therefore it can be concluded that this method works to stabilize the gain of the SiPM when variations in the temperature happens.

4.3 Characterization of the Water Purification System

The characterization of the water purification system is described in this section. This system guarantees that the quality of the water sample fulfills the requirements of the TRITIUM detector. There are three different requirements that this water purification system must satisfy,

1. A quite low conductivity⁴ of the water, around $10 \mu\text{S}/\text{cm}$, to avoid that external particles dissolved in the water be deposited on the fibers, drastically reducing the detector efficiency.
2. The radioactive particles (other than tritium isotope) from the water sample should be removed because tritium cannot be separated from other radioactive isotopes.
3. The tritium activity should not be affected by the water purification process.

To verify that these requirements are fulfilled, a characterization of the water sample for both raw water and purified water, was done. This characterization consisted of measuring the water sample conductivity and the activity of the different radioactive element present in the sample. The turbidity and the chemical components of the water sample were also measured. The sample of the raw water was taken at 40 meters from the water

⁴Conductivity is the ability of a material to conduct electrical current. In liquids, conductivity is related to the presence of salts (presence of positive and negative ions)

4.3. CHARACTERIZATION OF THE WATER PURIFICATION SYSTEM

purification system and two meters deep in the river since it is the place where the samples used in TRITIUM monitor will be taken. Variations of up to 25% in the tritium activity was measured between both points (due to the diffusion of tritium along the river). The chemical composition of the water was measured by a physico-chemical analysis, shown in Table 4.7, before the purification process. The water sample contains a number of components, that must be removed to prevent their deposition on the scintillating fibers of the detector.

Chemical components	Concentration (mg/L)
CO ₃ H ⁻	154
Mg	46
Ca	105
NO ₃ ⁻	16
Cl ⁻	196
NO ₂ ⁻	0.03
K	11
Na	173
SO ₄ ⁻	217
Dry Residue	1029

Table 4.7: Chemical components measured in the raw water sample.

The water turbidity⁵ was measured using the Hanna Hi 9829 portable multiparameter system from Hanna Instruments [Han], obtaining a value of 29 NTU, much higher than the WHO recommended limit of 5 NTU for drinking water. The water conductivity was also measured for both raw and purified water, using the same system. The results of the conductivity measurements, together with the measurement of the rejected water, described in section 3.3.2, are presented in Table 4.8. As it can be seen in the first column, the raw water sample has high values of conductivity, due to its

⁵The turbidity of water is the loss of transparency due to dissolved particles, normally measured in Nephelometric Units of Turbidity, NTU, as the intensity of scattered light at 90 degrees.

content of ions, shown in Table 4.7. It can be noticed in the second column of the table that the conductivity of pure water was reduced by almost two orders of magnitude, to values close to $10 \mu\text{S}/\text{cm}$, fulfilling the requirement. In the third column, it can be remarked that the rejected water conductivity is higher than that of raw water, because this water contains the removed ions from the purified water.

Date	Raw ($\mu\text{S}/\text{cm}$)	Pure ($\mu\text{S}/\text{cm}$)	Reject ($\mu\text{S}/\text{cm}$)
1/8/18	970	11.85	1442
7/8/18	958	11.8	1632
14/8/18	966	12.04	1725
22/8/18	980	12.54	1702
28/8/18	987	9.9	1692
5/9/18	1009	12.02	1645

Table 4.8: Measurements of the conductivity for several samples of water.

The gamma radioactive elements present in both raw and purified water, were identified and their activities measured by a HPGe, high purity germanium detector. A gamma analysis was carried out to determine the emitters with long enough lifetime to be measured. The radioactive isotopes found in the raw water sample with measurable activities were ^{40}K and ^{226}Ra which were absent in the purified water.

The tritium activity was measured by liquid scintillation counting (LSC) to check if the purification process had modified it. The raw water was filtered at 0.45 microns to remove any particles that could cause the extinction of the scintillation signal. Table 4.9 show several measurements of the tritium activity for different water samples before and after purification. As seen in the table, tritium activity is not affected by the purification process.

Date	Raw (Bq/L)	Pure (Bq/L)
7/8/18	24 ± 3	26 ± 4
11/12/19	13.2 ± 2.1	13.85 ± 2.2
15/01/20	30.6 ± 4.2	30 ± 4

Table 4.9: Measurements of the tritium activity for several samples of both raw and purified water.

4.4 Characterization of the TRITIUM Cosmic Veto

The characterization of the active shield (cosmic veto), which was carried out using PMTs as photosensors, is reported in this section. Measurements of the cosmic veto using SiPM arrays has already started and their replacement will be as soon as possible.

The quality of the veto wrapping, shown in Figure 3.27, was checked. This study was done at the level of one detector so the configuration of the electronics is the one given in Figure 3.15b. The surface of the veto was divided in 9 parts, shown in Figure 4.27, in which a gamma source was placed.

Two different tests were made for this task:

1. The improvement of the veto signal due to wrapping. A ^{137}Cs source was placed at point 2 and a energy spectrum was measured with the veto before wrapping. Next, the measurement was repeated after wrapping. The spectra obtained are shown in Figure 4.28.

The spectrum of the wrapping veto is shifted to the right, which means that more photons (a factor two) are collected per event. No improvement was obtained in the number of events detected, only in the collection efficiency.




Figure 4.27 – Reference points used for veto mapping.

2. The spatial uniformity of the signal in the wrapped veto was evaluated. For this task, a mapping was carried out, which consisted of placing a ^{60}Co source at each point and measuring the number of events detected in the same time window. This test was done for two different veto modules and the energy spectrum obtained was integrated. The count rates obtained are plotted in Figure 4.29. It can be observed that the veto signal has a uniform response on its whole surface, giving a fairly similar counting rate in all the points measured.

Next, both vetos in time coincidence was studied, so the configuration of the used electronics was that of Figure 3.15c. The goal was to find the conditions in which the detection of cosmic events is optimized. This optimization consists of, on the one hand, finding the minimum high voltage of PMTs for which their efficiency is stable, and, on the other hand,




Figure 4.28 – Measurement of a radioactive source ^{137}Cs with the TRI-TIUM cosmic detector with and without wrapping.

finding the maximum threshold of the discriminator⁶ before starting to loss cosmic events. For higher voltages and a smaller thresholds, a plateau of the counting rate should be obtained.

The counting rate was measured for several high voltages at fixed threshold and for several thresholds at fixed high voltage, plotted in Figure 4.30. To find the optimal conditions, the amplification line of the electronics was eliminated and the output signal of the coincidence module was connected to a CAEN Quad Scaler And Preset Counter-Timer module, N. 1145, [CAE]. The counting rate was measured in a time window of 300 s. In Figure 4.30a, the counting rate at several high voltages for three different thresholds, 60 mV, 100 mV and 200 mV is plotted. As it can be observed, there is a minimum high voltage for each threshold, 700 V, 730 V and 780 V respectively, at which the plateau start. This minimum voltage is higher

⁶The threshold is the voltage value that the PMT output signals must exceed to contribute to the cosmic detection




Figure 4.29 – Bidimensional graph of the count rate (Mapping) measured with two different TRITIUM cosmic detectors using a radioactive source of ^{60}Co .


4.4. CHARACTERIZATION OF THE COSMIC VETO

when the value of the threshold increases, as it should. Analogously, the counting rate for several thresholds and fixed high voltage was measured for three different high voltages, 750 V, 800 V and 850 V, plotted in Figure 4.30b. There is a maximum threshold for every high voltage used, 140 mV, 270 mV and 450 mV respectively, at which the plateau ends. This maximum threshold increases with high voltage, as it should. The voltage chosen was 800 V since it is on the plateau for the three thresholds and the threshold chosen was 200 mV which is on the plateau for the selected high voltage.


With this setting, the energy spectrum of cosmic events was measured, shown in Figure 4.31.

As expected, this energy spectrum fits well to a Landau function. The cosmic ray rate determined from the area of this spectrum is 2.5 event/s. The expected cosmic rate, calculated in section 3.4.2, is 2.9 event/s, so the efficiency of the active veto developed in TRITIUM experiment for cosmic event detection is 85%, which is a usual value for the efficiency of plastic detectors to mips.

Finally the detected cosmic ray rate versus the distance between the two cosmic veto was obtained. The energy spectrum was measured for five different distances, namely 10 cm, 20 cm, 36 cm, 40 cm and 50 cm. The spectra are plotted in Figure 4.32a. The energy spectrum in Figure 4.31 was also included. As it is expected, the counting rate decreases with the distance but the spectrum shape remains the same. The integrated spectra as a function of distance, plotted in Figure 4.32b, was fitted to a second degree polynomial which allows to estimate the cosmic rate for a given veto distance.



(a)



(b)

Figure 4.30 – Counting rate a) as a function of high voltage for fixed thresholds and b) as function of thresholds for fixed high voltage. in semi-logarithmic scale




Figure 4.31 – Energy spectrum measured with the cosmic veto.




Figure 4.32 – Measurement of the cosmic veto for several distances between the two scintillators. Above) Energy spectrum of the cosmic veto for several distance. Below) Fit of the cosmic veto rate versus distance to a second degree polynomial.

Chapter 5

TRITIUM Detector Prototypes

The different prototypes developed in the framework of the TRITIUM experiment are described in this chapter, which are so-called TRITIUM-IFIC-0, TRITIUM-IFIC-1, TRITIUM Aveiro and TRITIUM-IFIC-2, listed in chronological order of their construction. The first two prototypes built, TRITIUM-IFIC-0 and TRITIUM-IFIC-1, are preliminary prototypes used to learn about tritium detection and to improve the monitor design. The other two prototypes built, TRITIUM-Aveiro and TRITIUM-IFIC-2, are prototypes with an optimized design, based on the lessons learned from the former prototypes.

Each prototype was designed and built in the laboratories of IFIC or Aveiro and was filled with tritiated water following a method specially developed for this task. Several water tightness and filling tests were carried out for each prototype to guarantee its radiosecurity. The measurements obtained by the different prototypes during their installation in the laboratory are discussed in this chapter. The laboratories involved in the characterization of the prototypes are the IFIC in Valencia, the DRIM¹, in the

¹DRIM, Deteção da Radiação e Laboratorio Imagem Médica (Laboratory for Radiation Detection and Medical Imaging)

5.1. FIRST PROTOTYPES

University of Aveiro, and the LARUEX² in Extremadura. An additional section shows the measurements obtained at the Arrocampo dam, the TRITIUM monitor installation site, where the control of external atmospheric conditions is less accurate. At the end of the chapter, the final monitor of TRITIUM detector will be described. Its design is a modular structure for easy scalability, composed of the number of detector modules needed to reach the required sensitivity.

5.1 First IFIC prototypes

Two preliminary prototypes, TRITIUM-IFIC-0 and TRITIUM-IFIC-1, are reported in this section, which were designed, developed and built at the IFIC workshop. These prototypes were thought to be a small scale proof of concept of the final TRITIUM detector module. They helped to learn about tritium detection, to detect design problems and to implement improvements for the final prototype.

5.1.1 TRITIUM-IFIC-0

The TRITIUM-IFIC-0 prototype was the first prototype developed in the TRITIUM experiment to check the feasibility of the technology proposed by TRITIUM, that is, to verify that is using plastic scintillating fibers to detect tritium in water with good sensitivity.

As liquid radioactive sources were involved, a special attention was paid to radiation safety in the design of the first prototype.

TRITIUM-IFIC-0 consists of a bundle of 35 fibers, shown in Figure

²LARUEX, Laboratorio de Radiactividad Ambiental de la Universidad de Extremadura (Environmental Radioactivity Laboratory of the University of Extremadura)




Figure 5.1 – a) Metallic piece of the fiber bundle. b) and c) Bundle of 35 fibers, the length of which is 20 cm, used in TRITIUM-IFIC-0 prototype.

5.1, of 20 cm length, which were cleaved and polished with the techniques reported in section 4.1.1. This bundle has metallic pieces located in both ends, shown in Figure 5.1a for attaching it to the prototype vessel. The fiber bundle was placed inside of a vessel, made of PVC³ since it is a safe widely used material. This vessel, shown in Figure 5.2, was designed in a U-shape to improve the radiological safety, although this shape was not the most appropriate for tritium detection, as we learned afterwards. As can be seen in Figure 5.2, a frame of methacrylate and steel was designed and built to hold the prototype. Two calibrated Hamamatsu R8520-460 PMTs [K.K19] were optically coupled to the fiber bundle ends using optical grease [Sai]. The voltage divider circuit of these PMTs is shown in Figure 3.9. The high voltage was set to -800 V, at which the gain are $1.26 \cdot 10^6$ and $1.01 \cdot 10^6$, and the quantum efficiency 29.76% and 28.66%, respectively. The two PMTs were read out in coincidence mode, using the electronics circuit shown in Figure 3.15b.

³Polyvinyl Chloride, PVC

5.1. FIRST PROTOTYPES




Figure 5.2 – TRITIUM-IFIC-0 Prototype.

Two identical prototypes were built and filled following the same protocol. The first prototype, called “TRITIUM-IFIC-0 Background”, was filled with pure water (39 mL, uncertainty of 0.05%) and was used to measure the background of the detectors whereas the second prototype, called “TRITIUM-IFIC-0 Signal”, was filled with a radioactive liquid source of tritium, the preparation of which is reported in the appendix C. The specific activity of the liquid source employed was 99.696 kBq/L (uncertainty of 2.24%) and the volume used to fill this prototype was the same, 39 mL (uncertainty of 0.05%). This second prototype was used to measure the total signal (tritium + background) from the detector. The measured tritium activity was determined by subtracting the background from the signal.

The statistically significant number of time coincident events was found too weak to be measured by time coincidences. The loss of photons was caused by several reasons, such as an excessive curvature of the fiber bundle due to the U-shape of the PVC vessel, causing most of the photons




Figure 5.3 – a) Fiber bundle in PMMA vessel b) illumination test of the bundle to visualize the light loss due to the fiber curvature.

to escape from the fibers and the poor quality of the tritiated water-fiber interface (the cleaning process described in section 4.1.1 was motivated by this result).

A test was carried out to find an explanation to the absence of coincident events in the data. A transparent glass vessel was built similar to the TRITIUM-IFIC-0 prototype vessel, shown in Figure 5.3a, to study the effect of the fiber bundle curvature. The LED described in section 4.1.2 was used to verify the reduction in photocollection efficiency of the fiber bundle due to this curvature. As can be seen in Figure 5.3b, a large amount of photons introduced from one side of the bundle does not reach the other side due to the fiber curvature. This problem indicated the necessity to keep a straight fiber arrangement in the design of the next prototypes. Another important point that can explain the absence of coincident events is the flow of water through the fibers. The fiber bundle of this prototype is very compact and water may not be able to circulate properly around the fibers. This fact will be solved in the next prototype by using a matrix to keep the fibers at a necessary distance.

To overcome this problem and to obtain some data with this pro-

5.1. FIRST PROTOTYPES

totype, a single PMT measurement was taken using the electronic chain configuration shown in figure 3.15a. The energy spectra measured for both the signal and background prototypes, are shown in Figure 5.4a. The difference between signal and background, Figure 5.4b, corresponds to the energy spectrum of tritium. The counting rate obtained for the three spectra is given in Table 5.1, where the tritium counts are obtained by subtracting the background from the signal.

Spectrum	Counts/second
Signal prototype	2.27 ± 0.06
Background prototype	2.06 ± 0.06
Tritium counts	0.21 ± 0.085


Table 5.1: Contes per segon obtinguts per al prototip TRITIUM-IFIC-0.

The tritium detection efficiency obtained for this prototype is $(2.11 \pm 0.85) \cdot 10^{-3} \frac{\text{cps}}{\text{kBq/L}}$, was calculated as the ratio of the tritium counting rate to the specific activity of the tritium liquid source.


As we reported in section 2.1, the efficiency of scintillating detectors scales with the active area of the scintillator used. Therefore, to compare the efficiency with other detectors and with other prototypes developed in TRITIUM experiment, the specific efficiency of this prototype is calculated by normalizing to the scintillator area, which is

$$S = (9.59 \pm 3.88) \cdot 10^{-6} \frac{\text{cps}}{\text{kBq/L} \cdot \text{cm}^2}$$

As can be seen in Table 2.2, the specific efficiency is somewhat larger than that obtained by Muramatsu [Mur67], $3.13 \cdot 10^{-6} \frac{\text{cps}}{\text{kBq/L} \cdot \text{cm}^2}$, and similar than that obtained by Moghissi [Mog69], $< 10.6 \cdot 10^{-6} \frac{\text{cps}}{\text{kBq/L} \cdot \text{cm}^2}$, both detectors consisting of solid scintillators. These efficiencies are too low efficiencies to achieve the objective of being able to measure 100 Bq/L.



(a) .



(b)

Figure 5.4 – Energy spectra measured with TRITIUM-IFIC-0 prototype.
a) Signal and background energy spectra. b) Tritium energy spectrum.

5.1.2 TRITIUM-IFIC-1

The TRITIUM-IFIC-1 prototype was designed to overcome the problems and limitations found in TRITIUM-IFIC 0. The main improvements were:

1. The fiber bundle was arranged straight to optimize the photon collection efficiency of the fibers. In addition, a PTFE matrix was used to maintain a distance of 1 mm between fibers.
2. A special fiber cleaning method, described in section 4.1.1, was applied to the fibers to improve the quality of the interfaces between the fibers and tritiated water. This method produces a better wetting property of the fibers, which improves their photon collection efficiency.
3. A PTFE vessel was used to improve the collection of photons inside the prototype. Indeed, PTFE has a reflectivity close to 100% at the fiber scintillating wavelengths. Thus, the photons that escape from fibers and hit the vessel walls are reflected back to the scintillating fibers.

The TRITIUM-IFIC-1 prototype consists of 64 straight scintillating fibers of 20 cm length, arranged in an 8×8 PTFE squared matrix, as shown in Figure 5.5.

This structure is placed within a cylindrical PTFE vessel of 48 mm diameter and 200 mm length, shown in Figure 5.6.

The cleaning process described in section 4.1.1 was applied to the fibers to achieve a better tritiated water-fiber interface. A PVC piece was used to attach the photosensor to the prototype and prevent external light from being read out. A general view of this prototype is shown in Figure 5.7.




Figure 5.5 – PTFE structure used to arrange the fibers of TRITIUM-IFIC-1 prototype in a matrix of 8×8 .

The prototype was instrumented with a PMT model R8520-460, from Hamamatsu Photonics company [K.K19], coupled directly to the fiber bundle using optical grease [Sai]. The quantum efficiency of this PMT for the fiber scintillating wavelength is 28.66%. The voltage divider, shown in Figure 3.9, was used to polarize the PMT. The high voltage was -800 V. The signal from this PMT was acquired using the same electronics as for TRITIUM-IFIC-0 prototype, shown in Figure 3.15a. Unlike the first prototype, only one TRITIUM-IFIC-1 prototype was built. In a first measurement, this prototype was filled with pure water (118 mL, uncertainty of 0.05%) and several background measurements were taken over a week. Then, it was emptied and refilled with 118 mL (uncertainty of 0.05%) of a tritiated water source of the same specific activity as the one used for TRITIUM-IFIC-0 prototype, 99.696 kBq/L.

The measured signal and background energy spectra are shown in Figure 5.8a. The difference between both energy spectra corresponds to the tritium energy spectrum, shown in Figure 5.8b. The detection efficiency was obtained as in the previous section. The rates measured are given in Table 5.2, which are obtained from the integration of each spectrum.

5.1. FIRST PROTOTYPES



(a)



(b)

Figure 5.6 – PTFE vessel of TRITIUM-IFIC-1 prototype.

Spectrum	Counts/second
Signal prototype	7.82 ± 0.11
Background prototype	3.99 ± 0.08
Tritium counts	3.83 ± 0.13

Table 5.2: Counting rate obtained with the TRITIUM-IFIC-1 prototype.



Figure 5.7 – A general view of TRITIUM-IFIC-1 prototype.

The tritium detection efficiency obtained for TRITIUM-IFIC-1 is $(3.84 \pm 0.16) \cdot 10^{-2} \frac{\text{cps}}{\text{kBq/L}}$. The specific efficiency obtained is

$$S = (9.56 \pm 0.40) \cdot 10^{-5} \frac{\text{cps}}{\text{kBq/L} \cdot \text{cm}^2}$$

which is a factor ten better than that of TRITIUM-IFIC-0. Furthermore, compared to the scintillating detectors developed in other experiments for tritium in water measurements, given in table 2.2, the efficiency of this prototype is very close to the best result, obtained by Singh [Sin85, Rat00], $4,1 \cdot 10^{-2} \frac{\text{cps}}{\text{kBq/L}}$, and the specific efficiency, which is the most relevant parameter for comparison, is almost 5 times larger than that obtained by Hofstetter [Hof92b, Hof92c], $< 22.2 \cdot 10^{-6} \frac{\text{cps}}{\text{kBq/Lcm}^2}$.

5.1. FIRST PROTOTYPES




Figure 5.8 – Energy spectra measured with TRITIUM-IFIC-1 prototype.
a) Signal and background energy spectra. b) Tritium energy spectrum.

5.2 Latest TRITIUM Prototypes

The prototypes so-called TRITIUM-Aveiro and TRITIUM-IFIC-2 are reported in this section. In these prototypes, a different design was used compared to the previous ones (TRITIUM-IFIC-0 and TRITIUM-IFIC-1) so that they can safely allow the reading of a large number of fibers arranged in a straight mode with two photosensors operating in time coincidence. A better tritium detection efficiency was obtained in these prototypes through the use of a much larger number of scintillating fibers than in the preliminary prototypes, and the time-coincidences read out mode of the photosensors. Furthermore, the activity of the radioactive liquid source of tritium used to fill these prototypes was much lower than that used for the first prototypes, in order to measure their minimum detectable activity, MDA.

A similar design was used for the latest prototypes and subtle differences were included to check which ones optimize the tritium detection. The main differences between both prototypes are:

- The diameter of the scintillating fiber, 2 mm for TRITIUM-Aveiro and 1 mm for TRITIUM-IFIC 2. The use of a larger diameter facilitates the flow of water around the fibers, reducing problems related to surface tension and ensuring that the entire active volume of the fibers participates in tritium detection. In addition, a large radius increases the rigidity of the fiber, improving its robustness. However, this large radius decreases the signal-to-background ratio. The detector active volume for 2 mm fibers is smaller for the same volume than for 1 mm fibers and the internal volume of the fibers, unreachable by tritium decay electrons, is larger for 2 mm fibers, producing a higher background. As a result, a lower signal-to-background ratio is obtained.
- The scintillating fibers methods used to prepare the fibers before its use. The entire surface-conditioning method (section 4.1.1), consisting

5.2. LATEST TRITIUM PROTOTYPES

in the cutting, polishing and cleaning methods, are applied in the scintillating fibers used in the TRITIUM-IFIC-2 prototype. However, only the cutting method is applied to the scintillating fibers used in the TRITIUM-Aveiro prototype.

- Different photosensors, PMTs for TRITIUM-Aveiro and SiPM arrays for TRITIUM-IFIC-2. Although most of the current development with TRITIUM-IFIC-2 was made with PMTs, the final purpose is to use SiPM arrays with which larger photodetection efficiencies than PMTs with a similar price can be achieved. In addition, no high voltage is needed, lowering the price of its supply voltage. However, it is necessary to read many more channels, which raises its price.
- A different electronic system is used to process and analyze the signals of the photosensors. The TRITIUM-Aveiro prototype uses a home-made PCB-based electronic system, which is cheaper than the commercial system used by TRITIUM-IFIC 2, PETsys. Nevertheless, the PETsys system is more stable and it is prepared for the scalability property of the detector, allowing read out much more SiPM arrays without any development. However, the PETsys system is more stable and meets the TRITIUM monitor scalability requirement, allowing more SiPM arrays to be read without any additional development.

The development and operation of these two prototypes aimed at defining the final design and construction options for the module used in the TRITIUM monitor.

5.2.1 TRITIUM-Aveiro

The third prototype built, TRITIUM-Aveiro, is a proposal of the final TRITIUM detector module. This prototype, which is shown in Figure 5.9, was

designed and built in the workshop of the University of Aveiro. This prototype consists of a PTFE vessel (marked as D in Figure 5.9), shown in Figure 5.10, with an internal cylindrical hole of 43 mm diameter and 18 cm length.




Figure 5.9 – TRITIUM-Aveiro prototype.



Figure 5.10 – PTFE structure and fiber bundle used in TRITIUM-Aveiro prototype.

This vessel contains 360 uncladded scintillating fibers of 180 mm length. The fibers are BCF-10 from Saint-Gobain company [SGC21b], which have similar characteristics than the BCF-12 fibers, table 3.2, except the diameter, which is 2 mm. In order to quantify the importance of the fiber diameter, the measurements are compared with similar measurements performed with the TRITIUM-IFIC-2 prototype, which has a similar configuration but with 1 mm fibers.

5.2. LATEST TRITIUM PROTOTYPES

The scintillator fibers are freely arranged within the PTFE vessel (without any PTFE matrix that fix them) and the number of fibers used is the maximum that allows water to flow around them. These fibers were cleaved with the device developed by TRITIUM, section 4.1.1, but they were neither polished nor cleaned because the automatic polishing machine was not yet developed and it was not feasible to polish 360 fibers by hand.

The PTFE vessel is totally closed and a water inlet/outlet were installed in it to allow a constant water flux through it. Two PMMA 10 mm thick windows, located at both ends of the fiber bundle, are used to read out the fibers. Two clamps are used to make a tight junction of the PTFE walls and the PMMA. PMMA was chosen for its optical properties, especially its transmission coefficient, which is larger than 95% at the scintillating fiber wavelength. Two PMTs (marked as C in Figure 5.9) are used to read out this prototype in time coincidence, the HV of which was set at -1500 V. Its quantum efficiency is 26%. These PMTs are attached to both fiber bundle ends by two pieces (marked as E in Figure 5.9) built with a 3D printer and they are optically coupled to the PMMA windows through optical grease [Sai]. The PMTs used are R2154-02 2" from Hamamatsu [K.K10], that have gain and efficiency quite similar to the PMTs used in the other TRITIUM prototypes.

This prototype and its electronics (marked as F in Figure 5.9), were arranged in a structure, shown in Figure 5.9, composed of several clamps and four stainless-steel screws, locked to an external PVC structure, marked as A and B in Figure 5.9, which protects the prototype from physical damage and provides a light-tight operation environment. This PVC structure is equipped with the necessary feed-through connectors.

Only one prototype was built, which was designed to be installed in the Arrocampo dam. The electronics, which is detailed in appendix D, is based on several PCBs that was specially designed to process and analyze the signals of this prototype. Two interfaces were developed to control the

PMT power supply and to control the data adquisition (thresholds, results, etc).

Measurements taken in the laboratories (DRIM and LARUEX laboratories) were used to characterize the detector. For this task, the prototype was at first filled with pure water, which was used to measure the background of the detector, and next, with a radioactive liquid tritium solution with an activity of 30 kBq/L, which was used to measure the efficiency and the minimum detectable activity, MDA, of the prototype. The volume of pure water and tritium solution used in TRITIUM-Aveiro prototype was 58 mL.

First, a measurement with a passive shield was performed in the DRIM laboratory to quantify the attenuation of the background by lead. These measurements, shown in Figure 5.11, were carried out in three different situations. The first, region A, was performed without shielding, the second, region B, with a lead shield of 2.5 mm thickness and the third, region C, with two lead foil layers. As can be seen, in the region A, the average rate of 2.5 days is $3.5 \cdot 10^3$ counts/min. In the region B, a background suppression by a factor of 2 was observed, measuring an average rate of $1.6 \cdot 10^3$ counts/min. In the region C, an average rate of $0.9 \cdot 10^3$ counts/min was obtained, supressing the background by about a factor of 4.

Then, the prototype was installed in the LARUEX laboratory, at the University of Extremadura, in order to work with a tritiated water. The background of the prototype was measured during 4 days with the prototype filled with pure water and covered with lead bricks of 5 cm thickness. The time adquisition of each measurement was 1 minut. The data, fitted to a Gaussian function, are shown in Figure 5.12a. An average rate of 540 counts/min with a standard deviation of 22.61 counts/min was obtained. To calculate the Minimum Detectable Activity (MDA), the detection limit concepts developed by Lloyd A. Currie [Gle10] were applied, according to which the minimum net counts with a probability of a false-negative less




Figure 5.11 – Measurement of the background with TRITIUM-Aveiro prototype shielded with different layers of lead, A) without shielding, B) with a lead shield of 2.5 mm thickness and C) with two lead shields of 2.5 mm thickness each one [Aze22].

than a 5%, N_D , is given by,

$$N_D = 4.65 \cdot \sigma_{Nb} + 2.71 = 108 \text{ counts/min} \quad (5.1)$$

which corresponds to a critical level of $L_C = 2.33 \cdot \sigma_{Nb} = 53 \text{ counts/min}$ (minimum net currents with a probability of a false-positive less than 5%).

L_C and N_D refer to the net rate after background subtraction. Therefore, L'_C and N'_D , referred to the detector signal (before background subtraction), are 593 and 648 counts/min respectively.

To find the MDA, tritiated water was slowly added so that the tritium water activity increased continuously up to reach the N'_D value. An




Figure 5.12 – Measurements of the background and tritium liquid source (with an activity of 29.8 kBq/L) performed with the TRITIUM-Aveiro prototype and integrated during a minute [Aze22]. a) Counts per minut measured as a function of time. b) Distribution of the acquired data.

average of 656 ± 26 counts/min was obtained, the activity of which was MDA=29.8 kBq/L, obtained with a Quantulus liquid scintillator system.

The tritium detection efficiency was calculated from the ratio of the net tritium rate measured, 1.93 ± 0.58 counts/sec, and the activity of the tritium source used, 29.8 kBq/L. The efficiency obtained is $(6.49 \pm 1.94) \cdot 10^{-2} \frac{\text{cps}}{\text{kBq/L}}$. and the specific efficiency is

$$S = (1.6 \pm 0.5) \cdot 10^{-5} \frac{\text{cps}}{\text{kBq/L} \cdot \text{cm}^2}$$

Comparing to the specific efficiency obtained with scintillating detectors, Table 2.2, the specific efficiency of the TRITIUM-Aveiro prototype is close the largest value, obtained by Hofstetter [Hof92b, Hof92c], $< 2.22 \frac{\text{cps}}{\text{kBq/L} \cdot \text{cm}^2}$. However this prototype has a lower specific efficiency than TRITIUM-IFIC-1. A possible reason is that the fibers in this prototype are not polished,

5.2. LATEST TRITIUM PROTOTYPES

neither cleaned.

The efficiency uncertainties obtained for this prototype are larger than those obtained in the first TRITIUM prototypes since the measurement time used is shorted (1 minute) than the time used for the previous prototypes (several hours). Because of that, longer measurements are studied to quantify the reduction of the MDA of this prototype, which depends directly on the background uncertainty, equation 5.1. The data for an integrated time of 60 minutes is shown in Figure 5.13. The mean value and the uncertainty of the measured background data are $3.186 \cdot 10^4$ and 228 counts per hour respectively. Values of $L_C = 530$ and $N_D = 1043$ counts per hour are obtained from the equation 5.1. Assuming linearity between the measured counts for the background and the tritiated water, the N'_D obtained for this case, $3.872 \cdot 10^4$ counts per hour, corresponds to a MDA of 4.53 kBq/L. A daily oscillation is clearly observed in the Figure 5.13, indicating that the measurements are affected by external light. This oscillation begins on the 19th day, when the water closed circuit pump was installed, so it is likely that a light leak was introduced in the system.

This prototype was finally installed in the Arrocampo dam to test its functionality and to begin with the tritium level monitoring the measurements of which are reported in section 5.3.

5.2.2 TRITIUM-IFIC-2

The last prototype developed for TRITIUM was TRITIUM-IFIC-2, marked as A in Figure 5.14. This prototype, built in the IFIC workshop, consists of a cylindrical PTFE vessel, shown in Figure 5.15, with a similar shape to that of Aveiro. The internal length and diameter of the PTFE vessel were 210 mm and 36 mm respectively. This prototype contains 800 uncladded BCF-12 scintillating fibers of 200 mm length and 1 mm diameter. This number is larger than that in Aveiro's prototype and is contained in a smaller volume.




Figure 5.13 – Measurements of the background and tritium liquid source (with an activity of 29.8 kBq/L) performed with the TRITIUM-Aveiro prototype and integrated during one hour [Aze22].

The fibers used were cleaved, polished and cleaned with the conditioning processes described in section 4.1. These scintillating fibers were freely and tightly arranged while standing straight, allowing water to flow among them. Two PMMA windows, located at the ends of the fiber bundle, allowed to read out the scintillation light in a similar way as in the Aveiro's prototype.

A 5 mm width PMMA optical windows is sufficient to guarantee tightness, since the detector works at very low water pressure. Two clamps allow to keep the water tightness of the prototype, similar to the TRITIUM-Aveiro prototype. PMMA was chosen for its optical properties, especially its transmission coefficient, shown in Figure 5.16, which was measured for visible light at ICMOL laboratories. This transmission coefficient

5.2. LATEST TRITIUM PROTOTYPES




Figure 5.14 – TRITIUM-IFIC-2 prototype (A) and active veto (E) within the metallic structure (D).

is approximately 95% for the working wavelength (435 nm). Slightly better transmission coefficients can be achieved with other materials such as quartz or sapphire but they are much more expensive.

A water inlet/outlet was implemented in the PTFE vessel, B in Figure 5.15, to allow a constant water flux, as in the TRITIUM-Aveiro prototype.

In the first laboratory measurements, two PMTs model Hamamatsu R8520-460 [K.K19] were used to compare the results to those of the previous prototypes. However, measurements of the TRITIUM-IFIC-2 prototype with SiPM arrays controlled by PETsys were also performed, as this is the final readout option for this prototype. PETsys has a graphical user interface, shown in Figure 5.17. It allows the remote control of all the different input and output options such as the supply voltage for the SiPM arrays, thresholds, etc., via computer terminal.



(a)



(b)

Figure 5.15 – a) TRITIUM-IFIC-2 PTFE vessel. b) TRITIUM-IFIC-2 PTFE vessel with PVC caps in which a groove is made for the cable connection to the SiPM.

5.2. LATEST TRITIUM PROTOTYPES




Figure 5.16 – Light transmission spectrum of a 5 mm thick PMMA plate, measured at ICMOL laboratory.

Two PVC caps, located at both ends of the prototype were used to provide a light-tight environment to the SiPM arrays. An aluminum structure was designed and built to house up to 10 TRITIUM-IFIC-2 modules and two cosmic vetos, marked as D in Figure 5.14.

In Arrocampo site, the available space inside the lead shield box may accommodate up to 5 structures. This means that the final TRITIUM monitor may accommodate up to 50 TRITIUM-IFIC-2 modules and 5 different cosmic vetos.

Two identical TRITIUM-IFIC-2 prototypes were built, as for the TRITIUM-IFIC-0 prototype. One of them was filled with pure water and used to measure the background and the other was filled with a radioactive liquid source of tritium and employed to measure the signal. The water volume in both cases was 82 mL (uncertainty of 0.05%). The activity of the tritium source used for this prototype was 10 kBq/L (uncertainty of 2.24%), which was prepared by diluting a sample of tritiated water in pure water. The signal and background energy spectra are shown in Figure 5.18a. The




Figure 5.17 – Graphical User Interface (GUI) of PETsys.

energy spectrum of tritium, Figure 5.18b, was obtained by subtracting the background to the signal. The rates obtained from these three spectra are given in Table 5.3.

Spectrum	Counts/second
Signal prototype	19.05 ± 0.18
Background prototype	11.54 ± 0.14
Tritium counts	7.11 ± 0.23

Table 5.3: Counting rates measured by TRITIUM-IFIC-2 prototype.

The tritium detection efficiency obtained for this prototype is $(7.11 \pm 0.28) \cdot 10^{-1} \frac{\text{cps}}{\text{kBq/L}}$. This efficiency is larger than those reported in the literature, Table 2.2. This is an expected result since the active area of this prototype is the largest. To remove the active area effect, the specific efficiency was measured, obtaining a value of

$$S = (14.1 \pm 0.6) \cdot 10^{-5} \frac{\text{cps}}{\text{kBq/L} \cdot \text{cm}^2}$$

5.2. LATEST TRITIUM PROTOTYPES




Figure 5.18 – Energy spectra measured with TRITIUM-IFIC-2 prototype.
a) Signal and background energy spectra. b) Tritium energy spectrum.

Again, it can be observed that this prototype has the largest specific efficiency reported for tritium detection, demonstrating that its design the best design currently developed for detection of low activities of tritium in water.

The energy spectrum is given in ADC channels, since an energy calibration for a plastic scintillator is not accurate due to the large uncertainty in the number of photons produced per energy event. Nevertheless, a detector calibration in units of photons detected per event can be obtained from the single-photon distribution of the PMTs. The PMTs used to read this prototype was decoupled from the prototype and covered with a special black blanket to screen the PMT from external photons. The distribution measured and fitted to a Gaussian function is shown in Figure 5.19a. As can be seen, the mean and uncertainty of the single photon signal are around 172 and 66 ADC channels, respectively, for one of the PMT and 173 and 57 ADC channels, respectively, for the other. The tritium signal given in number of photons detected per event, shown in Figure 5.19b, is obtained as the ratio of the energy spectrum to the single-photon distribution mean. A maximum of 15 photons are measured per tritium event, which is in agreement with the results of the simulations shown in Chapter 6.

A monitoring of both prototypes, signal and background, were carried out during several months. The rates measured are shown in Figure 5.20. No quenching of the signal was observed, which indicates the detector efficiency remained stable, within statistical and systematic uncertainties, over up to 6 months.

Finally, the Minimum Detectable Activity (MDA) was calculated. To do so, fourteen different measurements of the background were done using two different integration times, 10 min and 60 min. The mean value and standard deviation of these measurements are shown in the Table 5.4. The minimum net counts with a probability of a false-negative less than 5%, N_D , and with a probability of a false-positive less than 5%, L_C , were calculated by applying the Currie's law, equation 5.1 and they are included




Figure 5.19 – a) Single photon distribution measured with TRITIUM-IFIC-2 prototype. b) Tritium energy spectrum measured with TRITIUM-IFIC-2 prototype in photons detected per event.




Figure 5.20 – Signal and background rates for a long time measurement.

in Table 5.4.

Int. time (min.)	Mean V.	Std. Dev.	L_C	N_D
10	5635	82	191	384
60	33969	158	368	737

Table 5.4: Mean value and standard deviation of the counts of fourteen background measurements. Minimum net counts obtained by applying the Currie's Law, L_C and N_D .

Therefore, N'_D , which is the counts referred to the detector signal (before background subtraction), are 6019 and 34706 counts for an integration time of 10 min and 60 min respectively. Then, the MDA of tritium can be obtained from the N'_D values by associating the mean value of the background counts to a zero tritium activity and the mean value of the signal counts to a tritium activity of 10 Bq/L, assuming counts scale linearly with the activity. This results in a MDA of 677 Bq/L and 218 Bq/L for the integration time of 10 min and 60 min respectively.

In addition, it has to be taken into account that one of the most im-

5.2. LATEST TRITIUM PROTOTYPES

portant properties of the TRITIUM detector is its scalability, which means that better results can be achieved by using a large number of modules. The MDA of the TRITIUM monitor is expected to be reduced by a factor of $\sqrt{\text{number of prototypes}}$, according to the equation 5.1. This relationship is shown in Figure 5.21, where it can be seen that the goal of the TRITIUM project (to be able to measure 100 Bq/L (red line) in quasi-real time) is achieved by using 45 TRITIUM-IFIC-2 modules read out in parallel with an integration time of 10 min and, the cheaper and more realistic option of using 5 TRITIUM-IFIC-2 modules read out in parallel with an integration time of 1 h.




Figure 5.21 – Minimum detectable activity, MDA, as a function of the number of TRITIUM-IFIC-2 prototypes read out in parallel for an integration time of 10 min (blue line) and 1 h (black line). The dotted red line indicates the goal of the TRITIUM project, 100 Bq/L.

5.3 Results from Measurements at Arrocampo Dam

The measurements obtained with the TRITIUM-Aveiro prototype in the Arrocampo dam are reported in this section. This prototype was installed and working there for more than four months, from March 27, 2019 to August 18, 2019, taking background measurements. The data acquired during this time are plotted in Figure 5.22, for a measurement time of 60 minutes.




Figure 5.22 – Background measured with the TRITIUM-Aveiro prototype during its installation in Arrocampo dam [Aze22].

The data show good stability during the measuring period. An average rate of 9.31 counts per second was obtained. A narrow peak is

5.3. EXPERIMENTAL RESULTS IN ARROCAMPO DAM

observed on May 2, 2019, caused by an opening of the roof of the lead shield to access the prototype. In the inset of the figure, the data are magnified for a better visualization. The MDA measured in Arrocampo dam for 60 minute integration time is 6 times larger than that obtained in the laboratory measurements, section 5.2.1. This may be due to the electric noise introduced by the pumps of the water purification system and the instability observed in the electronic boards.

The cosmic veto currently under development is planned to be installed and used in anti-coincidence along with two additional prototypes.

Furthermore, three TRITIUM-IFIC-2 prototypes and a cosmic veto, described above, are also planned to be installed in Arrocampo dam as soon as possible.

5.4 Modular TRITIUM Detector for In-Situ Tritium Monitoring

The final TRITIUM monitor is presented in this section, a schematic design of which is shown in Figure 5.23. It consists of a number of TRITIUM modules read out in parallel, the design of each one will include the characteristics (differences between the latest prototypes) with which the best results has been obtained. These modules are shielded from environmental radioactivity by three different techniques:

1. An external lead shield, which is used to stop the environmental radioactivity and soft cosmic rays (particles with energies below 200 MeV).
2. Several active vetos, which are placed below and above the TRITIUM modules. These active vetos are read out in anticoincidence to suppress high energy event background, mainly cosmic ray particles with energies above 200 MeV.
3. A water purification system, which is used to eliminate the radioactive elements present in the water samples measured by the TRITIUM monitor.

The water purification system, the lead shield and a TRITIUM-Aveiro prototype are installed and currently in operation at the Arrocampo dam. This entire system is employed to successfully monitor the tritium levels in Arrocampo dam during several months. Furthermore, two additional TRITIUM-Aveiro prototypes and four active vetos are currently under construction and will be measured in parallel with this prototype.

The electronics of the TRITIUM-Aveiro prototype, based on a RaspberryPi, cannot be used for multiple modules due to counting limitations and this must be replaced by an FPGA-based counter board.

5.4. MODULAR TRITIUM DETECTOR FOR IN-SITU TRITIUM MONITORING




Figure 5.23 – A schematic design of the TRITIUM detector.

Three TRITIUM-IFIC-2 prototypes and two active veto (on up and other below the modules) are already built and they will be installed as soon as possible. In this first installation, lateral cosmic vetos for the TRITIUM-IFIC-2 modules are not contemplated since its influence is expected to be small ($\propto \cos^2(\theta)$), but if necessary they can be included in the future.

One of the most important aspects of the TRITIUM monitor is its modular design, which allows scalability to reach the required sensitivity, 100 Bq/L. It means that if this target sensitivity is not achieved with the three modules to be installed, it can be obtained by installing additional modules.

The only scalability restriction is the available space, which is set by the lead shield and the cabin in which the setup is installed. In the currently available space, five different structures as the one shown in Figure 5.24 can be placed, each one containing 10 modules and two active veto. If the 50 TRITIUM modules are installed, the sensitivity of the TRITIUM

monitor could be improved by a factor of around 7 ($\sqrt{50}$) with respect to the sensitivity of a single module.




Figure 5.24 – A TRITIUM monitor design based on the TRITIUM-IFIC-2 prototype.

5.4. MODULAR TRITIUM DETECTOR FOR IN-SITU TRITIUM MONITORING

Chapter 6

Simulations

The Monte Carlo simulations performed in the TRITIUM experiment are described in this chapter. They were carried out to optimize the design of the TRITIUM detector, understand its behaviour and investigate its limitations. This chapter is divided into two different sections. The first section contains the results of several simulations used to improve the design of the TRITIUM detector, while the second section describes the simulation results of a full TRITIUM monitor composed of several TRITIUM-IFIC-2 prototypes read out in anticoincidence mode with an active cosmic veto. Furthermore, several tests were carried out to verify the correct simulation of the different steps such as the simulated tritium source, the energy deposition in the fibers and the production of photons in them. The simulation environment employed is Geant4 [GEA, Ago03].

6.1 Geant4 Environment

Geant4 is a software toolkit for the simulation of the passage of particles through matter developed at CERN, based on object-oriented technology

6.1. GEANT4 ENVIRONMENT

implemented in C ++ programming language. Geant4 includes the definition of all the different aspects of the simulation process such as detector geometry, materials used, particles of interest, physical processes that handle particle and matter interactions, response of sensitive detectors, generation, storage and analysis of event data and visualization.

Geant4 simulates particle-by-particle physics. This means that the tritium events are generated one by one, generating energy, momentum, position, etc. The propagation of each tritium decay electron and its interaction with the scintillator is simulated, and optical photons are created. The propagation of these optical photons are also simulated one by one and the simulation ends when all the created optical photons have been absorbed by either the sensitive detector or other materials present in the simulation.

The physics list used for these simulations is Livermore, G4EmLivermorePhysics, which is specially designed to work with low energy particles. This list includes the most important electromagnetic processes at low energies such as bremsstrahlung, Coulomb scattering, atomic de-excitation (fluorescence) and other related effects.

The materials included in these simulations were water (to simulate the tritiated water source), PMMA (to simulate the optical windows of the prototype), polystyrene (to simulate the core of scintillating fibers), PTFE (to simulate the prototype vessel), silicone (to simulate the optical grease), silicate glass (to simulate the optical windows of the PMTs) and bialkali (to simulate the photocathode material of the PMT). The properties of water, PTFE and polystyrene were taken from the Geant4 NIST database and the other materials were built by specifying their atomic composition. The following optical properties were added to these materials:

1. The refraction index and light attenuation coefficient were added to water, obtained from ref. [Bui94]. A spectrum of tritium decay elec-

trons, uniformly distributed in the volume, was added to water to simulate tritiated water. The tritium decay spectrum data were taken from ref. [Mer15].

2. The spectra of refractive index, light attenuation and photon emission, obtained from the data sheet of scintillating fibers, [SGC21a], were added to the polystyrene. The scintillation yield and the decay time coefficient, also obtained from this data sheet, were included.
3. The quantum efficiency spectrum was added to the photocathode material of the PMTs, taken from their data sheet [K.K19]. A refraction index of 1.46 was used for optical grease, also obtained from its data sheet [Sai].
4. Finally, the optical data for the remaining materials, PMMA windows, PTFE and silicate glass, were taken from ref. [Arg11].

6.2 Simulations for the design of the TRITIUM Detector

Several simulations were performed during the design of the TRITIUM detector, which were used to quantify the influence of some modifications and to choose those that optimize the tritium detection. The characteristics studied are the diameter and the length of the scintillating fibers. As the tritium electrons have a very short mean free path, the shape of the simulated tritium source was also studied to reduce computing time.

6.2.1 The Tritiated Water Source

First of all, the shape of the simulated tritiated water source was optimized. The mean free path of tritium electrons in water is only around $5 \mu\text{m}$,

6.2. SIMULATIONS FOR THE DESIGN OF THE TRITIUM DETECTOR




Figure 6.1 – Energy distribution of a) simulated tritium decays b) Initial energy of tritium decays that reach the scintillating fibers (red histogram) compared to all simulated tritium events (blue histogram) [Aze20].

so most electrons do not reach the scintillating fibers. These electrons do not provide useful information and only consume computing resources. To optimize the simulation, the dimensions of the simulated tritium source were set to minimize the number of tritium events that do not reach the scintillating fibers.

Before that, the energy distribution of the simulated tritium events, shown in figure 6.1a, was compared with the input taken from ref. [Mer15], obtaining a good agreement with it. In addition, the distribution of the initial energy of tritium electrons capable of penetrating a fiber and depositing energy was compared to the initial energy distribution of all simulated tritium events, Figure 6.1b. A shift of the peak to high energies is observed, obtaining a peak centred at 10 keV. This shift occurs because the lower energy tritium decay electrons do not reach and penetrate the fibers and are not detected.

Regarding the optimization of the tritium source shape, a scintil-

lating fiber 20 cm long and 2 mm in diameter and a surrounding tritiated water source of the same length and 0.5 mm thick(100 times greater than the mean free path of tritium electrons) were simulated to assess the tritium source. The dimensions of the fiber are not important in this study since only the energy deposition of tritium electrons in the fiber was simulated, excluding optical processes. The goal of this simulation was to find the radial thickness of the simulated tritium source beyond which no significant amount of tritium decay electrons are detected. In Figure 6.2a, a transversal cut of the 2 mm scintillating fiber, the simulated 0.5 mm thick tritium source around the fiber, and the position where happen the tritium decays that deposit energy in the scintillating fiber are shown. Furthermore, the distribution of the radial distance between the position where tritium decays take place and the surface of the scintillating fiber is shown in figure 6.2b. As can be seen in the Figure 6.2, most of the tritium decays that are detected occur close to the scintillating fiber. A zoom of low energy events is shown in the inset box of the Figure 6.2b for better viewing. The chosen thickness of the simulated tritium source was $5 \mu\text{m}$ since 99.4% of the events that deposit energy in the fibers are produced at a shorter distance.

6.2.2 Energy Deposition and Light Output of Scintillating Fibers

The scintillation yield provided by the manufacturer, 8000 photons/MeV, is only valid for minimum ionizing particles (MIP). As tritium electron energies do not correspond to MIP particles, the output light generated by the scintillating fibers was studied. For this task, the energy deposition of tritium electrons in scintillating fibers and their subsequent emission of scintillation photons was included in the simulation.

When particles that are not MIP are detected in plastic scintillators, a quenching effect for the output light per unit of path length, $\frac{dL}{dx}$, with

6.2. SIMULATIONS FOR THE DESIGN OF THE TRITIUM DETECTOR




Figure 6.2 – a) Transversal cut of simulated scintillating fiber (yellow) and tritium source (green) with various tritium decays (red dots) b) Distribution of the radial distance between the position where the tritium decay takes place and the surface of the scintillating fiber [Aze20].

respect to the energy deposited per unit of path length, $\frac{dE}{dx}$, happens, that can be parametrized by the Birks coefficient[Bir51].

$$\frac{dL}{dx} = S \frac{\frac{dE}{dx}}{1 + k_B \frac{dE}{dx}} \quad (6.1)$$

where S is the scintillation yield, provided by the manufacturer. The value for the Birk's coefficient of $k_B = 0.126$ mm/MeV, typically used for scintillators based on polystyrene [B. 11], was taken. In this section, the significance of this quenching effect and how it affects the tritium detection is discussed.

A study of the energy deposition of tritium electrons on scintillating fibers was carried out. In Figure 6.3 the initial energy of simulated tritium electrons that reach the scintillating fibers is compared to the energy

deposited in the scintillating fibers. A shift to lower energies is observed, caused by the loss of energy of tritium electrons in water. A cut about 1 keV is observed in both energy distributions, produced by the default energy threshold of 990 eV in the G4EmLivermorePhysics physics list.




Figure 6.3 – Distribution of the initial energy of tritium events that reach the scintillating fibers (blue histogram) and the energy deposited in these fibers (red histogram) [Aze20].

Figure 6.4 shows two distributions of number of photons produced in scintillating fibers by tritium events, one in which the quenching effect is not considered ($k_B = 0$) and the other with the Birks coefficient set to $k_B = 0.126 \text{ mm/MeV}$.

A distribution with a peak of around 40 photons per tritium event and a maximum of around 150 photons is obtained when the quenching effect is not considered. A significant reduction of the output light is observed

6.2. SIMULATIONS FOR THE DESIGN OF THE TRITIUM DETECTOR




Figure 6.4 – Energy distribution of photons produced in the scintillating fiber, without the Birks coefficient (red histogram) and with the Birks coefficient of $k_B = 0.126 \text{ mm/MeV}$ (blue histogram)[Aze20].

when the Birks coefficient is taken into account, producing a distribution peaked at around 10 photons and a maximum of 110 photons. The quenching effect is also observed in Figure 6.5, in which the number of produced photons as a function of the energy deposited in the fibers is displayed in a two-dimensional plot. In this figure, in addition to a reduction of the number of photons produced per unit of energy deposited, a broader distribution is obtained when the Birks coefficient is considered, indicating an increase of the fluctuations of energy deposition.




Figure 6.5 – Number of photons produced versus the energy deposited in the scintillating fibers when a)the Birks coefficient is not considered ($k_B = 0$) b) the Birks coefficient is $k_B = 0.126$ mm/MeV [Aze20].

6.2.3 Optimization of the Fiber Length

A study to find the fiber length that optimizes the tritium detection efficiency was carried out. Two different lengths of scintillating fibers were considered in this study, 1 m and 20 cm, and two different tritium source activities were used, 0.5 kBq/L and 2.5 kBq/L. As detected tritium decays are proportional to the active area, 5 detectors were simulated for the case of a 20 cm fiber length to have the same active area. As the active area of the detector is related to its tritium detection efficiency, the advantage for using long fibers is their large active areas with a small number of cells, reducing the number of photosensors and, consequently, the price of the TRITIUM monitor. However, a smaller length of scintillating fibers reduces the photon absorption produced in the fibers, which increases the tritium detection efficiency per active area.

To find the scintillating fiber length that optimizes the tritium detection efficiency, the Tritium-Aveiro prototype, consisting of 360 scintillating fibers of 2 mm diameter, was simulated. All optical properties for

6.2. SIMULATIONS FOR THE DESIGN OF THE TRITIUM DETECTOR

the photon propagation were included in this study.

The propagation of photons in scintillating fibers was checked. The number of photons produced in a scintillating fiber per tritium electron was compared for the electrons that reach the scintillating fiber and for only those photons detected in time coincidence by the photosensors, shown in Figure 6.6. Tritium events that produce a high number of photons are almost always detected but events that produce few photons are seldom detected, resulting in a peak centred at around 25 photons.




Figure 6.6 – Number of photons produced in the fiber per tritium event for all tritium events that reach the fiber (blue histogram) and for only tritium events producing photons detected in coincidence by photosensors (red histogram) [Aze20].

The counts, integrated over 60 min and taken over a week, are shown in Figure 6.7 as a function of time for both tritium activities and

fiber lengths studied. 5 times greater signal is seen for the shorter fiber length in both cases, due mainly to the lower absorption of photons in the shorter scintillating fibers and the leakage of some photons due to partial photon collection in the fiber. In addition, non simulated effects like the dirty or mechanical imperfections of scintillating fibers increase this photon loss effect.




Figure 6.7 – Simulations of counts integrated over 60 min, normalized to the same active area and taken over a week for a fiber length of 1 m (dashed lines) and 20 cm (solid lines) and two different activities, 0.5 kBq/L (blue lines) and 2.5 kBq/L (red lines) [Aze20].

6.2. SIMULATIONS FOR THE DESIGN OF THE TRITIUM DETECTOR

6.2.4 Fiber Diameter Effect

A study of the influence of the fiber diameter in the tritium measurement was carried out. For this task, simulations of a single 20 cm length scintillating fiber and two different diameters, 1 mm and 2 mm (the commercial options given for Saint-Gobain), were compared. An important point is how the fiber diameter affects the cosmic ray detection, which is an important component of the TRITIUM monitor background. The energy deposited in the scintillating fiber by a cosmic ray is proportional to the active volume crossed, which is larger for 2 mm fibers. Therefore, the cosmic ray signal would be larger for 2 mm diameter fibers. The objective of this study is to find which minimizes the background in the energy region of tritium detection, up to 18 keV (region of interest, ROI). For this study, the tritiated water source was replaced by a cosmic ray source, generated by the CRY library¹ [Plo, Hag07]. The CRY library is a package based on object-oriented technology and implemented in the C++ programming language. This library generates cosmic-ray shower distributions for different particles (muons, neutrons, protons, electrons, photons and pions). The cosmic source shape used in this simulation is a horizontal square of $1 \times 1 \text{ m}^2$ located at a height of 35 cm (above the detector) with the typical distribution of cosmic particles at sea level. The distribution of energy deposited in scintillating fibers for 1 mm and 2 mm diameters by cosmic rays is shown in Figure 6.8. As can be seen in the figure, a smaller background (about 50%) is measured for fiber diameters of 1 mm, which allow to achieve a lower minimum detectable activity MDA of the detector. There are other reasons that may favor the use of 2 mm fibers, such as their greater rigidity and better flow of water through them. Thus, a complementary experimental study is needed to assess the most appropriate diameter size for the scintillating fibers.

o

¹CRY library, Cosmic-Ray Shower library




Figure 6.8 – Comparison of the energy deposition by cosmic rays in scintillating fibers of 1 mm and 2 mm diameter.

6.2.5 Effect of the PMMA windows

In the first prototypes, TRITIUM-IFIC-0 and TRITIUM-IFIC-1, the fibers were directly coupled to the photosensor, so the detected photons were only those guided by the fibers. However, in the last prototypes, TRITIUM-Aveiro and TRITIUM-IFIC-2, two PMMA windows are used, which allows the transmission to the photosensors of the photons guided by the fiber and photons that propagate through the water at the cost of losing some photons when passing through the PMMA (approximately 5% at the working wavelength, measured in Figure 5.16). To quantify the importance of the latter contribution, the TRITIUM-Aveiro prototype was simulated. The distribution of the number of photons that reach the PMMA per tritium event is shown in Figure 6.9. Fiber-guided photons are shown in a red distribution, while those traveling in the water medium are plotted in the blue histogram. It can be seen that the tritium signal obtained from the water is

6.3. SIMULATIONS OF THE TRITIUM MONITOR

as important as that obtained from the fibers. Therefore, the use of PMMA windows improve the tritium detection efficiency by a factor of almost 2.




Figure 6.9 – Distribution of photons reaching the PMMA windows. The red histogram corresponds to the photons guided by fibers and the blue histogram to photons traveling in the water [Aze20].

6.3 Simulations of the TRITIUM Monitor

The simulations of a TRITIUM monitor, consisting of various TRITIUM-IFIC-2 prototypes in parallel and a background rejection system, are shown in this section.

6.3.1 Simulation of the TRITIUM-IFIC-2 Prototype

For the simulation of the Tritium-IFIC-2 prototype, 800 fibers of 1 mm diameter were arranged and uniformly distributed in sixteen different circles of increasing radius, as illustrated in Figure 6.10. The optical properties were included.




Figure 6.10 – Distribution of the scintillating fibers in the simulations of the Tritium-IFIC-2 prototype.

The tritiated water source consists of a tritiated water volume with a thickness of $5 \mu\text{m}$ around each scintillating fiber. Scintillating fibers are located in a PTFE vessel. Two PMMA windows of 5 mm thickness located in both ends of the cylindrical vessel and an optical grease layer with a thickness of 0.5 mm located on each PMMA windows were included. Two PMTs, model R8520-460 from Hamamatsu [K.K19], were also simulated as photosensors.

6.3. SIMULATIONS OF THE TRITIUM MONITOR

The geometry simulated for TRITIUM-IFIC-2 is shown in Figure 6.11 in which is shown the PMTs (black), the optical grease (blue), the PMMA windows (white), the tritiated water (green) and the scintillating fibers (yellow). In this image, the PTFE container is not drawn to allow its interior to be seen. Several volumes of tritiated water were also excluded to allow some scintillation fibers to be seen. The PMTs do not cover the entire active area formed by the scintillating fiber bundle. This fact produces that some photons are not detected, slightly reducing the efficiency of the detector. In the future, possible solutions will be studied, such as the use of photosensors that covers that entire active.




Figure 6.11 – Simulation of Tritium-IFIC-2 prototype. PMTs (black), the optical grease (blue), PMMA windows (white), tritiated water (green) and scintillating fibers (yellow).

The aim of these simulations were to find the activity resolution of the prototype and how it can be improved by increasing the integration time window and the number of prototypes read out in parallel. The detection of a tritium event in the TRITIUM-IFIC-2 prototype is shown in Figure 6.12. The paths of the photons created in scintillating fibers are represented by green lines ending in red dots when they are absorbed in the fiber or the water and blue dots when they are absorbed in the PMTs (detected). The fiber in which the tritium electron is detected is clearly identified. Some photons go out of the fiber and are not collected. Blue dots in both PMTs indicate that photons are detected in time coincidence.




Figure 6.12 – Tritium electron detected in the simulated TRITIUM-IFIC-2 prototype. The path of the optical photons is represented by green lines and the position in which they are absorbed is represented by red and blue dots (absorbed in water or PMT, respectively).

Several variables were used to check the different steps of the simulation such as the production of tritium electrons, the energy deposition in scintillating fibers and their subsequent photon emission, the spatial distribution of generated events, the detected events, etc. The distribution of the number of photons detected by photosensors per tritium event for the TRITIUM-IFIC-2 prototype is shown in Figure 6.13. A maximum of 17 photons is obtained for the TRITIUM-IFIC-2 prototype simulations, which is in agreement with the distribution of photons per tritium event measured experimentally, shown in Figure 5.19. The experimental distributions are lower than the simulations mainly in the range from 3 to 8 photons per event, probably due to some subtle imperfections of the prototype, which are impossible to included in the simulations.

Activities from 100 Bq/L to 5 kBq/L for three months of data taking and an integration counting time of 10 min were simulated. The simulation results are presented in Figure 6.14. A difference of 250 Bq/L in the activity is not distinguished due to the overlapping of distributions. To reduce the width of the distribution obtained for each activity, the statistics must be increased, which can be done in two different ways, either by increasing the integration time or the number of prototypes read out in

6.3. SIMULATIONS OF THE TRITIUM MONITOR




Figure 6.13 – Photons detected by both PMTs per tritium event in the simulated TRITIUM-IFIC-2 prototype.

parallel. To check the role of increasing the integration time, distributions for integration times of 10 min, 30 min and 60 min were generated. They are shown in Figure 6.15. The effect of increasing the integration time is clearly visible in this figure, by reducing the relative distribution width and improving the activity resolution of the TRITIUM monitor. Differences as low as 250 Bq/L are clearly discriminated with only one TRITIUM-IFIC-2 module and an integration time of 60 min, which could still be considered as a quasi-real time measurement. Similarly, these distributions are shown in Figure 6.16 for 10 min of integration time, for 1, 5 and 10 modules read out in parallel. Again, the reduction of the distribution width with increasing number of modules is clearly visible in these figures, improving the activity resolution of the detector. In this case, differences of 250 Bq/L are clearly discerned by an integration time of 10 min and 5 TRITIUM-IFIC-2 modules. The resolution, defined as

$$\text{Resolution}(\%) = \frac{\text{FWHM}}{\text{centroid}} \cdot 100 \quad (6.2)$$

is plotted in Figure 6.17. It can be observed that the resolution improves with the integration time and the number of modules. Therefore, both parameters must be set according to the requirements and funding of the experiment. The studied cases are summarized in Table 6.1.

# of modules	10 min	30 min	60 min
1	< 1000 Bq/L	500 Bq/L	200 Bq/L
5	200 Bq/L	150 Bq/L	100 Bq/L
10	150 Bq/L	100 Bq/L	≈ 50 Bq/L

Table 6.1: Difference in activity that can be resolved for the TRITIUM-IFIC-2 prototype, for different integration times and different number of modules.

The decision made by the TRITIUM collaboration is to install 5 TRITIUM-IFIC-2 modules with an integration time of 1 h, with which a MDA of 100 Bq/L is expected to be achieved, as it was seen in Figure 5.21. With this configurations, differences of 100 Bq/L are expected to be resolved according to the table 6.1.

Three TRITIUM-IFIC-2 modules are planned to be installed in Arrocampo dam as soon as possible, which will be used to detect and solve possible problems when several TRITIUM modules are read out in parallel. In addition, two other TRITIUM-Aveiro prototypes are being built and will be installed soon, to be read out in parallel with the one currently installed.

6.3.2 Simulation of the Lead Shield and Cosmic Veto

The lead shield and the active vetos, described above, were included in the simulation of the Tritium-IFIC-2 prototype. The purpose of these simulations was to quantify the reduction of cosmic background detected by the prototype. For this task, the tritium decays was replaced by a cosmic event

6.3. SIMULATIONS OF THE TRITIUM MONITOR




Figure 6.14 – a) Simulated of tritium counts measured with a TRITIUM-IFIC-2 prototype, using an integration time of 10 min, during three months of measurements (13248 measurements for each activity). b) Distribution of these counts for each activities.




Figure 6.15 – Simulation of the distribution of the tritium counts obtained with a TRITIUM-IFIC-2 prototype for different tritium activities during three months of measurements and three different integration times: a) 10 min (13248 measurements), b) 30 min (4416 measurements) and c) 60 min (2208 measurements).

6.3. SIMULATIONS OF THE TRITIUM MONITOR




Figure 6.16 – Simulation of the distribution of the tritium counts during three months using an integration time of 10 min (13248 measurements) for different tritium activities and different number of TRITIUM-IFIC-2 modules: a) 1, b) 5 and c) 10.




Figure 6.17 – Resolution of the TRITIUM-IFIC-2 prototype as a function of the. a) Integration counting time using 1 TRITIUM-IFIC 2 module. b) Number of modules, using an integration counting time of 10 min.

6.3. SIMULATIONS OF THE TRITIUM MONITOR

source, which was simulated using the CRY library. This source of cosmic events consists of a 1×1 square plane placed on the tritium monitor (at a height of 70 cm). The optical properties of the plastic scintillators of the active veto considered are the refractive index, the light attenuation spectrum and energy emission spectrum, the values of which were obtained from their data sheet provided by the manufacturer [Epi20]. Two PMTs, model R8520-460 from Hamamatsu, were simulated to read out each plastic scintillator, as described in section 3.4.2. The lead shield was simulated with the lead properties taken from the Geant4 NIST database. The dimensions of the simulated lead shield were $60 \times 60 \times 70$ cm³, which are the minimum dimensions needed for lodging one TRITIUM-IFIC-2 prototype and an active cosmic veto inside it. The length of the simulated lead castle, 60 cm, is smaller than the real dimension, 148 cm, of the lead shield at Arrocampo. The reason for this is that only one tritium detector module was simulated, so the dimension of the lead shield was reduced to optimize simulation time and computing resources. As for the simulations of the TRITIUM-IFIC-2 prototype, the characteristics of the events generated (energy distribution, position and momentum distribution, etc) were produced as control parameters of the simulations along with the simulation results of counts in the detector.

Three different simulations were carried out with three different shielding configurations with the aim of quantifying the background rejection due to each part of the background rejection system (pasive shield and active veto). The first simulation consists of one TRITIUM-IFIC-2 prototype and the cosmic ray source. In the second simulation, a lead shield was added and for the third simulation, the cosmic veto was also included, located inside the lead shield. The total counts of cosmic events detected by the TRITIUM-IFIC-2 prototype are shown in Figure 6.18, which is divided into three different bins according to the three shielding configurations used. It is found that the cosmic rays detected by the TRITIUM-IFIC-2 prototype are reduced by around a factor 5.5 when a lead shield with 5 cm thick walls

is included (this is the width of the shield currently installed in Arrocampo). This reduction is most probably caused by the suppression of the soft cosmic radiation (energy lower than 200 MeV). It has to be taken into account that the natural background of the installation site was not included in this simulation. This background will also be mitigated by the lead shield, so the expected reduction of the background due to the passive veto would be even better. Around 60% of the cosmic events that penetrate the lead shield and reach the TRITIUM-IFIC-2 prototype, which are mostly hard cosmic rays, are detected by the cosmic veto and, therefore, are suppressed from the background in the detector. In summary, the cosmic events that would be detected and misidentified as tritium events by the TRITIUM-IFIC-2 prototype are reduced by 92.6% by means of the full passive and active shielding system. Furthermore, this reduction is expected to be even larger since, as stated before, the natural background of the site was not included in this simulation.




Figure 6.18 – Total cosmic ray events detected by the TRITIUM-IFIC-2 prototype (from 10^5 generated cosmic events), which are misidentified as tritium events by the TRITIUM-IFIC-2 prototype in three different shielding configurations. The first configuration (bin 1) corresponds to a TRITIUM-IFIC-2 prototype without the background rejection system. The second configuration (bin 2) corresponds to adding the passive shield and the third configuration (bin 3) corresponds to the full shield of passive and active cosmic veto. .

Chapter 7

Present Status and Summary of the Results of the TRITIUM Project

In this chapter, the most important results obtained in this PhD thesis and in the TRITIUM project are summarized and discussed. These results were previously presented in chapters 4 to 6.

Tritium, which is a radioactive element, is one of the most abundantly produced radioisotopes in nuclear facilities such as nuclear power plants and research facilities. Due to its radiotoxicity, an excessive amount of tritium released to the environment could directly (drinking tritiated water) or indirectly (use of tritiated water for irrigation) affect human health and the environment.

The legal limit of tritium for drinking water in Europe is 100 Bq/L, which is one of the most restrictive limits in the world. This limit is established by the EURATOM Council Directive [Eur13].

The TRITIUM project was funded to investigate the feasibility of a monitor for measuring in quasi-real time low tritium activities in water. The goal of this project is to design, build, install and commission a tritium monitor that measures tritium activities as low as 100 Bq/L in 1 hour or less. The TRITIUM monitor consists of three different parts:

1. The TRITIUM detector, where tritium measurements take place. This consists of modules of hundreds of uncladded scintillating fibers read out in parallel. Various configurations for the TRITIUM module were tested, such as different diameters of the scintillating fibers (1 mm or 2 mm) and types of photosensor (PMTs or SiPM arrays).
2. The background rejection system, which is employed to suppress the radioactive background that affects the minimum detectable activity. This is based on a lead passive shield, that reduces the soft component of cosmic rays (energies below 200 MeV) and the environmental radioactive background, and an active veto that reduces the hard component of cosmic rays (energies above 200 MeV).
3. The water purification system that removes particles and minerals present in the water sample measured by the TRITIUM detector.

The results obtained by the TRITIUM collaboration are the following:

1. During the R&D activities, the TRITIUM module and the water purification and background rejection systems, were designed, built, characterized and optimized.

Regarding the detector development, the following tasks were carried out:

- (a) Simulations were performed by the TRITIUM Aveiro team using the Geant4 package to optimize tritium detection efficiency. It

was found that in 25 cm long fibers the light signal is a 23% factor larger than in 1 m long fibers.

- (b) A surface-conditioning method for scintillating fibers, which consists in cleaving, polishing and cleaning the fibers, was developed in the frame of this PhD thesis. A polishing machine, based on Arduino technology, was developed. The objective of this machine was to automate the polishing of hundreds of fibers simultaneously, a task that requires an unaffordable time for the amount of fibers needed for the TRITIUM monitor. The surface-conditioning method resulted in an increase of the light collected by the fibers, a factor of 2 due to polishing and an additional 25% due to cleaning.
- (c) A characterization of the scintillating fibers was performed in this PhD thesis. A photon collection efficiency of $76 \pm 8\%$ was obtained, smaller than stated by the manufacturer (96%). The typical deviation of the photon collection efficiency after applying the surface-conditioning method was also measured, obtaining 2.86%, which is acceptable for tritium measurements.
- (d) A characterization of the S13360-1375 Hamamatsu SiPM was carried out in this PhD thesis. In this characterization, some of the most relevant parameters of the SiPM for detection of tritium, such as gain, breakdown voltage, temperature coefficient and others as the quenching resistance and the terminal capacitance, were measured and compared to the values provided by the manufacturer. The charge of the single photoelectron spectrum was measured with a resolution of 1% for each photoelectron peak and up to 10 photoelectron peaks were resolved.
- (e) Due to the strong dependence of the SiPM gain on temperature, a gain stabilization method was implemented in the temperature range of interest. This method consists in compensating the variation of the gain due to changes in the temperature by a

variation of the bias voltage. Indeed, the gain depends linearly on both temperature and voltage, increasing with voltage and decreasing with temperature. This allows us to stabilize the gain to its nominal value at 25°C by a variation of 59.9 ± 1.3 mV/°C of the bias voltage. This stabilization method was tested, obtaining variations of 0.1% in the SiPM gain in the [20 – 30]°C temperature range, which is the expected temperature range of operation. These results indicate that a stable operation of the SiPM readout can be obtained by an automatic implementation of a temperature dependent SiPM bias in the TRITIUM detector.

2. The background rejection system consists of an active veto and a passive shield. The latter consists of a lead castle of 5 cm thick walls, designed by the TRITIUM CENBG team and presently installed in the Arrocampo site.

A 5.5 reduction factor for cosmic ray events due to the lead shield was obtained by simulations performed in this PhD thesis. In addition, the background of the environmental radioactivity (which was not included in these simulations) would also be suppressed by the shield.

The active veto, built and characterized in this PhD thesis, consists of two parallel plastic scintillating plates of 1 cm thickness, separated 34.2 cm distance, that enclose the TRITIUM modules. Each scintillator plate was read out by two photosensors. The plastic scintillator plates were threefold wrapped in PTFE, aluminium and black tape layers. This wrapping improved by a factor 2 the light collection and produced a better response uniformity on the plate surface. In addition, the electronics settings that optimize the detection of hard cosmic events, such as discrimination thresholds and photosensor high voltage bias, were found. A hard cosmic rate of 2.5 events/s was measured, from which is drawn an efficiency of the cosmic veto of 85% by comparison to the cosmic ray rate at sea level. Finally, the dependence of the hard cosmic rate on the distance between the scintillating plates

was fitted to a second order polynomial, which allows us to change this distance without needing to perform a new calibration of the veto. A 60% reduction of the hard cosmic ray events due to the active veto was obtained through simulations. Therefore, a 92.7% suppression of the cosmic ray rate by the whole background rejection system was obtained from simulations. The actual cosmic ray suppression will be measured at the Arrocampo site.

3. Regarding the water purification system, a detailed analysis of the Arrocampo water was carried out. Due to the presence of the high concentrations of organic components at the site, a water purification system is needed. The TRITIUM LARUEX team designed and installed a water purification system at the Arrocampo site, consisting of several filtering stages that eliminate all organic matter and mineral particles of more than $1 \mu\text{m}$ size. Conductivities close to $10 \mu\text{S}/\text{cm}$ (two orders of magnitude less than the raw water) were achieved. Furthermore, the water tritium activity did not change after the purification process.
4. Four different detector prototypes, called TRITIUM-IFIC-0, TRITIUM-IFIC-1, TRITIUM-Aveiro and TRITIUM-IFIC-2, listed in chronological order, were developed by the TRITIUM collaboration. The first two prototypes, TRITIUM-IFIC-0 and TRITIUM-IFIC-1, (developed in this PhD thesis) were used as a proof of concept for the detection of tritium in water with scintillating fibers and to identify the different issues that affect the detection efficiency. The latest prototypes, TRITIUM-Aveiro (developed by the TRITIUM Aveiro team) and TRITIUM-IFIC-2 (developed in this PhD thesis), have slightly different designs. Small tritium activities were used to measure their tritium detection efficiency and MDA.

During the development of the first prototypes, a straight arrangement of the scintillating fibers was found crucial for tritium detection. In addition, a surface-conditioning method of scintillating fibers was

implemented, that improved the tritium detection efficiency. The use of a PTFE vessel was also found to improve the light collection due to its optical properties (reflectivity close to 95% for visible light). All these improvements were applied to the TRITIUM-IFIC-1 prototype, obtaining a factor 10 increase of the measured count rate of tritium with respect to the first prototype.

In the latest prototypes, two photosensors in time coincidence were employed to improve the MDA, since this reduces the photosensor noise. These two prototypes have a similar design but with subtle differences. One of the most important differences is the scintillating fiber diameter (2 mm for the TRITIUM-Aveiro prototype and 1 mm for the TRITIUM-IFIC-2 prototype). Fibers of 1 mm allow us to fit more of them in the same volume. This increases the total active area of the prototype (and, therefore its tritium detection efficiency) and the signal-to-background ratio (improving the MDA). Fibers of 2 mm may facilitate the water flow through the fiber bundle, which may increase the effective detection area. In addition, 2 mm fibers are stiffer which could be important for high water fluxes. It was obtained from simulations that the cosmic ray rate in the energy range of interest is a factor 2 higher for scintillating fibers of 2 mm. Additional measurements need to be done to decide the final fiber diameter. A possible way to take this decision could be to build two identical TRITIUM prototypes, one with 1 mm and the other with 2 mm fibers and compare their results.

The second important difference between the TRITIUM-Aveiro and TRITIUM-IFIC-2 prototypes is the type of photosensor proposed. TRITIUM-Aveiro uses PMTs and for TIRITIUM-IFIC-2, SiPM arrays are proposed. SiPM arrays have some advantages with respect to PMTs such as a higher photodetection efficiency, which would increase the detection efficiency of the TRITIUM detector. Furthermore, the SiPMs do not need high voltage, which implies a reduction of the TRITIUM monitor cost. However, SiPM arrays have some disadvantages

as the need to read out more channels and the need to implement a gain stabilization method due to the strong dependence of SiPMs gain on temperature.

The specific efficiency obtained with the TRITIUM-IFIC-2 prototype, $(141 \pm 6) \times 10^{-6} \text{ s}^{-1}\text{L} \text{ kBq}^{-1}\text{cm}^{-2}$, is an order of magnitud better than that obtained with the TRITIUM-Aveiro prototype, $(16 \pm 5) \times 10^{-6} \text{ s}^{-1}\text{L} \text{ kBq}^{-1}\text{cm}^{-2}$, most probably due to the surface-conditioning method applied to the fibers of the IFIC prototype. In addition, a MDA of 677 Bq/L was obtained for the TRITIUM-IFIC-2 prototype for an integration time of 10 min and 218 Bq/L for an integration time of 1 h. This is compared to a MDA of 29.8 kBq/L for an integration time of 1 min and 5 kBq/L for an integration time of 1 h for the TRITIUM-Aveiro prototype. A lower MDA allows us to discriminate smaller tritium activities from the background. An integration time of 1 h can still be considered a quasi-real time.

A summary of the state-of-the-art of the tritium detection in water is shown in Table 7.1, which includes the results obtained with the four different prototypes developed by the TRITIUM collaboration. As it can be seen in this table, the TRITIUM-IFIC-2 prototype ameliorates significantly the current state-of-the-art. A specific efficiency and a MDA almost an order of magnitud better than the results reported in the literature are obtained.

One of the most relevant properties of the TRITIUM monitor is scalability, which means that a lower MDA can be achieved by using a larger number of modules. The MDA of the TRITIUM monitor is expected to decrease with the square root of the number of modules. Therefore, as shown in Figure 5.21, a MDA of 100 Bq/L (goal of the TRITIUM project) could be achieved by using 5 TRITIUM-IFIC-2 modules and an integration time of 1 h. It has to be taken into account that the MDA reported in this PhD work was measured without the background rejection system. The TRITIUM MDA is expected

Reference	$\varepsilon_{det} \times 10^{-3}$ L kBq $^{-1}$ s $^{-1}$	F_{sci} cm 2	$\eta_{det} \times 10^{-6}$ L kBq $^{-1}$ s cm $^{-2}$	MDA kBq L $^{-1}$
[Mur67]	0.39	123	3.13	370
[Mog69]	4.50	> 424	< 10.6	37
[Osb70]	12	3000	4	37
[Sin85]	41	3000	13.7	< 37
[Hof92b]	2.22	\sim 100	< 22.2	25
T-IFIC-0†	2.1 ± 0.8	219	10 ± 4	100*
T-IFIC-1†	38.4 ± 1.6	402	96 ± 4	100*
T-Aveiro†	64 ± 19	4072	16 ± 5	5**
T-IFIC-2†	711 ± 27	5027	141 ± 6	0.22**

Table 7.1: Results of scintillator detectors developed for experiments (including the TRITIUM project) for tritiated water detection. This table shows the efficiency of the detector (ε_{det}), active surface (F_{sci}), specific efficiency ($\eta_{det} = \varepsilon_{det}/F_{sci}$, defined as efficiency normalized to active surface), and MDA.

* Specific activity measured, not MDA.

** MDA measured for 1 h integration time.

† This Thesis.

to improve when this system is included.

The stability of the tritium detection efficiency of the latest TRITIUM prototypes was monitored during six months, obtaining a stable behavior of the detector during this time with a relative standard deviation of 2.5% for the measured tritium rate.

5. Finally, simulations were carried out to determine the dependence of the tritium detection efficiency and activity resolution of the TRITIUM-IFIC-2 prototype on integration time and number of prototypes. These simulations, which agree with the experimental measurements, allow us to determine the number of modules needed in the TRITIUM monitor and the integration time to be used. With 5 modules and an integration time of 1 h a tritium activity resolution of 100 Bq/L is expected. This configuration is also the one that has an MDA of 100 Bq/L, goal of the TRITIUM project.

At present, the lead shielding, the water purification system and a TRITIUM-Aveiro module are installed in the Arrocampo site. Two additional TRITIUM-Aveiro modules and an active veto are planned to be installed as soon as possible. Moreover, three TRITIUM-IFIC-2 modules and an active veto are ready to be installed too. Their installation was delayed due to the coronavirus pandemic.

Chapter 8

Conclusions and Prospects

In this chapter, the main results and conclusions obtained in this PhD thesis are summarized and the prospects of the TRITIUM project are outlined:

1. A scalable modular monitor for measuring low activities of tritium in water is proposed. The goal of this monitor is to reach a sensitivity of 100 Bq/L of tritium activity, which is the maximum level allowed for drinking water by the EU directive. The modularity allows to reach the required sensitivity by selecting a given integration time and including the corresponding number of modules.
2. The IFIC modules of the TRITIUM monitor proposed consist of 1 mm diameter scintillating fibers read out by photosensors.
3. Three different prototypes of the TRITIUM-IFIC module in which different improvements were successively incorporated were developed.
4. A surface conditioning method for the scintillating fibers, consisting in specific rules for cleaving, polishing and cleaning the fibers was developed.

5. The conditioning method was applied to the selected 1 mm uncladded scintillating fibers from Saint-Gobain. An improvement of the photon collection efficiency of the fibers of a factor 2 due to polishing and an additional 25% due to cleaning was found.
6. Although most of the laboratory tests were carried out with PMTs as photosensors to read out the scintillating fibers, SiPM arrays are proposed by TRITIUM Valencia team for the final monitor.
7. A single SiPM, model S13360-1375 from Hamamatsu, selected for the monitor, was characterized. The most relevant parameters for tritium detection of this photosensor, such as breakdown voltage and gain, were measured.
8. As SiPM gain varies strongly with temperature, a stabilization method to maintain the gain constant with temperature was implemented. This method consisting in compensation of the gain variations with the bias voltage, was tested in the $[20 - 30]^\circ\text{C}$ temperature range of interest. Variations of the gain of the order of 0.1% were found which guarantees a stable operation of the photosensors.
9. In order to obtain the required tritium activity sensitivity a background rejection system consisting of a lead shield castle and an active plastic scintillator veto was proposed and implemented. The lead castle was designed and built by the TRITIUM CENBG group.
10. The passive background rejection system was simulated. A 5.5 reduction factor of the cosmic ray events measured by the TRITIUM-IFIC-2 prototype was obtained.
11. An active veto based on plastic scintillators read out by photosensors was designed and built.
12. A characterization of the active veto was done and the optimal parameters for detection of hard cosmic rays were found. A count rate of

2.5 events/s was measured, which gives an efficiency for cosmic ray detection of 85% by comparing the counting rate to the cosmic ray rate at sea level.

13. The active veto was simulated obtaining a suppression of the 60% of the cosmic rays that cross the lead shield and are measured by the TRITIUM-IFIC-2 prototype.
14. The total background suppression by the rejection system obtained from simulations for the TRITIUM-IFIC-2 prototype is 92.5%.
15. A specific efficiency $\eta = (141 \pm 6) \times 10^{-6} \text{ s}^{-1}\text{L}^{-1} \text{kBq}^{-1}\text{cm}^{-2}$ for the TRITIUM-IFIC-2 prototype was measured which is about an order of magnitude higher than specific efficiencies reported in the literature. The state-of-the-art of tritium detection with plastic scintillators is substantially improved.
16. The MDA obtained with the TRITIUM-IFIC-2 prototype is 680 Bq/L for 10 min integration time and 220 Bq/L for 1 h integration time.
17. Simulations of the detection resolution of TRITIUM-IFIC-2 monitor were done. A resolution of 250 Bq/L for an integration time of 30 min and three TRITIUM-IFIC-2 modules read out in parallel and 100 Bq/L for an integration time of 1 h and five modules were found.
18. The goal of the TRITIUM project of measuring 100 Bq/L in quasi-real time is expected to be reached with 5 TRITIUM-IFIC-2 prototypes read out in parallel and 1 h integration time.
19. At present, the water purification system and the lead shield are installed in the Arrocampo site, the final location of the TRITIUM monitor. A TRITIUM-Aveiro module is also installed, which was monitoring the tritium activities during several months.

CHAPTER 8. CONCLUSIONS AND PROSPECTS

20. The next step for the TRITIUM project is to install 2 additional TRITIUM-Aveiro prototypes which will be read out in parallel. In addition, an active veto for these three TRITIUM-Aveiro prototypes will be installed and read out in anticoincidence with them.
21. Three TRITIUM-IFIC-2 prototypes with the corresponding active veto are ready to be installed at Arrocampo site as soon as possible.

Appendices

Appendix A

Electronics for the SiPM Characterization

The electronic system designed to perform a complete characterization of the SiPM S13360-6075 model, which is the one proposed for the final TRI-TIUM monitor is shown in this appendix. This system consists of three different PCBs connected through HDMI connectors:

1. In the first PCB, shown in Figure A.1a, up to 8 SiPMs and one temperature sensor are connected. This PCB is placed inside a light-tight box from Thorlabs [Tho18]. This black box has a small hole of 1 mm diameter, prepared to introduce an optical fiber¹ to illuminate SiPMs with a LED, model 430L from Thorlabs [Tho18]. The spectrum of this LED, shown in Figure A.1d, was measured with a spectrometer. The emission peak of this LED is located at 436 nm with a FWHM of 19 nm. With the help of this LED, the light emission of the TRI-TIUM scintillating fibers was simulated to calibrate the SiPMs at the working wavelength.

¹The optical fiber used is BCF-98 from Saint-Gobain company [Sai21]

APPENDIX A. ELECTRONICS FOR THE SiPM CHARACTERIZATION

2. In the second PCB, shown in Figure A.1b, the signals of the SiPMs are summed and amplified by a factor either $G = 4187$ or $G = 10761$, depending on the input resistance of the oscilloscope, 50Ω or $1 M\Omega$ respectively. This PCB uses a differential amplifier to reduce the electronic noise of the system.
3. In the third PCB, shown in Figure A.1c, the different input and output signals are rearranged to avoid crosstalk. The input signals are the supply voltage of the SiPMs and the PCBs (± 6 V) and the output signals are the temperature sensor signal and the sum of the SiPM signals. The output signal of the third PCB is connected to an oscilloscope, model MSO44X from Tektronix [Tek21], that records the data.

APPENDIX A. ELECTRONICS FOR THE SiPM CHARACTERIZATION




Figure A.1 – The three PCBs used for SiPM characterization a) The PCB 1 used to connect up to 8 SiPMs inside the black box. b) The PCB 2 used to sum and amplify the output signals of the SiPMs. c) The PCB 3 used to rearrange the input and output signals of the system. d) The LED emission spectrum.

APPENDIX A. ELECTRONICS FOR THE SIPM
CHARACTERIZATION

Appendix B

Water Purification System

In this appendix, several pictures of the water purification system are shown.

The scheme of the whole water purification system is shown in Figure B.1.

The gross filtering stage, made of silex-antracite and granate filters, the fine filtering stage, consisting of a $20\ \mu\text{m}$ filter and an active carbon filter, the super-fine filtering, composed of a $1\ \mu\text{m}$ filter, and the UV lamps, are shown in Figure B.2.

The double phase reverse osmosis is exhibited in Figure B.3a and the containers in which pure and reject water are gathered after treatment are displayed in Figure B.3b.

The Siemens Programmable Logic Controller (PLC), used to control the water purification system, is shown in Figure B.4.

Finally, a picture of the whole water purification system is displayed in Figure B.5.

APPENDIX B. WATER PURIFICATION SYSTEM




Figure B.1 – Scheme of the water purification system.




Figure B.2 – Different stages of filtration of the water purification system.
a) The gross filtering stage. b) The fine filtering stage. c) The super-fine filtering stage.

APPENDIX B. WATER PURIFICATION SYSTEM



(a)




(b)

Figure B.3 – a) Doble phase reverse osmosis stage. b) Containers used to gather the output water of the water purification system.

Samples of raw, rejection and pure water are shown in Figure B.6, where the difference in the turbidity are distinguished.



(a)



(b)

Figure B.4 – Siemens PLC displays for the remote control of the water purification system.

APPENDIX B. WATER PURIFICATION SYSTEM



Figure B.5 – Picture of the water purification system.




Figure B.6 – Raw, reject and pure water obtained with the water purification system.

APPENDIX B. WATER PURIFICATION SYSTEM

Appendix C

Preparation of Tritiated Water Sources

Radioactive liquid sources were prepared from 1.86 g (uncertainty of 0.05%) of tritiated water, purchased from PTB [Phy]. The activity of this tritium source was 26.8 MBq/g (uncertainty of 2.24%, reference date of 1/1/2017).

This source was dissolved in 500 mL (uncertainty of 0.05%) of hiper pure water (conductivity of 0.72 $\mu\text{S}/\text{cm}$), resulting in a solution of 500 mL of tritiated water with an activity of 100 kBq/g (uncertainty of 2.24%), that is 99.7 kBq/L (uncertainty of 2.24%).

APPENDIX C. PREPARATION OF TRITIATED WATER SOURCES

Appendix D

Electronic System of TRITIUM-Aveiro prototype

The electronic system of the TRITIUM-Aveiro prototype consists of several PCB and is divided in two parts:

1. A PCB, which electronic scheme is shown in Figure D.1, designed to power the PMTs with a negative high voltage. That consists of several high voltage power supplies, model C11152-01 from Hamamatsu Photonics [K.K15]. This PCB is controloed by a DAC¹, model MAX5500 from Maxim Integrated [Int09]. An Arduino Mega controls the DAC communication and is connected to a Raspberry Pi that runs the whole system.

A graphical interface, shown Figure D.1b, was developed to set up the different options in an easy way.

2. A electronic chain consisting of several PCBs that process and analyze the system signals, which electronic scheme is shown in Figure D.2.

¹DAC, Digital-to-analog converter

APPENDIX D. ELECTRONIC SYSTEM OF TRITIUM-AVEIRO PROTOTYPE




Figure D.1 – a) The electronic scheme of the PCB designed to power the PMTs of Aveiro prototype b) The graphical user interface developed to control the prototype.

This system consists of three different lines, two of them for the PMT signals of the prototype and the other for anticoincidence with an active veto.

To test this electronic chain, a plastic scintillator of $10 \times 10 \times 1 \text{ cm}^3$ dimensions was used to simulate a veto signal. Four different vetos are being built, based on a rectangular plastic scintillators from Saint-Gobain company [SGC21c], of $50 \times 30 \times 2 \text{ cm}^3$ dimensions. The vetos are read out by 2" PMTs, model R2154-02 from Hamamatsu Photonics [K.K10]. The output signal of these PMTs goes into an OR stage, which output is connected to the veto line shown in Figure D.2. Thus, each veto is read in anticoincidence with the TRITIUM-Aveiro prototype.

Both lines, used to process and analyze the PMT signals of the prototypes, are equal and they are used to operate in time coincidence. Each PMT signal is introduced in a preamplifier model CR111 from

APPENDIX D. ELECTRONIC SYSTEM OF TRITIUM-AVEIRO PROTOTYPE




Figure D.2 – Electronic scheme that process and analyze the signal of the TRITIUM-Aveiro prototype.

CREMAT Inc. [Inc20], that shapes and pre-amplifies the signal. To reduce electronic noise and signal loss, both preamplifiers are connected as close as possible to the PMTs and they are inside aluminum boxes which act as a Faraday cage.

Each preamplifier is followed by a differentiator stage, which reduces the time width of the signal and an amplifier stage, that amplifies the signal. The amplifier is model OPA656 from Texas Instruments [Ins15].

A fast comparator, model LT111 from Linear Technology [Tec], is used to set a threshold to remove PMT signals with low amplitude (dark counts of the PMT). A MAX5500 DAC is used to configure the thresholds.

As the time width of the preamplifier output signal is too large, $200\ \mu s$, a second differentiator stage was included to reduce fake coincidences. A second comparator was added to restore a $5V$ square signal again.

Finally a tunable pulse stretcher based on an OR gate, model SN74AHC1 from Texas Instruments [Ins17], is used to set the time width of each signal to $100\ ns$. The time coincidence windows of the system is $200\ ns$.

APPENDIX D. ELECTRONIC SYSTEM OF TRITIUM-AVEIRO PROTOTYPE

The third line consists of an inverter, which gives a 5 V signal, except when a cosmic particle is detected, in which case the signal is 0 V. A stretcher is used to set the signal time width to 100 ns.

The signals from the three lines are introduced into a 3-input AND gate, model SN74LVC1G11 from Texas Instruments [Ins16], that makes a logic level comparison. With this last stage a temporal coincidence of both PMT signals in anti-coincidence with the veto signal is obtained. The output signal of this stage is connected to a pulse counter.

The GPIO pins of a Raspberry Pi are used to communicate with the system and configure the threshold levels. A graphical user interface, shown in Figure D.3, was developed to set the counter system in an easy way.




Figure D.3 – Graphical user interface used to manage the counter system.

Besides counting, this electronic system includes a voltage follower

APPENDIX D. ELECTRONIC SYSTEM OF TRITIUM-AVEIRO PROTOTYPE




Figure D.4 – a) Tritium event accepted as veto has not detected it. **b)** Background event rejected because veto has fired.

circuit connected to the preamplifier output signal that produces an energy spectrum for each PMT.

In Figure D.4 screenshots for accepted an rejected events are displayed.

APPENDIX D. ELECTRONIC SYSTEM OF TRITIUM-AVEIRO
PROTOTYPE

Bibliography

- [Ago03] Agostinelli, S. et al., *Geant4—a simulation toolkit*, Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment, **506** (2003) 250–303, URL [http://dx.doi.org/10.1016/S0168-9002\(03\)01368-8](http://dx.doi.org/10.1016/S0168-9002(03)01368-8).
- [AH99] Al-Haddad, M., Fayoumi, A. and Abu-Jarad, F., *Calibration of a liquid scintillation counter to assess tritium levels in various samples*, Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment, **438** (1999) 356–361, URL [http://dx.doi.org/10.1016/S0168-9002\(99\)00272-7](http://dx.doi.org/10.1016/S0168-9002(99)00272-7).
- [Alb17] Alberto Soler Cambra, *Contribución al Desarrollo de un Prototipo de Ddetector de Fibras Centelleadoras para la Medición de Tritio en Agua* (2017), Trabajo final de grado (TFG) de la Universidad de Valencia.
- [Ale11] Alecu, C. G. et al., *Reachable Accuracy and Precision for Tritium Measurements by Calorimetry at TLK*, Fusion Science and Technology, **60** (2011) 937–940, URL <http://dx.doi.org/10.13182/FST11-A12569>.

BIBLIOGRAPHY

- [All11] Allegro, *Driver Pololu A4988, DMOS Microstepping Driver with Translator And Overcurrent Protection*, Allegro (2011).
- [Alv39] Alvarez, W., L. and Cornog, R., *Helium and Hydrogen of Mass 3*, Phys. Rev., **56** (1939) 613–613, URL <http://dx.doi.org/10.1103/PhysRev.56.613>.
- [Amp] AmpTek, *MCA8000D, Pocket MCA, Digital Multichannel Analyzer, Manual reference*, AmpTek, Bedford Massachusetts, USA.
- [ARD] ARDUINO, *Arduino UNO REV3*, <https://www.arduino.cc/>.
- [Arg11] Argyriades, J. et al., *Spectral modeling of scintillator for the NEMO-3 and SuperNEMO detectors*, Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment, **625** (2011) 20–28, URL <http://dx.doi.org/10.1016/j.nima.2010.09.027>.
- [Aus21] Australian Government, *Australian Drinking Water Guidelines 6. National Water Quality Management Strategy*, Technical report, National Health and Medical Research Council (2021).
- [Aze20] Azevedo, C. et al., *Simulation results of a real-time in water tritium monitor*, Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment, **982** (2020) 874–877, URL <http://dx.doi.org/10.1088/0370-1298/64/10/303>.
- [Aze22] Azevedo, C. et al., *Development of a real-time tritium-in-water monitor* (2022), arXiv.
- [B. 11] B. D. Leverington and M. Anelli and P. Campana and R. Rosellini, *A 1 mm Scintillating Fibre Tracker Readout by a Multi-anode Photomultiplier* (2011), URL <http://dx.doi.org/10.48550/arXiv.1106.5649>, arXiv.

- [BD13] Bükk-Deme, A., Alecu, C., Kloppe, B. and Bornschein, B., *First results with the upgraded TLK tritium calorimeter IGC-V0.5*, Fusion Engineering and Design, **88** (2013) 2865–2869, URL <http://dx.doi.org/10.1016/j.fusengdes.2013.05.066>.
- [Ber98a] Berthold, J. W. and Jeffers, L. A., *IN-SITU TRITIUM BETA DETECTOR*, Technical Report 836625, Office of Scientific and Technical Information (OSTI.GOV), U.S. Department of Energy (1998), URL <http://dx.doi.org/10.2172/836625>.
- [Ber98b] Berthold, J. W. and Jeffers, L. A., *Phase 1 Final Report for In-Situ Tritium Beta Detector*, Technical Report 2225, Office of Scientific and Technical Information (OSTI.GOV), U.S. Department of Energy (1998), URL <http://dx.doi.org/10.2172/2225>.
- [Bir51] Birks, J. B., *Scintillations from Organic Crystals: Specific Fluorescence and Relative Response to Different Radiations*, Proceedings of the Physical Society. Section A, **64** (1951) 874–877, URL <http://dx.doi.org/10.1088/0370-1298/64/10/303>.
- [Bla91] Blauvelt, R. K., Deaton, M. R. and Gill, J. T., *Health physics manual of good practices for tritium facilities*, Technical Report 2225, Office of Scientific and Technical Information (OSTI.GOV), U.S. Department of Energy (1991), URL <http://dx.doi.org/10.2172/266889>.
- [Bor19] Born, Max and Wolf, Emil, *Principles of Optics: 60th Anniversary Edition*, Cambridge University Press, Cambridge, 7 edition (2019), URL <http://dx.doi.org/10.1017/9781108769914>.
- [Bra15] Bray, C., Pailoux, A. and Plumeri, S., *Tritiated water detection in the 2.17 μm spectral region by cavity ring down spectroscopy*, Nuclear Instruments and Methods in Physics Research Section

BIBLIOGRAPHY

- A: Accelerators, Spectrometers, Detectors and Associated Equipment, **789** (2015) 43–49, URL <http://dx.doi.org/10.1016/j.nima.2015.03.064>.
- [Bro] Brookhaven National Laboratory (BNL), *Why is the High Flux Beam Reactor Being Decommissioned?*, <https://www.bnl.gov/hfbr/decommission.php>.
- [Bui94] Buiteveld, H., Hakvoort, J. H. M. and Donze, M., *Optical properties of pure water*, in J. S. Jaffe (Ed.), *Ocean Optics XII*, Ocean Optics XII, International Society for Optics and Photonics, Honolulu, Hi, USA, 174–183, URL <http://dx.doi.org/10.1117/12.190060>.
- [Bun06] Bundesamt für Strahlenschutz (BMU), Federal Office for Radiation Protection, *Environmental Radioactivity and Radiation Exposure. Annual Report*, Technical report, Bundesamt für Strahlenschutz (2006).
- [CAE] CAEN company, *Quad Scaler And Preset Counter-Timer, N1145*, CAEN company.
- [CAE91] CAEN, *Model 84, 4 channels discriminator*, CAEN (1991).
- [Cal12] Calmon, P. and Garnier-Laplace, J., *Tritium and the environment* (2012), Institut de Radioprotection et de Sureté Nucléaire (IRSN).
- [Cam] Camberra, *Tennelec Model TC 952 High Voltage Supply*, Camberra.
- [CERa] CERN, *Coincidence Unit Type N6234, Manual reference*, CERN.
- [CERb] CERN Collaboration, *ROOT: analyzing petabytes of data, scientifically*, <https://root.cern.ch/>.

- [Che13] Chen, Z., Peng, S., Meng, D., He, Y. and Wang, H., *Theoretical study of energy deposition in ionization chambers for tritium measurements*, AIP, Review of Scinetific Instruments, **84** (2013) 650–659, URL <http://dx.doi.org/10.1063/1.4825032>.
- [Cona] Consejo de Seguridad Nuclear (CSN), *Red de Estaciones Automáticas (REA)*, <https://www.csn.es/mapa-de-valores-ambientales>.
- [Conb] Consejo de Seguridad Nuclear (CSN), *Red de Estaciones de Muestreo (REM)*, <https://www.csn.es/kprgisweb2/index.html?lang=es>.
- [Conc] Consejo de Seguridad Nuclear (CSN), Spain , <https://www.csn.es/home>.
- [Con13] Consejo de Seguridad Nuclear (CSN), (Nuclear Safety Council), *National Regulation of Radionuclides*, Technical report, (2013).
- [Dep16] Departament of Energy (DOE) of U. S., *DOE Handbook Primer on tritium safe handling practices*, U. S. Departament of Energy Washington, D.C. 20585 (2016).
- [Dep17] Departement federal de l'interieur, DFI (Federal Department of the Interior), *Ordonnance du DFI sur les substances etrangeres et les composants dans les denrees alimentaires (817.021.23)*, Technical report, The Federal Council (Swiss Government) (2017).
- [Div16a] Division, H. P. K. S. S., *MPPC Multi-Pixel Photon Counter S13360-1325*, HAMAMATSU PHOTONICS K.K., Japan (2016).
- [Div16b] Division, H. P. K. S. S., *MPPC Multi-Pixel Photon Counter S13360-6050*, HAMAMATSU PHOTONICS K.K., Japan (2016).
- [Div16c] Division, H. P. K. S. S., *MPPC Multi-Pixel Photon Counter S13360-6075*, HAMAMATSU PHOTONICS K.K., Japan (2016).

BIBLIOGRAPHY

- [Dr.20] Dr. Linda Capuano, *International Energy Outlook 2013 with projections to 2050*, Technical report, Center for Strategic and International Studies, U. E. Energy Information Administration, U.S. Department of Energy, Washington, DC 20585 (2020).
- [DYC] DYCOMETAL, *DYCOMETAL model CCK 85*, DYCOMETAL.
- [ea20] et al., P. Z., *Particle Data Grup), PDG, Prog. Theor. Exp. Phys.* (2020).
- [Ene19] Energy News, *Estados Unidos anuncia una inversión de 35 millones para las centrales nucleares*, <https://www.energynews.es/estados-unidos-centrales-nucleares/> (2019).
- [Epi20] Epic Crystal, *Plastic scintillator of Epic Crystal, Manual reference*, Epic Crystal (2020).
- [Eur13] European Atomic Energy Community, EURATOM, *Laying down requirements for the protection of the health of the general public with regard to radioactive substances in water intended for human consumption*, Technical report, Council directive 2013/15/euratom (2013).
- [EUR14] EUROATOM, *Council Directive 2013/59/Euratom of 5 December 2013*, <https://eur-lex.europa.eu/eli/dir/2013/59/oj> (2014).
- [Eur16] Europa Press, *China construirá al menos 60 centrales nucleares en la próxima década*, <https://www.europapress.es/internacional/noticia-china-construira-menos-60-centrales-nucleares-proxima.html> (2016).
- [Eva95] Evans, R. D., *The Atomic Nucleus*, McGraw-Hill, Inc., Bom-bai (1995), URL https://www.academia.edu/28858622/Evans_The_atomic_nucleus.

- [Fer19] Fermilab, *Tritium at Fermilab*, <https://www.fnal.gov/pub/tritium/> (2019).
- [GEA] GEANT4 Collaboration, *Geant4: A toolkit for the simulation of the passage of particles through matter*, <https://geant4.web.cern.ch/node/1>.
- [Gle10] Glenn F. Knoll, *Radiation Detection and Measurement*, 4th Edition, volume 21, John Wiley & Sons, Inc. (2010), URL <https://www.wiley.com/en-sg/Radiation+Detection+and+Measurement,+4th+Edition-p-9780470131480>.
- [GRB] GRBL, *GRBL package of Arduino*, <https://github.com/grbl/grbl/wiki>.
- [Hag07] Hagmann, C., Lange, D. and Wright, D., *Cosmic-ray shower generator (CRY) for Monte Carlo transport codes*, in IEEE (Ed.), *2007 IEEE Nuclear Science Symposium Conference Record*, IEEE Nuclear Scince Symposium Conference Record, IEEE, Honolulu, Hi, USA, 1143–1146, URL <http://dx.doi.org/10.1109/NSSMIC.2007.4437209>.
- [Hai14] Haight, R., Wermer, J. and Fikani, M., *Tritium Production by Fast Neutrons on Oxygen: An Integral Experiment*, Journal of Nuclear Science and Technology, **39** (2014) 1232–1235, URL <http://dx.doi.org/10.1080/00223131.2002.10875326>.
- [HAM16] HAMAMATSU PHOTONICS K.K. Solid State Division, *MPPC Multi-Pixel Photon Counter) S13360-1375*, HAMAMATSU PHOTONICS K.K., Japan (2016).
- [Han] Hanna Instruments, *Multiparamétrico con opciones GPS, sonda autoregistradora, turbidez e ISE*, Hanna Instruments.

BIBLIOGRAPHY

- [Hof92a] Hofstetter, K. J. and Wilson, H. T., *Aqueous Effluent Tritium Monitor Development*, Fusion Technology, **21** (1992) 446–451, URL <http://dx.doi.org/10.13182/FST92-A29786>.
- [Hof92b] Hofstetter, K. J. and Wilson, H. T., *Aqueous Effluent Tritium Monitor Development*, Fusion Technology, **21** (1992) 446–451, URL <http://dx.doi.org/10.13182/FST92-A29786>.
- [Hof92c] Hofstetter, K. J. and Wilson, H. T., *Continuous tritium effluent water monitor at the Savannah River Site*, Technical Report WSRC-MS-92-163; CONF-9209261-1 ON: DE93002157, Office of Scientific and Technical Information (OSTI.GOV), U.S. Department of Energy (1992).
- [Hou18] Hou, X., *Tritium and ^{14}C in the Environment and Nuclear Facilities: Sources and Analytical Methods*, Journal of Nuclear Fuel Cycle and Waste Technology, **16** (2018) 11–39, URL <http://dx.doi.org/10.7733/jnfcwt>.
- [Hyd16] Hydro Quebec, *Réultats du programme de surveillance de l'environnement du site de Gentilly-2*, Technical report, National Library (2016).
- [IGU] IGUS, Plastics for longer life, *Carro transversal Drylin-SLW*, <https://www.igus.es/info/linear-guides-drylin-cross-slide>.
- [Inc20] Inc., C., *CR 111-R2.1 Charge sensitive preamplifier*, CREMAT Inc., 07 (2020).
- [Ind] Indistroan fiber optical, *POF Cutter block*, <https://i-fiberoptics.com/tool-detail.php?id=105&cat=cutters>.
- [Ins15] Instruments, T., *OPA656 Wideband, Unity-Gain Stable, FET-Input Operational Amplifier*, Texas Instruments, 09 (2015).

- [Ins16] Instruments, T., *SN74LVC1G11DBVR Single 3-Input Positive-AND Gate*, Texas Instruments, 11 (2016).
- [Ins17] Instruments, T., *SN74AHC1G32 Single 2-Input Positive-OR Gate*, Texas Instruments (2017).
- [Ins18] Institut de radioprotection et de sûreté nucléaire (IRSN), *Bilan de l'état radiologique de l'environnement français de 2015 à 2017*, Technical report, Réseau National de mesures de la radioactivité de l'environnementement (2018).
- [Inta] International Atomic Energy Agency (IAEA), *Nuclear Data Services*, <https://www-nds.iaea.org/>.
- [Intb] International Commission on Radiological Protection (ICRP), <https://www.icrp.org/>.
- [Intc] International Commission on Radiological Units and Measurements (ICRU), <https://www.icru.org/>.
- [Intd] International Society of Radiology (ISR), <https://www.isradiology.org/>.
- [Int91] International Commission on Radiological Protection (ICRP), *1990 Recommendations of the International Commission on Radiological Protection*, volume 21, Pergamon Press, Oxford (1991), URL <https://www.icrp.org/publication.asp?id=icrp%20publication%2060>.
- [Int96] International Commission on Radiological Protection (ICRP), *Age-dependent doses to members of the public from intake of radionuclides: Part 5. Compilation of ingestion and inhalation dose coefficients.*, volume 26, Pergamon Press, Oxford, United Kingdom (1996), URL <https://www.icrp.org/publication.asp?id=ICRP%20Publication%2072>.

BIBLIOGRAPHY

- [Int07] International Council for Science (UCSU), World Data System, *NRB-99 Radiation Safety Norms*, Technical report, World Data Centers (2007).
- [Int09] Integrated, M., *Low-Power, Quad, 12-Bit, Voltage-Output DACs with Serial Interface*, Maxim Integrated (2009).
- [Int14] International Energy Agency (IEA), *Key World Energy Statistics*, <https://www.iea.org/publications/freepublications/publication/KeyWorld2014.pdf> (2014).
- [Int19] Integrated Circuits, *Driver TMC2208, Step/Dir Drivers for Two-Phase Bipolar Stepper Motors up to 2A peak- StealthChop for Quiet Movement- UART Interface Option*, Integrated Circuits (2019).
- [IT] ISO-TECH, *ISO-TECH GPS-4303 Digital Bench Power Supply With UKAS Calibration, 4 Output*, ISO-TECH.
- [JB10] Jean-Baptiste, P. et al., *3He mass spectrometry for very low-level measurement of organic tritium in environmental samples*, Journal of Environmental Radioactivity, **101** (2010) 185–190, URL <http://dx.doi.org/10.1016/j.jenvrad.2009.10.005>.
- [Keh] Kehtley, *Model 6517B Electrometer User's Manual*, Kehtley.
- [KEI] KEITHLEY, a tektronix company, *Model 6487 Picoammeter/voltage source*, KEITHLEY.
- [Khe02] Kherani, N., *An alternative approach to tritium-in-water monitoring*, Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment, **484** (2002) 650–659, URL [http://dx.doi.org/10.1016/S0168-9002\(01\)02008-3](http://dx.doi.org/10.1016/S0168-9002(01)02008-3).
- [K.K10] K.K., H. P., *Photomultiplier tube R2154-02 2*, HAMAMATSU PHOTONICS K.K., Japan (2010).

- [K.K15] K.K., H. P., *High Voltage Power Supply C11152-01*, HAMAMATSU PHOTONICS K.K., Japan (2015).
- [K.K19] K.K., H. P., *Photomultiplier tube R8520-406/R8520-506*, HAMAMATSU PHOTONICS K.K., Japan (2019).
- [Kno99] Knoll, G. F., *Radiation Detection and Measurement*, John Wiley and Sons, Inc., New York, Chichester, Weinheim, Brisbane, Toronto, Singapore, 3 edition (1999).
- [Law06] Law, S. et al., *Cleaving of microstructured polymer optical fibres*, Optics Communications, **258** (206) 193–202, URL <http://dx.doi.org/10.1016/j.optcom.2005.08.011>.
- [LeC] LeCroy, *Model 465 Coincidence Unit, Manual reference*, LeCroy.
- [Lee18] Lee, J. et al., *Tissue distribution, excretion and effects on genotoxicity of tritium following oral administration to rats*, Nuclear Engineering and Technology, **51**, URL <http://dx.doi.org/10.1016/j.net.2018.09.013>.
- [Leo94] Leo, W. R., *Techniques for Nuclear and Particle Physics Experiments: a How-to Approach*, Springer-Verlag Berlin Heidelberg GmbH, New York, 2 edition (1994), URL <http://dx.doi.org/10.13182/FST92-A29786>.
- [Lin20] Lin, Z., *Simulation and Optimization Design of SiC-Based PN Betavoltaic Microbattery Using Tritium Source*, Crystals, **10** (2020) 105, URL <http://dx.doi.org/10.3390/crust10020105>.
- [Mar72] Martin, J. R. and Koranda, J. J., *Biological Half-Life Studies of Tritium in Chronically Exposed Kangaroo Rats*, Radiation Research, **50** (1972) 426–440, URL <http://dx.doi.org/10.2307/3573500>.

BIBLIOGRAPHY

- [Mas21] Masuda, T. and Yoshioka, T., *Estimation of radiation dose from ingested tritium in humans by administration of deuterium-labelled compounds and food*, Scientific Reports, **11** (2021) 1232–1235, URL <http://dx.doi.org/10.1038/s41598-021-82460-5>.
- [Mat07] Matsuyama, M., Torikai, Y., Hara, M. and Watanabe, K., *New technique for non-destructive measurements of tritium in future fusion reactors*, International Atomic Energy Agency (IAEA), **47** (2007) S464–S468, URL <http://dx.doi.org/10.1088/0029-5515/47/7/s09>.
- [Mat08] Matsuyama, M., *Development of a new detection system for monitoring high-level tritiated water*, Fusion Engineering and Design, **83** (2008) 1438–1441, URL <http://dx.doi.org/10.1016/j.fusengdes.2008.05.023>, proceedings of the Eight International Symposium of Fusion Nuclear Technology.
- [Mer15] Mertens, S. et al., *Sensitivity of next-generation tritium beta-decay experiments for keV-scale sterile neutrinos*, Journal of Cosmology and Astroparticle Physics, **2015** (2015) 020–020, URL <http://dx.doi.org/10.1088/1475-7516/2015/02/020>.
- [Mog69] Moghissi, A., Kelley, H., Phillips, C. and Regnier, J., *A tritium monitor based on scintillation*, Nuclear Instruments and Methods, **68** (1969) 159, URL [http://dx.doi.org/10.1016/0029-554X\(69\)90705-8](http://dx.doi.org/10.1016/0029-554X(69)90705-8).
- [Mur67] Muramatsu, M., Koyano, A. and Tokunaga, N., *A scintillation probe for continuous monitoring of tritiated water*, Nuclear Instruments and Methods, **54** (1967) 325–326, URL [http://dx.doi.org/10.1016/0029-554X\(67\)90645-3](http://dx.doi.org/10.1016/0029-554X(67)90645-3).
- [Nan06] Nanotec, *ST4209S1404-A - STEPPER MOTOR NEMA 17*, Nanotec (2006).

- [Nie15] Niemes, S., Sturm, M., Michling, R. and Bornschein, B., *High Level Tritiated Water Monitoring by Bremsstrahlung Counting Using a Silicon Drift Detector*, Fusion Science and Technology, **67** (2015) 507–510, URL <http://dx.doi.org/10.13182/FST14-T66>.
- [Nuc93] Nuclear Energy Agency (NEA), *Radiation and Nuclear Safety Authority. Radioactivity of Household Water*, Technical report, (1993).
- [Off07] Office of Environmental Health Hazard Assessment (OEHHA), *Public Health Goals for Chemicals in Drinking Water-Tritium*, Technical report, OEHHA, California Environmental Protection Agency (2007).
- [Oli34] Oliphant, M. L., Harteck, P. and Rutherford, E., *Transmutation Effects observed with Heavy Hydrogen*, The Royal Society Publishing, **133** (1934) 23–28, URL <http://dx.doi.org/10.1098/rspa.1934.0077>.
- [Ont94] Ontario Ministry of the Environment, *Ontario Drinking Water Objectives*, Technical report, The Federal Council (Swiss Government) (1994).
- [ORTa] ORTEC, *Model 416A Gate and Delay Generator, Manual reference*, ORTEC, South Illinois Ave., Oak Ridge USA.
- [ORTb] ORTEC, *Model 575A Amplifier, Manual reference*, ORTEC, South Illinois Ave., Oak Ridge USA.
- [ORTc] ORTEC, *Model 671 Spectroscopy Amplifier, Manual reference*, ORTEC, South Illinois Ave., Oak Ridge USA.
- [ORTd] ORTEC, *Model 9326 FastPreamplifier, Manual reference*, ORTEC, South Illinois Ave., Oak Ridge USA.

BIBLIOGRAPHY

- [ORTe] ORTEC, *Model CF8000 Octal Constant-Fraction Discriminator, Manual reference*, ORTEC, South Illinois Ave., Oak Ridge USA.
- [Osb70] Osborne, R., *Detector for tritium in water*, Nuclear Instruments and Methods, **77** (1970) 170–172, URL [http://dx.doi.org/10.1016/0029-554X\(70\)90596-3](http://dx.doi.org/10.1016/0029-554X(70)90596-3).
- [OSI] OSI Optoelectronics, *Characteristics and Applications*, https://osioptoelectronics.com/standard-products/default.aspx?gclid=EAIIaiQobChMIkYrLif_37QIVDNTtCh3NuwpkEAAYASAAEgKMJ_D_BwE.
- [OSO17] OSOYOO, *CNC shield V3.0*, OSOYOO (2017).
- [Pal07] Palomo, M., Peñalver, A., Aguilar, C. and Borrull, F., *Tritium activity levels in environmental water samples from different origins*, Applied Radiation and Isotopes, **65** (2007) 1048–1056, URL <http://dx.doi.org/10.1016/j.apradiso.2007.03.013>.
- [PET] PETsys, *PETsys Electronics*, <https://www.petseyelectronics.com/web/private/login>.
- [PF81] Pietrzak-Flis, Z., Radwan, I., Major, Z. and Kowalska, M., *Tritium Incorporation in Rats Chronically Exposed to Tritiated Food or Tritiated Water for Three Successive Generations*, Journal of Radiation Research, **22** (1981) 434–442, URL <http://dx.doi.org/10.1269/jrr.22.434>.
- [Phi] Philips Scientific, *Model 740 Quad Linear Fan-In/Out, Manual reference*, Philips Scientific.
- [Phy] Physikalisch-Technische Bundesanstalt (PTB), <https://www.ptb.de/cms/>.
- [Plo] Plot Nuclear Data (NADS), *Physics simulation packages, CRY (cosmic-ray particle showers)*, <https://nuclear.llnl.gov/simulation/>.

- [Ras] Raspberry Pi Foundation, <https://www.raspberrypi.org/>.
- [Rat00] Ratnakaran, M., Revetkar, R. M., Samant, R. K. and Abani, M. C. (Eds.), *A Real-time Tritium-In-Water Monitor for Measurement Of Heavy Water Leak To The Secondary Coolant, SPECIFIC NUCLEAR REACTORS AND ASSOCIATED PLANTS (S21)*, volume 32, International Atomic Energy Agency (IAEA), Japan Health Physics Society, Japan (2000), URL https://inis.iaea.org/search/search.aspx?orig_q=RN:32015986.
- [Red19] Red Eléctrica de España, *El Sistema Eléctrico Español*, <https://www.ree.es/es/datos/\protect\discretionary{\char\hyphenchar\font}{}{}publicaciones/informe-anual-sistema/\protect\discretionary{\char\hyphenchar\font}{}{}informe-del-sistema-electrico-espanol-2019> (2019).
- [Roi10] Roithner LaserTechnik GmbH, *LED435-03, 20 mW, 20 mA*, Roithner LaserTechnik GmbH (2010).
- [SAG12] SAGAWA, H. and URABE, I., *Estimation of Absorbed Dose Rates in Air Based on Flux Densities of Cosmic Ray Muons and Electrons on the Ground Level in Japan*, Journal of Nuclear Science and Technology, **38** (2012) 1103–1108, URL <http://dx.doi.org/10.1080/18811248.2001.9715142>.
- [Sai] Saint-Gobain Crystals, Inc., *BC-630, Silicone Optical Grease*, <https://www.crystals.saint-gobain.com/>.
- [Sai21] Saint-Gobain Crystals, Inc., *Optical fiber BCF-98, Manual reference*, Saint-Gobain Crystals, Inc., United States (2021).
- [San] San Nopco company, *Wetting property*, <https://www.sannopco.co.jp/eng/products/function/function4.php>.

BIBLIOGRAPHY

- [Saw00] Sawodni, A., Pazdur, A. and Pawlyta, J., *Measurements of Tritium Radioactivity in Surface Water on the Upper Silesia Region*, Journal of Nuclear Fuel Cycle and Waste Technology, **18** (2000) 23–28, URL <http://yadda.icm.edu.pl/baztech/element/bwmeta1.element.baztech-article-BAT3-0035-0005>.
- [Sen17] SensL sense light, *Introduction to the SPM TECHNICAL NOTE*, SensL sense light (2017).
- [SGC21a] Saint-Gobain Crystals, I., *Scintillating Optical Fibers, It's What's Inside that Counts*, Saint-Gobain Crystals, Inc., United States (2021).
- [SGC21b] Saint-Gobain Crystals, I., *Scintillating Optical Fibers, It's What's Inside that Counts*, Saint-Gobain Crystals, Inc., United States (2021).
- [SGC21c] Saint-Gobain Crystals, I., *Scintillating plastic grown with polymeric method*, Saint-Gobain Crystals, Inc., United States (2021).
- [Sha97] Shah, K. S., Gothoskar, P., Farrell, R. and Gordon, J., *High efficiency detection of tritium using silicon avalanche photodiodes*, IEEE Transactions on Nuclear Science, **44** (1997) 774–776, URL <http://dx.doi.org/10.1109/23.603750>.
- [Sig94] Sigg, R., McCarty, J., Livingston, R. and Sanders, M., *Real-time aqueous tritium monitor using liquid scintillation counting*, Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment, **353** (1994) 494–498, URL [http://dx.doi.org/10.1016/0168-9002\(94\)91707-8](http://dx.doi.org/10.1016/0168-9002(94)91707-8).
- [Sin85] Singh, A., Ratnakaran, M. and Vohra, K., *An on-line tritium-in-water monitor*, Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and

- Associated Equipment, **236** (1985) 159–164, URL [http://dx.doi.org/10.1016/0168-9002\(85\)90141-X](http://dx.doi.org/10.1016/0168-9002(85)90141-X).
- [Spi97] Spinelli, A. and Lacaita, A., *Physics and numerical simulation of single photon avalanche diodes*, IEEE Transactions on Electron Devices, **44** (1997) 1931–1943, URL <http://dx.doi.org/10.1109/16.641363>.
- [SR15] Sáez-Rodríguez, D., Nielsen, K., Bang, O. and Webb, D. J., *Simple Room Temperature Method for Polymer Optical Fibre Cleaving*, Journal of Lightwave Technology, **33** (2015) 4712–4716, URL <http://dx.doi.org/10.1109/JLT.2015.2479365>.
- [Str93] Straume, T. and Carsten, A. L., *Tritium radiobiology and relative biological effectiveness*, Health Physics, **65** (1993) 657–72, URL <http://dx.doi.org/10.1097/00004032-199312000-00005>.
- [Szu15] Szucs, T. et al., *Cosmic-ray-induced background intercomparison with actively shielded HPGe detectors at underground locations*, The European Physical Journal A, **51**, URL <http://dx.doi.org/10.1140/epja/i2015-15033-0>.
- [Tec] Technology, L., *LT111A Voltage Comparator*, Linear Technology.
- [Tek21] Tektronix, *Mixed Signal Oscilloscope, Model MSO44*, Tektronix (2021).
- [TEL17] TELEDYNE LECROY, *WaveRunner 6 Zi Oscilloscopes 400 MHz – 4 GHz*, TELEDYNE LECROY (2017).
- [Thea] The International Atomic Energy Agency (IAEA), <https://www.iaea.org/>.
- [Theb] The United Nations Scientific Committee on the Effects of Atomic Radiation (UNSCEAR), <https://www.unscear.org/>.

BIBLIOGRAPHY

- [The96] Theodórsson, P., *Measurement of weak radioactivity*, World Scientific (1996), URL <http://dx.doi.org/10.1142/2800>.
- [Thoal] Thorlabs, Inc, <https://www.thorlabs.com/>.
- [Thob] Thorlabs Inc., *BK5 - Black Nylon, Polyurethane-Coated Fabric, 5'x9' (1.5m x 2.7m) x 0.005" (0.12 mm) Thick*, Thorlabs Inc.
- [Tho06] Thorlabs Inc., *Guide to connectorization and polishing optical fibers*, Thorlabs Inc. (2006).
- [Tho18] Thorlabs, Inc., *LED430L - 430 nm LED with a Glass Lens, 8 mW, TO-18*, Thorlabs, Inc. (2018).
- [Tri] Tritium Collaboration, *Tritium, Interreg Sudoe Program*, <https://www.interreg-sudoe.eu/gbr/projects/the-approved-projects/158-design-construction-and-commissioning-of-a-low-level-tr>
- [Uni00] United States Environmental Protection Agency (US EPA), *Drinking Water Requirements for States and Public Water Systems. Radionuclides Rule*, Technical report, (2000).
- [Val07] Valverde Hermosilla, M., *Interacción neutrino-núcleo a energías intermedias*, Ph.D. thesis, University of Granada, Granada, Spain (2007).
- [Wen] Wenzel Electronik, *Model N 1330-4 High Voltage Power Supply*, Wenzel Electronik.
- [Wor17] World Health Organization (WHO), *Guidelines for Drinking-Water Quality*, World Health Organization (WHO), Geneva (2017).
- [Wor20a] World Nuclear Association, *Three mile island accident*, www.world-nuclear.org/information-library/

- safety-and-security/safety-of-plants/
three-mile-island-accident.aspx (2020).
- [Wor20b] World Press, *Tritium decay image*, <https://conexioncausal.wordpress.com> (2020).
- [Yah13] Yahlali, N., Fernandes, L. and Lorca, D., *Characterization of UV-enhanced SiPMs for imaging in a high pressure xenon electroluminescent TPC*, in ANIMMA (Ed.), *2013 3rd International Conference on Advancements in Nuclear Instrumentation, Measurement Methods and their Applications (ANIMMA)*, IEEE, IEEE, France, 1–12, URL <http://dx.doi.org/10.1109/ANIMMA.2013.6728092>.