

14 SEER Single-Package Air Conditioner and Gas Furnace System

3 Phase Airflow Table

Slip Sheet



SPP14SEERYAC-01SS

NOTE: This table replaces Table 11 and Table 12 in the Installation Instructions and 3-Phase Dry Coil Air Delivery Table in the Product Data.

Table 1 – Dry Coil Air Delivery* - Horizontal and Downflow Discharge, 208/230 VAC 3-Phase Units

Unit	Heating Rise Range	Motor Speed	Wire Color		External Static Pressure ("WC)								
					0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
36060	25 - 55°F (14 - 31°C)	Low	Blue	CFM	1056	982	911	882	812	740	667	564	486
				Heating Rise (°F)	42	45	48	50	54	NA	NA	NA	NA
				Heating Rise (°C)	23	25	27	28	30	NA	NA	NA	NA
		Med-Low ¹	Pink	CFM	1174	1107	1045	985	914	890	825	760	673
				Heating Rise (°F)	37	40	42	45	48	49	53	NA	NA
				Heating Rise (°C)	21	22	23	25	27	27	30	NA	NA
		Medium ²	Red	CFM	1246	1195	1148	1081	1019	953	884	859	795
				Heating Rise (°F)	35	37	38	41	43	46	50	51	55
				Heating Rise (°C)	20	20	21	23	24	26	28	28	31
		Med-High	Orange	CFM	1361	1299	1229	1210	1152	1092	1025	958	889
				Heating Rise (°F)	32	34	36	36	38	40	43	46	50
				Heating Rise (°C)	18	19	20	20	21	22	24	26	28
		High	Black	CFM	1596	1542	1482	1424	1362	1304	1238	1173	1201
				Heating Rise (°F)	28	29	30	31	32	34	36	38	37
				Heating Rise (°C)	15	16	16	17	18	19	20	21	20
36090	35 - 65°F (19 - 36°C)	Low	Blue	CFM	1056	982	911	882	812	740	667	564	486
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low	Pink	CFM	1174	1107	1045	985	914	890	825	760	673
				Heating Rise (°F)	56	59	63	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	31	33	35	NA	NA	NA	NA	NA	NA
		Medium ²	Red	CFM	1246	1195	1148	1081	1019	953	884	859	795
				Heating Rise (°F)	53	55	57	61	65	NA	NA	NA	NA
				Heating Rise (°C)	29	31	32	34	36	NA	NA	NA	NA
		Med-High ¹	Orange	CFM	1361	1299	1229	1210	1152	1092	1025	958	889
				Heating Rise (°F)	48	51	54	54	57	60	64	NA	NA
				Heating Rise (°C)	27	28	30	30	32	33	36	NA	NA
		High	Black	CFM	1596	1542	1482	1424	1362	1304	1238	1173	1201
				Heating Rise (°F)	41	43	44	46	48	50	53	56	55
				Heating Rise (°C)	23	24	25	26	27	28	30	31	30
42060	25 - 55°F (14 - 31°C)	Low	Blue	CFM	1001	902	833	777	717	650	575	527	466
				Heating Rise (°F)	43	48	52	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	24	27	29	NA	NA	NA	NA	NA	NA
		Med-Low ¹	Pink	CFM	1016	950	902	842	783	721	655	590	541
				Heating Rise (°F)	43	46	48	51	55	NA	NA	NA	NA
				Heating Rise (°C)	24	25	27	29	31	NA	NA	NA	NA
		Medium	Red	CFM	1403	1358	1316	1265	1217	1167	1116	1067	1012
				Heating Rise (°F)	31	32	33	34	36	37	39	41	43
				Heating Rise (°C)	17	18	18	19	20	21	22	23	24
		Med-High ²	Orange	CFM	1461	1411	1367	1327	1275	1220	1174	1127	1074
				Heating Rise (°F)	30	31	32	33	34	36	37	38	40
				Heating Rise (°C)	16	17	18	18	19	20	21	21	22
		High	Black	CFM	1575	1528	1488	1447	1406	1360	1314	1264	1213
				Heating Rise (°F)	28	28	29	30	31	32	33	34	36
				Heating Rise (°C)	15	16	16	17	17	18	18	19	20

Table 1 – Dry Coil Air Delivery* - Horizontal and Downflow Discharge, 208/230 VAC 3-Phase Units

Unit	Heating Rise Range	Motor Speed	Wire Color		External Static Pressure ("WC)								
					0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
42090	35 - 65°F (19 - 36°C)	Low	Blue	CFM	1001	902	833	777	717	650	575	527	466
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low	Pink	CFM	1016	950	902	842	783	721	655	590	541
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Medium ¹	Red	CFM	1403	1358	1316	1265	1217	1167	1116	1067	1012
				Heating Rise (°F)	48	49	51	53	55	57	60	63	NA
				Heating Rise (°C)	26	27	28	29	31	32	33	35	NA
		Med-High ²	Orange	CFM	1461	1411	1367	1327	1275	1220	1174	1127	1074
				Heating Rise (°F)	46	47	49	50	52	55	57	59	62
				Heating Rise (°C)	25	26	27	28	29	30	32	33	35
		High	Black	CFM	1575	1528	1488	1447	1406	1360	1314	1264	1213
				Heating Rise (°F)	42	44	45	46	48	49	51	53	55
				Heating Rise (°C)	24	24	25	26	26	27	28	29	31
48090	35 - 65°F (19 - 36°C)	Low	Blue	CFM	644	552	461	376	301	235	---	---	---
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low ¹	Pink	CFM	1430	1386	1347	1302	1258	1208	1160	1114	1065
				Heating Rise (°F)	47	48	50	51	53	55	58	60	63
				Heating Rise (°C)	26	27	28	29	30	31	32	33	35
		Medium ²	Red	CFM	1658	1622	1585	1549	1512	1476	1442	1402	1360
				Heating Rise (°F)	40	41	42	43	44	45	46	48	49
				Heating Rise (°C)	22	23	23	24	25	25	26	27	27
		Med-High	Orange	CFM	1945	1913	1867	1829	1792	1758	1717	1688	1645
				Heating Rise (°F)	NA	35	36	37	37	38	39	40	41
				Heating Rise (°C)	NA	19	20	20	21	21	22	22	23
		High	Black	CFM	2201	2172	2138	2108	2074	2041	1970	1867	1764
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	36	38
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	20	21
48115	30 - 60°F (17 - 33°C)	Low	Blue	CFM	644	552	461	376	301	235	---	---	---
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low	Pink	CFM	1430	1386	1347	1302	1258	1208	1160	1114	1065
				Heating Rise (°F)	60	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	33	NA	NA	NA	NA	NA	NA	NA	NA
		Medium ²	Red	CFM	1658	1622	1585	1549	1512	1476	1442	1402	1360
				Heating Rise (°F)	51	53	54	55	56	58	59	NA	NA
				Heating Rise (°C)	29	29	30	31	31	32	33	NA	NA
		Med-High ¹	Orange	CFM	1945	1913	1867	1829	1792	1758	1717	1688	1645
				Heating Rise (°F)	44	45	46	47	48	48	50	50	52
				Heating Rise (°C)	24	25	25	26	26	27	28	28	29
		High	Black	CFM	2201	2172	2138	2108	2074	2041	1970	1867	1764
				Heating Rise (°F)	39	39	40	40	41	42	43	46	48
				Heating Rise (°C)	22	22	22	22	23	23	24	25	27

Table 1 – Dry Coil Air Delivery* - Horizontal and Downflow Discharge, 208/230 VAC 3-Phase Units

Unit	Heating Rise Range	Motor Speed	Wire Color		External Static Pressure ("WC)								
					0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
48130	35 - 65°F (19 - 36°C)	Low	Blue	CFM	644	552	461	376	301	235	---	---	---
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low	Pink	CFM	1430	1386	1347	1302	1258	1208	1160	1114	1065
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Medium ²	Red	CFM	1658	1622	1585	1549	1512	1476	1442	1402	1360
				Heating Rise (°F)	57	59	60	61	63	64	NA	NA	NA
				Heating Rise (°C)	32	33	33	34	35	36	NA	NA	NA
		Med-High ¹	Orange	CFM	1945	1913	1867	1829	1792	1758	1717	1688	1645
				Heating Rise (°F)	49	50	51	52	53	54	55	56	58
				Heating Rise (°C)	27	28	28	29	30	30	31	31	32
		High	Black	CFM	2201	2172	2138	2108	2074	2041	1970	1867	1764
				Heating Rise (°F)	43	44	45	45	46	47	48	51	54
				Heating Rise (°C)	24	24	25	25	26	26	27	28	30
60090	35 - 65°F (19 - 36°C)	Low	Blue	CFM	839	768	697	625	551	486	422	360	306
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low ¹	Pink	CFM	1403	1361	1320	1276	1236	1192	1145	1099	1054
				Heating Rise (°F)	48	49	51	52	54	56	58	61	63
				Heating Rise (°C)	26	27	28	29	30	31	32	34	35
		Medium ²	Red	CFM	1822	1788	1757	1726	1690	1657	1623	1589	1553
				Heating Rise (°F)	37	37	38	39	40	40	41	42	43
				Heating Rise (°C)	20	21	21	22	22	22	23	23	24
		Med-High	Orange	CFM	1982	1940	1900	1859	1816	1775	1739	1701	1655
				Heating Rise (°F)	NA	NA	35	36	37	38	38	39	40
				Heating Rise (°C)	NA	NA	20	20	20	21	21	22	22
		High	Black	CFM	2271	2241	2206	2171	2134	2080	1973	1857	1746
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	36	38
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	20	21
60115	30 - 60°F (17 - 33°C)	Low	Blue	CFM	839	768	697	625	551	486	422	360	306
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low	Pink	CFM	1403	1361	1320	1276	1236	1192	1145	1099	1054
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Medium ²	Red	CFM	1822	1788	1757	1726	1690	1657	1623	1589	1553
				Heating Rise (°F)	47	48	48	49	50	51	52	54	55
				Heating Rise (°C)	26	26	27	27	28	29	29	30	30
		Med-High ¹	Orange	CFM	1982	1940	1900	1859	1816	1775	1739	1701	1655
				Heating Rise (°F)	43	44	45	46	47	48	49	50	51
				Heating Rise (°C)	24	24	25	25	26	27	27	28	29
		High	Black	CFM	2271	2241	2206	2171	2134	2080	1973	1857	1746
				Heating Rise (°F)	38	38	39	39	40	41	43	46	49
				Heating Rise (°C)	21	21	21	22	22	23	24	25	27

Table 1 – Dry Coil Air Delivery* - Horizontal and Downflow Discharge, 208/230 VAC 3-Phase Units

Unit	Heating Rise Range	Motor Speed	Wire Color		External Static Pressure ("WC)								
					0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
60130	35 - 65°F (19 - 36°C)	Low	Blue	CFM	839	768	697	625	551	486	422	360	306
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Med-Low	Pink	CFM	1403	1361	1320	1276	1236	1192	1145	1099	1054
				Heating Rise (°F)	NA	NA	NA	NA	NA	NA	NA	NA	NA
				Heating Rise (°C)	NA	NA	NA	NA	NA	NA	NA	NA	NA
		Medium ²	Red	CFM	1822	1788	1757	1726	1690	1657	1623	1589	1553
				Heating Rise (°F)	52	53	54	55	56	57	59	60	61
				Heating Rise (°C)	29	30	30	31	31	32	33	33	34
		Med-High ¹	Orange	CFM	1982	1940	1900	1859	1816	1775	1739	1701	1655
				Heating Rise (°F)	48	49	50	51	52	54	55	56	58
				Heating Rise (°C)	27	27	28	28	29	30	30	31	32
		High	Black	CFM	2271	2241	2206	2171	2134	2080	1973	1857	1746
				Heating Rise (°F)	42	42	43	44	45	46	48	51	55
				Heating Rise (°C)	23	24	24	24	25	25	27	28	30

Shaded areas indicate speed/static combinations that are not permitted for dehumidification speed.

* Air delivery values are without air filter and are for dry coil (See Wet Coil Pressure Drop table).

¹ Factory-shipped heating speed

² Factory-shipped cooling speed

"NA" = Not allowed for heating speed

Note: Deduct field-supplied air filter pressure drop and wet coil pressure drop to obtain external static pressure available for ducting.