
Sistema Aurora

Piano Sviluppo

Documento preparato per

Staff Tecnico Interno

Settembre 2026



Non consentita la divulgazione

Cronologia delle revisioni

Versione	Data	Autore	Descrizione
1.0.0	2026-07-02	Martin Pellizzer	Versione iniziale

Indice

Cronologia delle revisioni	2
Indice	3

| # | Question | System Architect Answer |

| -- | ----- | -----
----- |

| 1 | What is the overall purpose of the system? | The system monitors ozone concentration and makes the validated measurement available to the CORE controller for use in the overall system. |

| 2 | What problem is the system intended to solve? | It provides CORE with a reliable and standardized way to obtain ozone measurements from an external ZE27-O3 sensor. |

| 3 | What are the main objectives the system must achieve? | The system must reliably acquire, validate, monitor, and communicate ozone measurements while clearly indicating invalid, stale, or unavailable data. |

| 4 | Where and in what context will the system operate? | The module will operate as a DIN-rail-mounted electronic subsystem inside an electrical control cabinet as part of an ozone-related industrial control system. |

| 5 | What other systems, products, machines, or infrastructure interact with this system? | The module primarily interacts with one ZE27-O3 ozone sensor, the CORE controller, the control cabinet power supply, and the surrounding industrial process. |

| 6 | What external systems does the system depend on? | The module depends on the ZE27-O3 sensor for ozone measurements, CORE for higher-level system control, and the cabinet infrastructure for power and physical installation. |

| 7 | Are there system boundaries that must be clearly defined? | Yes, the responsibilities and interfaces between the ozone sensor, expansion module, CORE, and higher-level process control must be explicitly defined. |

| 8 | What is explicitly outside the responsibility of this system? | The module is not responsible for controlling the ozone process, making final process decisions, or replacing CORE's higher-level control logic. |

| 9 | What are the major functions the system must perform? | The module must acquire ozone data from the sensor, validate it, maintain its measurement state, diagnose communication problems, and provide the information to CORE. |

| 10 | What are the major operating modes of the system? | The system has normal measurement operation, startup/initialization, degraded operation when data is unavailable or stale, fault/diagnostic operation, and recovery after communication or power failures. |

|

What is the overall purpose of the system?

The system monitors ozone concentration and makes the validated measurement available to the CORE controller for use in the overall system.

What problem is the system intended to solve?

It provides CORE with a reliable and standardized way to obtain ozone measurements from an external ZE27-O3 sensor.

What are the main objectives the system must achieve?

The system must reliably acquire, validate, monitor, and communicate ozone measurements while clearly indicating invalid, stale, or unavailable data.

Where and in what context will the system operate?

The module will operate as a DIN-rail-mounted electronic subsystem inside an electrical control cabinet as part of an ozone-related industrial control system.

What other systems, products, machines, or infrastructure interact with this system?

The module primarily interacts with one ZE27-O3 ozone sensor, the CORE controller, the control cabinet power supply, and the surrounding industrial process.

What external systems does the system depend on?

The module depends on the ZE27-O3 sensor for ozone measurements, CORE for higher-level system control, and the cabinet infrastructure for power and physical installation.

Are there system boundaries that must be clearly defined?

Yes, the responsibilities and interfaces between the ozone sensor, expansion module, CORE, and higher-level process control must be explicitly defined.

What is explicitly outside the responsibility of this system?

The module is not responsible for controlling the ozone process, making final process decisions, or replacing CORE's higher-level control logic.

What are the major functions the system must perform?

The module must acquire ozone data from the sensor, validate it, maintain its measurement state, diagnose communication problems, and provide the information to CORE.

What are the major operating modes of the system?

The system has normal measurement operation, startup/initialization, degraded operation when data is unavailable or stale, fault/diagnostic operation, and recovery after communication or power failures.