

Management of Precursors to Catastrophe: Identifying & Measuring Precursors

Massoud Amin, D.Sc.

Area Manager, Infrastructure Security

Lead, Mathematics & Information Sciences

Roundtable on Management of Precursors to Catastrophe

National Academy of Engineering

February 21, 2002, Washington, D.C.

EPRI



Vulnerabilities: Power Grid Examples

- November 1965 blackout in the Northeast U.S., which cascaded system collapse in ten states.
- 1967 Pennsylvania-New Jersey-Maryland.
- July 13, 1977 blackout in New York City.
- December 19, 1978 blackout due to voltage collapse in France.
- July and August 1996 outages in the western U.S.
- December 1998, Bay Area black-out. NY July 7, 1999 blackout.
- December 1998 ice storms in Hydro Quebec
- December 1999 winter storms in France
- Industry-wide Y2K readiness program identified telecommunications failure as the biggest risk of the lights going out on rollover to 2000.
- Past summers' price spikes
- Aftermath of tragic events of 11th September.



EPRI/DOD Complex Interactive Network/Systems Initiative

The Reason for this Initiative: “Those who do not remember the past are condemned to repeat it.”

George Santayana


- Two faults in Oregon (500 kV & 230 kV) led to...
 - ...tripping of generators at McNary dam
 - ...500 MW oscillations
 - ...separation of the Pacific Intertie at the California-Oregon border
 - ...blackouts in 13 states/provinces
- Some studies show with proper “intelligent controls,” all would have been prevented by shedding 0.4% of load for 30 minutes!
- ... everyone wants to operate the power system closer to the edge. It's a good idea. But to do that we should know
 - *where is the edge, and*
 - *how close are we to it.*



August 10, 1996

Modeling and Simulation:



An Example- US Power Outages



Wide-Area Measurement System (WAMS)

Integrated measurements facilitate system management


*“Better information supports better
- and faster - decisions.”*




Real-Time System Data

Collected from various monitors throughout the grid


Example: BPA's Phasor Data Concentrator



✦ Disturbance records for WSCC breakup of August 10, 1996




Tacoma Bus Frequency
WSCC Breakup of August 10, 1996




Malin-Round Mountain #1 KV
WSCC Breakup of August 10, 1996

✦ Disturbance records for WSCC breakup of August 10, 1996





Malin-Round Mountain #1 MW
WSCC Breakup of August 10, 1996





Malin-Round Mountain #1 MVar
WSCC Breakup of August 10, 1996



✦ Disturbance records for WSCC breakup of August 10, 1996



✦ Disturbance records for WSCC breakup of August 10, 1996



✦ Disturbance records for WSCC breakup of August 10, 1996




EPRI/DoD Complex Interactive Networks

Use DRDs to Enhance Real Time System Operation

Use recorded data to

1. identify the type and location of disturbances
2. determine whether multiple events have occurred
3. assess the impact of disturbances on system
4. monitor whether the system is adequately damped
5. evaluate the needs for immediate control actions or retuning control algorithms

Last Episode of the TV series “Survivor”




Source: Jim Ingleson of NYISO and Joe Chow (RPI)





Disturbance Identification using Dynamic Recorded Data




- 47 disturbance (out of several hundreds) events recorded at Northfield Substation in New England Power System were analyzed
- Feature extraction – frequency deviation, frequency derivative, and power flows
- Clustering algorithm based on frequency deviation and frequency derivative features

Disturbance



- Loss of close by generation
- Estimate how much generation is lost from tracking system frequency






Disturbance Feature Extraction

Disturbance	Frequency change	Frequency derivative	Line flow change
Loss of nearby generation	Negative	Steep	Large
Loss of remote generation	Negative	Moderate	Negligible
Loss of load	Positive	Moderate	Detectable
Line trip close to DRD	Negligible	Steep	Large
Oscillations	Negligible	Small	oscillations

Clustering Algorithm – separate disturbance classes by hyperplanes




- C₁ – loss of nearby generation
- C₂ – loss of remote generation
- C₃ – loss of load
- C₄ – line trip
- C₅ – oscillations

* Markers show recorded data

Decision Tree for Disturbance Identification

- Developed based on disturbance classes (f in mHz)



- Presently applying neural network techniques for identification

Disturbance Event Analyzer

Event Analyzer

Load Event (.rwc file)

.rwc File:

Year:

Save .mat File

.mat File:

Plot

Northfield

Frequency Domain

Decimate Data:

start time: end time:

Spectral Estimation

Power Spectral Density

Yule-Walker Method

Butterworth Bandpass Filter

frequency (Hz)

Identification Methods


Calculate ERA

Calculate Prony

Load File Train NN Set Manually

Event Type	Hyperplane
L/O Generation	P2 x1 = -6 mHz
L/O nearby generation	1 x1 - x2 =
L/O remote generation	P4 54 mHz/sec
L/O load	P1 x1 = 6 mHz
Line trip	x2 =
Oscillations	P3 -60 mHz/sec

This event occurred on Sunday, 24-May-1998 at 3:15:51.6114. Provide additional event description in the box below:



Frequency range during event (Hz)
Maximum: 60.0255
Minimum: 59.9899
Range: 0.035566

Time Domain

Frequency before event was 60.0096 Hz
Frequency after event was 60.0111 Hz
Frequency change was 0.0015483 Hz

Calculate Beta
Beta (MW/0.1 Hz)

Calculate Generation Change
Generation Change (MW)


First swing frequency slope was -33.494 MilliHertz/sec

Event Classification

Oscillations in the power system about 0.29064 Hz. Use Prony analysis to determine damping information.


Modeling: Power law distributions

Power system
 $\beta = 1$



Power laws and other disasters

Hurricane and Earthquake Losses 1900-1989
Flood Losses 1986-1992




Complex Interactive Networks

Failure Propagation on Grid

Percolation




Designed System




Complex Interactive Networks


Failure Propagation on Grid – Topology & Probability





Yield




Multi-Resolutional Modeling



- Variable levels of details
- 15,000 utility-owned generators
- Highly interconnected
- Lines, loads, generators are *dynamic*



The system can be modeled
at many levels of detail




At this level, dynamic models include the *swing equations*


$$m_i \ddot{\delta}_i + D_i \dot{\delta}_i = P_i + \sum_j b_{ij} \sin(\delta_i - \delta_j)$$




Fast Simulation




Original system



Reduced system




Cascading failures




0.25

0.25




1.764

1.773




1.845

1.848



2.570

2.574



2.582


2.594

Failure time:


Original system

Reduced system


Multi-Resolutional Modeling: The U.S. Power Grid




Complex Interactive Networks



Integrated Protection and Control



Vulnerability Indices




Integrated Infrastructure Protection and Control via Multi-Agent Systems


DELIBERATIVE LAYER

COORDINATION LAYER


REACTIVE LAYER



Intelligent Adaptive Islanding



Technology Challenge for Powering the Digital Society



How do we make the leap to the next generation?