



Generated: 18 August 2026
Investment Party: **Anuva**
Period: **Jul 2026**

Site Performance Report

18

Records

224,192.413

Measured (kWh)

244,367.348

Expected (kWh)

-8.3%

Δ vs Expected

14

Expected Band

3 / 1

Moderate / Poor

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact	Other Comments
Opal Students	Jul-26	3,812	4,217.4	-9.6%	90.4%	Expected	31	0	None	None	The System performed as expected	N/A
Watt Place Rotoflo	Jul-26	14,705	18,900	-22.2%	77.8%	Moderate	31	0	None	None	Energy production was limited by reduced load demand	N/A
Coldstar International	Jul-26	3,547	3,416.15	+3.8%	103.8%	Expected	31	0	None	None	The system performed as expected	N/A
Plastiplate	Jul-26	6,917	6,946.725	-0.4%	99.6%	Expected	31	0	None	None	The System performed	N/A
TOTAL — 18 records		224,192.413	244,367.348	-8.3%								

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact d as expected	Other Comments
Saverite Durban	Jul-26	6,823	7,274.245	-6.2%	93.8%	Expected	31	0	None	None	The System performed as expected	N/A
Meredale Heights	Jul-26	5,690	5,383.9	+5.7%	105.7%	Expected	31	0	None	None	The System performed as expected	N/A
Mambha Cash & Carry	Jul-26	12,604.391	13,099.5	-3.8%	96.2%	Expected	31	0	None	None	The System performed as expected	N/A
Hilston Rotoflo	Jul-26	17,975	19,010.7	-5.4%	94.6%	Expected	31	0	None	None	The System performed as expected	N/A
Bendstore Spar	Jul-26	39,160	43,112.803	-9.2%	90.8%	Expected	31	0	None	None	The System performed as expected	N/A
Riverside Lodge	Jul-26	16,691	15,110.45	+10.5%	110.5%	Expected	31	0	None	None	The System performed as expected	N/A
Club Houghton	Jul-26	3,646	3,874.5	-5.9%	94.1%	Expected	31	0	None	None	The system performed as expected	N/A
TOTAL — 18 records		224,192.413	244,367.348	-8.3%								

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact	Other Comments
Bendstore Plaza Shops	Jul-26	10,351.41	13,735.15	-24.6%	75.4%	Moderate	31	0	None	None	Energy production was limited by reduced load demand	N/A
The Alec	Jul-26	2,690	4,730.4	-43.1%	56.9%	Poor	28	3 days; 8th, 23rd, 28th	Grid power outage	None	The system energy production has been affected by grid unavailability and reduced load demand	N/A
Mathe Group Company	Jul-26	40,997.122	43,977.3	-6.8%	93.2%	Expected	31	0	None	None	The System performed as expected	N/A
Monument Park Checkers	Jul-26	27,326.29	28,361.7	-3.7%	96.3%	Expected	31	0	None	None	The System performed as expected	N/A
Three Peaks	Jul-26	3,037	2,851.125	+6.5%	106.5%	Expected	31	0	None	None	The System performed as expected	N/A
Kool Village	Jul-26	6,582.2	8,550.9	-23.0%	77.0%	Moderate	31	0	None	2 strings were off due to damaged fuses,	Energy production was	Installing new monitoring
TOTAL — 18 records		224,192.413	244,367.348	-8.3%								

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact	Other Comments
										No inverter monitoring	limited by none operational strings	
21 Melrose	Jul-26	1,638	1,814.4	-9.7%	90.3%	Expected	31	0	None	None	The System performed as expected	N/A
Meredale Heights	Dec-25	5,472	5,223.25	+4.8%	104.8%	Expected	31 days	0	None	None	The system performed as expected	N/A
TOTAL — 18 records		224,192.413	244,367.348	-8.3%								