Reports

Generate filtered reports — use Print / Save as PDF to export

Sosimple Energy
CHEAP ENERGY. CLEAN BUSINESS.

Generated: 4 November 2026
Investment Party: **Anuva**
Period: **Oct-26**

Site Performance Report

18	339,182.032	306,711.804	10.6%	13	1 / 4
Records	Measured (kWh)	Expected (kWh)	Δ vs Expected	Expected Band	Moderate / Poor

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact	Other Comments
21 Melrose	Oct-26	**1,475.6**	2,346.564	**-37.1%**	**62.9%**	Poor	31	0	None	None	Energy production was limited by load demand	N/A
Bendstore Plaza Shops	Oct-26	**9,635.66**	14,431.033	**-33.2%**	**66.8%**	Poor	31	0	None	None	Energy production was limited by load demand	N/A
Bendstore Spar	Oct-26	**56,213.02**	45,837.248	**+22.6%**	**122.6%**	Expected	31	0	None	None	The system performed as expected	N/A
Club Houghton	Oct-26	**2,139.8**	5,439.955	**-60.7%**	**39.3%**	Poor	31	0	None	Internet connectivity issues	Energy production was limited by load demand, and missing energy production from offline days	The system wifi was switched off for 7 days, 26-31st
Coldstar International	Oct-26	**6,161.47**	4,106.062	**+50.1%**	**150.1%**	Expected	31	0	None	None	The system performed as expected	N/A
Hilston Rotoflo	Oct-26	**33,278.26**	26,803.992	**+24.2%**	**124.2%**	Expected	31	0	None	None	The system performed as expected	N/A
Total	18 rows	**339,182.032**	306,711.804	**10.6%**								

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact	Other Comments
Kool Village	Oct-26	**11,779.49**	11,834.1	**-0.5%**	**99.5%**	Expected	31	0	None	None	The system performed as expected	N/A
Mambha Cash & Carry	Oct-26	**20,149.163**	18,910.364	**+6.6%**	**106.6%**	Expected	31	0	None	None	The system performed as expected	N/A
Mathe Group Company	Oct-26	**56,994.51**	53,552.675	**+6.4%**	**106.4%**	Expected	31	0	None	None	The system performed as expected	N/A
Meredale Heights	Oct-26	**6,286.42**	5,382.267	**+16.8%**	**116.8%**	Expected	31	0	None	None	The system performed as expected	N/A
Monument Park Checkers	Oct-26	**47,810.21**	38,968.097	**+22.7%**	**122.7%**	Expected	31	0	None	None	The system performed as expected	N/A
Opal Students	Oct-26	**6,454.3**	5,546.317	**+16.4%**	**116.4%**	Expected	31	0	None	None	The system performed as expected	N/A
Plastiplate	Oct-26	**7,487.38**	8,519.052	**-12.1%**	**87.9%**	Moderate	31	0	None	None	Energy production was limited by load demand	N/A
Riverside Lodge	Oct-26	**21,178.94**	17,170.227	**+23.3%**	**123.3%**	Expected	31	0	None	None	The system performed as expected	N/A
Saverite Durban	Oct-26	**12,036.61**	10,511.22	**+14.5%**	**114.5%**	Expected	31	0	None	None	The system performed as expected	N/A
The Alec	Oct-26	**4,144.829**	7,081.171	**-41.5%**	**58.5%**	Poor	22	**15th-23rd, 9 days**	Power outage	None	Energy production was limited by system unavailability and load demand	N/A
Three Peaks	Oct-26	**5,157.77**	3,655.75	**+41.1%**	**141.1%**	Expected	31	0	None	None	The system performed as expected	N/A
Watt Place Rotoflo	Oct-26	**30,798.6**	26,615.709	**+15.7%**	**115.7%**	Expected	31	0	None	None	The system performed as expected	N/A
Total	18 rows	**339,182.032**	**306,711.804**	**10.6%**								

One row per site per reporting period, showing measured vs expected generation, performance band, and the technical comments logged for the month. Rows are ordered most-recent period first.

© 2026 Sosimple Energy — Cheap energy. Clean business.