

Reports

Generate filtered reports — use Print / Save as PDF to export



Generated: 7 September 2026
Investment Party: **Anuva**
Period: **Aug-26**

Site Performance Report

18
Records

268,878.03
Measured (kWh)

277,806.963
Expected (kWh)

-3.2%
Δ vs Expected

11
Expected Band

6 / 1
Moderate / Poor

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact	Other Comments
21 Melrose	Aug-26	1,374	2,116.8	-35.1%	64.9%	Poor	30 days	0	None	None	Energy production was limited by load demand	N/A
Bendstore Plaza Shops	Aug-26	11,244.861	15,350.15	-26.7%	73.3%	Moderate	30 days	0	None	None	Energy production was limited by load demand	N/A
Bendstore Spar	Aug-26	44,122.439	48,266.503	-8.6%	91.4%	Expected	30 days	0	None	None	The system performed as expected	N/A
Club Houghton	Aug-26	4,021	4,560.3	-11.8%	88.2%	Moderate	30	0	None	None	Energy production was limited by load demand	N/A
Coldstar International	Aug-26	4,690	3,857.045	+21.6%	121.6%	Expected	30 days	0	None	None	The system performed as expected	N/A
Hilston Rotoflo	Aug-26	23,217	22,169.7	+4.7%	104.7%	Expected	30 days	0	None	None	The system performed as expected	N/A
Kool Village	Aug-26	8,388.669	9,997.2	-16.1%	83.9%	Moderate	30 days	0	None	None	N/A	N/A
Mambha Cash & Carry	Aug-26	15,549.035	15,450.3	+0.6%	100.6%	Expected	30 days	0	None	None	The system performed as expected	N/A

Total18 rows268,878.03277,806.963-3.2%

Site Name	Period	Measured kWh	Expected kWh	Δ %	Perf %	PF Band	Availability	Downtime	Cause of Downtime	Technical Events	Energy Impact	Other Comments
Mathe Group Company	Aug-26	49,938.125	48,620.85	+2.7%	102.7%	Expected	30 days	0	None	None	The system performed as expected	N/A
Meredale Heights	Aug-26	6,058	5,638.05	+7.4%	107.4%	Expected	30 days	0	None	None	The system performed as expected	N/A
Monument Park Checkers	Aug-26	35,675.901	33,006.6	+8.1%	108.1%	Expected	30 days	0	None	None	The system performed as expected	N/A
Opal Students	Aug-26	4,901	4,844.7	+1.2%	101.2%	Expected	30 days	0	None	None	The system performed as expected	N/A
Plastiplate	Aug-26	6,801	7,852.65	-13.4%	86.6%	Moderate	30 days	0	None	None	Energy production was limited by reduced load demand	N/A
Riverside Lodge	Aug-26	18,348	16,763.7	+9.5%	109.5%	Expected	30 days	0	None	None	The system performed as expected	N/A
Saverite Durban	Aug-26	8,202	8,568.715	-4.3%	95.7%	Expected	30 days	0	None	None	The system performed as expected	N/A
The Alec	Aug-26	3,881	5,440.5	-28.7%	71.3%	Moderate	30 days	0	None	None	Energy production was limited by reduced load demand	N/A
Three Peaks	Aug-26	3,769	3,237	+16.4%	116.4%	Expected	30 days	0	None	None	The system performed as expected	N/A
Watt Place Rotoflo	Aug-26	18,697	22,066.2	-15.3%	84.7%	Moderate	30 days	0	None	None	Energy production was limited by reduced load demand	N/A
Total	18 rows	268,878.03	277,806.963	-3.2%								

One row per site per reporting period, showing measured vs expected generation, performance band, and the technical comments logged for the month. Rows are ordered most-recent period first.
© 2026 Sosimple Energy — Cheap energy. Clean business.