

CERTIFICATE OF CONFORMITY

Issued to: Sungrow Power Supply Co., Ltd.
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,
Hefei, P. R. China

For the product: GRID-CONNECTED PV INVERTER

Trade name:

SUNGROW

Type/Model: SG150CX

Ratings: See Annex

Manufactured by: Sungrow Power Supply Co., Ltd.
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,
Hefei, P. R. China

Requirements: UTE C15-712-1:2013
DIN V VDE V 0126-1-1:2006
DIN V VDE V 0126-1-1/A1:2012

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6173988.50

The examination has been carried out on one single specimen of the product. The certificate does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 2029-12-04 or expires upon withdrawal of one of the above mentioned standards.

Shanghai, 4 December 2024

Certificate Number: 6173988.01COC

DEKRA Testing and Certification (Shanghai) Ltd.


Cliff Lin
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.

No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China

T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-product-safety.com

ESA-CER-F021 v4.1



Annex to 6173988.01COC**Ratings of the test product:**

Operating temperature range: - 35°C to + 60°C

Protective class: I

Ingress protection rating: IP66

Power factor range (adjustable): 0.8 leading...0.8 lagging

SG150CX:

PV input:

Voltage: MPPT range: 180 – 1000 Vdc, Voc: 1100Vdc,

Current: total max. 336 A (48 A per MPPT),

Isc: total max.462 A (66 A per MPPT)

AC output:

Rated Voltage: 3/N/PE, AC 220/380 V, 3/N/PE, AC 230/400 V

Rated Frequency:50/60 Hz

Current: max. 250.7A, 380Vac; max.240.6A, 400Vac

Capacity: max. 165KVA

--The end--