

Technical Piping and Service Corp.

Mechanical Contractors - Certified Welding - State Approved

Pneumatic Pressure Test Record

Customer: Service Spring Corp.

Date: 4/11/12

Address: 6615 Maumee Western Rd, Maumee, OH 43537

System Under Test: Bulk Oxygen Tank

Page: 1 of 1

Name Plate Details: Cosmodyne Mfg., Vessel No. 1111, National Board # 1111, Year 1967

Test Conducted By: Randall L. Gerlach, Technical Piping Employee # T130

Test Witnessed By: Jim Galloway, Technical Piping Employee # T120

Maximum Allowable Working Pressure of System Being Tested: 250 PSIG

Pneumatic Test Pressure: 250 PSIG

Gas Used for Test: Nitrogen

Test Pressure PSIG		Leak Check (✓)	Result of Test Pass / Fail	Target Test Pressure
PSIG	15	✓	Pass	15
PSIG	30	✓	Pass	30
PSIG	60	✓	Pass	60
PSIG	90	✓	Pass	90
PSIG	120	✓	Pass	120
PSIG	150	✓	Pass	150
PSIG	180	✓	Pass	180
PSIG	210	✓	Pass	210
PSIG	240	✓	Pass	240
PSIG	250	✓	Pass	250
PSIG				
PSIG				

Technician Signature: *Randall L. Gerlach*

Witness Signature: *Jim Galloway (T120)*

Customer Signature (if required):

Technical Piping and Service Corp.

Mechanical Contractors - Certified Welding - State Approved

Pneumatic Pressure Test Record

Customer: Service Spring Corp.

Date: 4/11/12

Address: 6615 Maumee Western Rd, Maumee, OH 43537

System Under Test: Propylene Tank

Page: 1 of 1

Name Plate Details: Yr Built: 1965, National Board # 418

Test Conducted By: Randall L. Gerlach, Technical Piping Employee # T130

Test Witnessed By: Jim Galloway, Technical Piping Employee # T120

Maximum Allowable Working Pressure of System Being Tested:

250

PSIg

Pneumatic Test Pressure: 250

PSIg

Gas Used for Test: Nitrogen

Test Pressure PSIg		Leak Check (✓)	Result of Test Pass / Fail	Target Test Pressure
PSIg	15	✓	Pass	15
PSIg	30	✓	Pass	30
PSIg	60	✓	Pass	60
PSIg	90	✓	Pass	90
PSIg	120	✓	Pass	120
PSIg	150	✓	Pass	150
PSIg	180	✓	Pass	180
PSIg	210	✓	Pass	210
PSIg	240	✓	Pass	240
PSIg	250	✓	Pass	250
PSIg				
PSIg				

Technician Signature: *Randall L. Gerlach*

Witness Signature: *J. Galloway (T120)*

Customer Signature (if required):