## Certificate of Electrical Safety

## Prescribed Electrical Installation Work

Electricity Safety Act 1998, Electricity Safety (General) Regulations 2019



P1 0099 8916 1

CERTIFICATE OF COMPLIANCE				CERTIFICATE OF INSPECTION	
Responsible Person				Licensed Electrical Inspector	
REC registration no.	REC-25926	Telephone no.	0428 166 111	Licence no.	
Name	WINKI SOLUTIONS F	PTY LTD		1980519	
Address	59 ALLEYNE AV TORQUAY VIC 3228			Name	
ء Licensed Electrical Wo	orker			RICHARD MCKINNES	
Licence no.	A62495				
Name	Thomas Cameron			]	
۔ Details of Electrical In	stallation				
Address	10 LANGUID ST ARMSTRONG CREEK VIC 3217				
NMI [		Lot number (wher applicable only)	e		
Description of Prescri	bed Work Undertak	en			
Panel watts: 440W Panel volts: 52.2V Panel ISC: 10.67 Inverter make: Enphase Inverter model: IQ8AC-72-M-IN' Inverter capacity: 5.4kW Inverters installed (amount): 15 Export limit: 5kVA Installation date: 02/02/2024 Single Storey Access Required, please contact User manual and documentation	ct customer.	nap located in meter box			
	as passed all the requ	ired tests and comp	rk described above, certify lies in all respects with the ations.	I, RICHARD MCKINNES, have inspected the prescribed electrical installation work a described in the certificate of compliance and certify that the work COMPLIES with the Electricity Safety Act 1998 and the Electricity Safety (General) Regulations.  Date of Inspection  09 February 2024	
Date of Completion		Date of Certificati	on	Date of Certification	
02 February 2024		08 February 20	24	09 February 2024	

Please note: The electrical installation work described on this certificate may be subject to audit by representatives of Energy Safe Victoria. Please visit www.esv.vic.gov.au for further information.

