

D2

ADA Ramp & Elevator sections

This diagram outlines the accessibility strategy concentrated within the elevator and ramp core, where vertical and sloped circulation are consolidated into a continuous, code-compliant system. The core is designed to ensure that all users can move between levels without interruption, aligning ramp transitions and elevator access within a single, legible zone.

The elevator is sized to meet ADA requirements, providing a minimum clear interior dimension of 51 inches by 80 inches for a standard passenger configuration, allowing full wheelchair accommodation and turning. Door clear openings are maintained at a minimum of 36 inches, with maneuvering clearances at entries sized to support both front and side approaches. Call buttons, controls, and signaling devices are positioned within accessible reach ranges, ensuring usability without assistance.

Adjacent to the elevator, the ramp system operates as a continuous accessible route, maintaining a maximum slope of 1:12 and a minimum clear width of 36 inches. Landings are provided at all changes in direction and at required intervals, with minimum dimensions of 60 inches to allow for wheelchair turning and pause points. Handrails and edge protection align with ADA standards, reinforcing safety while maintaining visual continuity with the surrounding architecture.

Turning radii are embedded at the interface between ramp, elevator, and corridor, with 60-inch diameter clearances ensuring full maneuverability at points of transition. These nodes allow for seamless shifts between vertical and horizontal movement without congestion or conflict.

