Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

TYPE OF SALE: 1690

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

Liquid-to-Liquid Coolant Distribution Unit (CDU)

The Carrier 65LL Coolant Distribution Unit (CDU) delivers an efficient, direct-to-chip liquid cooling solution for modern data centers. It is designed to keep facility and technology cooling fluid separate, helping to maintain the high fluid quality needed for sensitive equipment. With advanced thermal management features, the CDU supports reliable, energy-efficient, and sustainable heat removal. Its modular design and hot-swappable components allow for scalable deployment, continuous operation, and simplified maintenance.



Performance Features

- High thermal performance with a robust brazed plate heat exchanger where the standard model features an optimized design that delivers a nominal capacity of 1.35 MW at 4°C ATD, and supports a broader range of capacities under varying operating conditions.
- High secondary external pressure capabilities with single or optional dual pumps with integral variable frequency drives (VFD)
- Secondary fluid circuit filters with standard 25-micron in-line filters on the secondary side. An optional 50-micron filter is also available for selection.
- Hot swapable components, such as the secondary filters, pumps, and temperature and pressure sensors
- Sensor redundancy
- Low pressure drop design
- Integrated SmartVu™ controls and human machine interface (HMI) standard
- Integrated hydronic options such as temperature control valves, bypass valves and pressure control valves.
- Optional expansion tanks to help prevent over pressurizing the secondary system.
- Optional automatic transfer switch (ATS) that will automatically allow the unit to switch to a backup power source.
- Optional uninterrupted power supply (UPS) enables continuous operation in the control board, HMI and temperature control valve.
- Optional feature that automatically maintains the secondary loop’s volume by supplying makeup fluid from an integrated tank whenever the system detects a drop in pressure or fluid level.

PC111	**FORM NO. 65LL-2PPG**
SUPERSEDES	
PRICE SECTION	**65LL-1PPG**

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

65LL Model Number Nomenclature

Digit	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Model Number	6	5	L	L	-	1	0	0	6	P	-	-	D	-	-	-	0

Unit
65 = Base Unit

Type
LL = Liquid-to-Liquid Coolant Distribution Unit

Design Series/Factory Location
- = Design/Location
S = Engineered-to-Order (ETO) Unit
100 = 1 MW

Voltage
1 = 575-3-60
2 = 380/415-3-60
6 = 460-3-60
9 = 380/415-3-50

Configuration
P = Perimeter, Standard Chassis

Connection, Auto Fill, Expansion Tank Options
– = Std Connections (all top), Std Flow Meter, No Auto Fill Pump/Tank, No Expansion Tank
2 = Alt Connections (PFC side high, SFC top), Std Flow Meter, No Auto Fill Pump/Tank, No Expansion Tank
3 = Std Connections, Std Flow Meter, Auto Fill Pump/Tank, No Expansion Tank
6 = Alt Connections, Std Flow Meter, Auto Fill Pump/Tank, No Expansion Tank
7 = Std Connections, Std Flow Meter, No Auto Fill Pump/Tank, Expansion Tank
B = Alt Connections, Std Flow Meter, No Auto Fill Pump/Tank, Expansion Tank
C = Std Connections, Std Flow Meter, Auto Fill Pump/Tank, Expansion Tank
G = Alt Connections, Std Flow Meter, Auto Fill Pump/Tank, Expansion Tank
H = Std Connections, Alt (High Accuracy) Flow Meter, No Auto Fill Pump/Tank, No Expansion Tank
L = Alt Connections, Alt (High Accuracy) Flow Meter, No Auto Fill Pump/Tank, No Expansion Tank
M = Std Connections, Alt (High Accuracy) Flow Meter, Auto Fill Pump/Tank, No Expansion Tank
Q = Alt Connections, Alt (High Accuracy) Flow Meter, Auto Fill Pump/Tank, No Expansion Tank
R = Std Connections, Alt (High Accuracy) Flow Meter, Auto Fill Pump/Tank, Expansion Tank
W = Alt Connections, Alt (High Accuracy) Flow Meter, Auto Fill Pump/Tank, Expansion Tank

Filtration Options
– = Std Connections, All Top, No Y-Strainer, 25 Micron Filter
0 = Std Connections, All Top, 250 Micron Y-Strainer, 25 Micron Filter
1 = Std Connections, All Top, 500 Micron Y-Strainer, 25 Micron Filter
8 = Alt Connections, PFC Side High, SFC Top, No Y-Strainer, 25 Micron Filter
9 = Alt Connections, PFC Side High, SFC Top, 250 Micron Y-Strainer, 25 Micron Filter
B = Alt Connections, PFC Side High, SFC Top, 500 Micron Y-Strainer, 25 Micron Filter
C = Std Connections, All Top, No Y-Strainer, 50 Micron Filter
D = Std Connections, All Top, 250 Micron Y-Strainer, 50 Micron Filter
F = Std Connections, All Top, 500 Micron Y-Strainer, 50 Micron Filter
N = Alt Connections, PFC Side High, SFC Top, No Y-Strainer, 50 Micron Filter
P = Alt Connections, PFC Side High, SFC Top, 250 Micron Y-Strainer, 50 Micron Filter
Q = Alt Connections, PFC Side High, SFC Top, 500 Micron Y-Strainer, 50 Micron Filter

Pump Options
3 = Single Pump (20 hp)
D = Dual Pump (20 hp ea.)

Electrical Options
– = Single Point (SP) No Disconnect, Standard SCCR, No Automatic Transfer Switch (ATS), No Active Harmonic Filtration (AHF)
0 = SP Non-Fused Disconnect (NFD), Standard SCCR, No ATS, No AHF
1 = Single Point (SP) Fused Disconnect, Standard SCCR, No ATS, No AHF
2 = SP No Disconnect, High SCCR, No ATS, No AHF
3 = SP NFD, High SCCR, No ATS, No AHF
4 = SP Fused Disconnect, High SCCR, No ATS, No AHF
5 = SP No Disconnect, Standard SCCR, ATS[a], No AHF
8 = SP No Disconnect, High SCCR, ATS[a], No AHF
C = SP No Disconnect, Standard SCCR, No ATS, AHF[a]
D = SP NFD, Standard SCCR, No ATS, AHF[a]
F = SP Fused Disconnect, Standard SCCR, No ATS, AHF[a]
G = SP No Disconnect, High SCCR, No ATS, AHF[a]
H = SP NFD, High SCCR, No ATS, AHF[a]
J = SP Fused Disconnect, High SCCR, No ATS, AHF[a]
K = SP No Disconnect, Standard SCCR, ATS[a], AHF[a]
N = SP No Disconnect, High SCCR, ATS[a], AHF[a]

Positions 15-17 continued on next page.

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

65LL Model Number Nomenclature (cont)

Digit	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Model Number	6	5	L	L	A	1	0	0	6	P	-	-	D	-	-	-	0

Positions 1-14 listed on previous page.

Control Options

- - = No extra sensor redundancy, no Energy Management Module (EMM), no external door locks, Standard Carrier Controller location
- 0 = Extra sensor redundancy, no EMM, no external door locks, Standard Carrier Controller location
- 1 = No extra sensor redundancy, EMM, no external door locks, Standard Carrier Controller location
- 2 = Extra sensor redundancy, EMM, no external door locks, Standard Carrier Controller location
- 3 = No extra sensor redundancy, no EMM, external door locks, Standard Carrier Controller location
- 4 = Extra sensor redundancy, no EMM, external door locks, Standard Carrier Controller location
- 5 = No extra sensor redundancy, EMM, external door locks, Standard Carrier Controller location
- 6 = Extra sensor redundancy, EMM, external door locks, Standard Carrier Controller location
- 7 = No extra sensor redundancy, no EMM, no external door locks, Alternate Carrier Controller location
- 8 = Extra sensor redundancy, no EMM, no external door locks, Alternate Carrier Controller location
- 9 = No extra sensor redundancy, EMM, no external door locks, Alternate Carrier Controller location
- B = Extra sensor redundancy, EMM, no external door locks, Alternate Carrier Controller location
- C = No extra sensor redundancy, no EMM, external door locks, Alternate Carrier Controller location
- D = Extra sensor redundancy, no EMM, external door locks, Alternate Carrier Controller location
- F = No extra sensor redundancy, EMM, external door locks, Alternate Carrier Controller location
- G = Extra sensor redundnacy, EMM, external door locks, Alternate Carrier Controller location

Insulation Options

- – = BPHE Insulation Only (R4)
- 0 = Standard Connections, PFC Insulation, No PFC Y-Strainer, Standard Flow Meter
- 3 = Alternate Connections, PFC Insulation, No PFC Y-Strainer, Standard Flow Meter
- 4 = Standard Connections, PFC Insulation, PFC Y-Strainer, Standard Flow Meter
- 7 = Alternate Connections, PFC Insulation, PFC Y-Strainer, Standard Flow Meter
- C = Alternate Connections, PFC Insultation, No PFC Y-Strainer, Alternate (High Accuracy) Flow Meter
- D = Standard Connections, PFC Insulation, PFC Y-Strainer, Alternate (High Accuracy) Flow Meter
- H = Alternate Connections, PFC Insulation, PFC Y-Strainer, Alternate (High Accuracy) Flow Meter

Packaging

- 0 = No Casters, No Shipping Crate
- 1 = No Casters, Shipping Crate
- 2 = Ship with Casters, No Shipping Crate
- 3 = Ship with Casters, Shipping Crate

[a] Not available on 575-3-60 units

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

BASE UNIT MASTER PRICES

ORDERING NUMBER	VOLTAGE-PHASE-HZ	CAPACITY	PUMP QTY	HEAT EXCHANGER QTY	MASTER PRICE
65LL-1001P--3---0	575-3-60	1MW	1	1	274,374
65LL-1002P--3---0	380/415-3-60	1MW	1	1	274,374
65LL-1006P--3---0	460-3-60	1MW	1	1	266,383
65LL-1009P--3---0	380/415-3-50	1MW	1	1	279,862
65LL-1001P--D---0	575-3-60	1MW	2	1	314,873
65LL-1002P--D---0	380/415-3-60	1MW	2	1	314,873
65LL-1006P--D---0	460-3-60	1MW	2	1	305,702
65LL-1009P--D---0	380/415-3-50	1MW	2	1	321,170
65LL-1021P--3---0	575-3-60	1MW	1	2	Future offering
65LL-1022P--3---0	380/415-3-60	1MW	1	2	Future offering
65LL-1026P--3---0	460-3-60	1MW	1	2	Future offering
65LL-1029P--3---0	380/415-3-50	1MW	1	2	Future offering
65LL-1021P--D---0	575-3-60	1MW	2	2	Future offering
65LL-1022P--D---0	380/415-3-60	1MW	2	2	Future offering
65LL-1026P--D---0	460-3-60	1MW	2	2	Future offering
65LL-1029P--D---0	380/415-3-50	1MW	2	2	Future offering

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

Connection, Auto Fill, Expansion Tank Options

11th DIGIT ORDER CODE	CONNECTION	FLOW METER	AUTO FILL PUMP/TANK	EXPANSION TANK	MASTER PRICE
					1MW
-	Standard	Standard	None	None	Std
2	Alternate	Standard	None	None	65LL_POS11_001 Future Offering
3	Standard	Standard	Included	None	65LL_POS11_002 4,036
6	Alternate	Standard	Included	None	65LL_POS11_003 Future Offering
7	Standard	Standard	None	Included	65LL_POS11_004 3,037
B	Alternate	Standard	None	Included	65LL_POS11_005 Future Offering
C	Standard	Standard	Included	Included	65LL_POS11_006 7,072
G	Alternate	Standard	Included	Included	65LL_POS11_007 Future Offering
H	Standard	High Accuracy	None	None	65LL_POS11_008 16,195
L	Alternate	High Accuracy	None	None	65LL_POS11_009 Future Offering
M	Standard	High Accuracy	Included	None	65LL_POS11_010 20,230
Q	Alternate	High Accuracy	Included	None	65LL_POS11_011 Future Offering
R	Standard	High Accuracy	Included	Included	65LL_POS11_012 23,267
W	Alternate	High Accuracy	Included	Included	65LL_POS11_013 Future Offering

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

Connection and Filter Options

12th DIGIT ORDER CODE	CONNECTION	Primary Y Strainer (micron)	Secondary Fitler (micron)	MASTER PRICE
				1MW
-	Standard	None	25	Std
0	Standard	250	25	65LL_POS12_001 16,468
1	Standard	500	25	65LL_POS12_002 16,466
8	Alternate	None	25	65LL_POS12_003 Future Offering
9	Alternate	250	25	65LL_POS12_004 Future Offering
B	Alternate	500	25	65LL_POS12_005 Future Offering
C	Standard	None	50	0
D	Standard	250	50	65LL_POS12_006 16,468
F	Standard	500	50	65LL_POS12_007 16,466
N	Alternate	None	50	65LL_POS12_008 Future Offering
P	Alternate	250	50	65LL_POS12_009 Future Offering
Q	Alternate	500	50	65LL_POS12_010 Future Offering

Pump Options

13th DIGIT ORDER CODE	PUMP QUANTITY	MASTER PRICE
		1MW
3	1	Std.
D	2	See Base Unit Master Prices

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

ELECTRICAL OPTIONS

14th DIGIT ORDER CODE	POWER CONNECTION	DISCONNECT	SCCR	ATS[a]	AHF[a]	MASTER PRICE 1MW
-	Single point (SP)	None	Standard	None	None	Std
0	SP	Non-Fused (NFD)	Standard	None	None	65LL_POS14_001 2,155
1	SP	Fused (FD)	Standard	None	None	65LL_POS14_002 4,989
2	SP	None	High	None	None	65LL_POS14_003 693
3	SP	NFD	High	None	None	65LL_POS14_004 2,848
4	SP	FD	High	None	None	65LL_POS14_005 5,682
5	SP	None	Standard	Included	None	65LL_POS14_006 11,021
8	SP	None	High	Included	None	65LL_POS14_007 11,713
C	SP	None	Standard	None	Included and 13th digit is "3"	65LL_POS14_008 19,067
					Included and 13th digit is "D"	65LL_POS14_009 38,133
D	SP	NFD	Standard	None	Included and 13th digit is "3"	65LL_POS14_010 21,222
					Included and 13th digit is "D"	65LL_POS14_011 40,288
F	SP	FD	Standard	None	Included and 13th digit is "3"	65LL_POS14_012 24,056
					Included and 13th digit is "D"	65LL_POS14_013 43,122
G	SP	None	High	None	Included and 13th digit is "3"	65LL_POS14_014 19,759
					Included and 13th digit is "D"	65LL_POS14_015 38,826
H	SP	NFD	High	None	Included and 13th digit is "3"	65LL_POS14_016 21,914
					Included and 13th digit is "D"	65LL_POS14_017 40,981
J	SP	FD	High	None	Included and 13th digit is "3"	65LL_POS14_018 24,748
					Included and 13th digit is "D"	65LL_POS14_019 43,815
K	SP	None	Standard	Included	Included and 13th digit is "3"	65LL_POS14_020 30,087
					Included and 13th digit is "D"	65LL_POS14_021 49,154
N	SP	None	High	Included	Included and 13th digit is "3"	65LL_POS14_022 30,780
					Included and 13th digit is "D"	65LL_POS14_023 49,847

Notes
Standard SCCR is 25kA @ 480V / 14kA @ 600V
High SCCR is 65kA @ 480V / 25kA @ 600V

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE
[a] Not available on 575-3-60

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

CONTROL OPTIONS

15th DIGIT ORDER CODE	EXTRA SENSOR REDUNDANCY	ENERGY MANAGEMENT MODULE (EMM)	EXTERNAL LOCKS	CONTROLLER LOCATION	MASTER PRICE
					1MW
-	None	None	None	Standard	Std
0	Included	None	None	Standard	65LL_POS15_002 6,896
1	None	Included	None	Standard	65LL_POS15_003 1,618
2	Included	Included	None	Standard	65LL_POS15_004 8,513
3	None	None	Included	Standard	65LL_POS15_005 336
4	Included	None	Included	Standard	65LL_POS15_006 7,232
5	None	Included	Included	Standard	65LL_POS15_007 1,954
6	Included	Included	Included	Standard	65LL_POS15_008 8,850
7	None	None	None	Alternate	65LL_POS15_009 498
8	Included	None	None	Alternate	65LL_POS15_010 7,393
9	None	Included	None	Alternate	65LL_POS15_011 2,115
B	Included	Included	None	Alternate	65LL_POS15_012 9,011
C	None	None	Included	Alternate	65LL_POS15_013 834
D	Included	None	Included	Alternate	65LL_POS15_014 7,730
F	None	Included	Included	Alternate	65LL_POS15_015 2,452
G	Included	Included	Included	Alternate	65LL_POS15_016 9,347

Notes
Alternate controller location is on the side of the unit

PRIMARY LOOP PIPING INSULATION OPTIONS

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

16th DIGIT ORDER CODE	CONNECTIONS	INSULATION	Y-STRAINER	FLOW METER	MASTER PRICE
					1MW
-	Standard	BPHE only	None	Standard	Std
0	Standard	Internal Primary Loop Piping + BPHE	None	Standard	65LL_POS16_001 1,866
3	Alternate		None	Standard	65LL_POS16_002 Future Offering
4	Standard		Included	Standard	65LL_POS16_003 2,366
7	Alternate		Included	Standard	65LL_POS16_004 Future Offering
C	Alternate		None	High Accuracy	65LL_POS16_005 Future Offering
D	Standard		Included	High Accuracy	65LL_POS16_006 2,616
H	Alternate		Included	High Accuracy	65LL_POS16_007 Future Offering

Carrier Corporation • Syracuse, N.Y. 13221
SUBJECT TO CHANGE WITHOUT NOTICE

F.O.B. SHIPPING POINT
FREIGHT AS PER D.O.M.

PACKAGING

17th DIGIT ORDER CODE	CASTERS	SHIPPING CRATE	MASTER PRICE
			1MW
0	None	None*	Std
1	None	Included**	65LL_POS17_001 1,651
2	Included	None*	65LL_POS17_002 2,808
3	Included	Included**	65LL_POS17_003 4,459

*Units will ship with a bag enclosure and will ship via dry van. These are not available for OP8
**Crate units can ship via low boy flat bed

OPTIONAL EXTENDED WARRANTIES ARE AVAILABLE. SEE CATALOG NO. 500-089 "COMMERCIAL START-UP AND OPTIONAL EXTENDED WARRANTY PRICING"

LEGEND
Std — Standard
Alt – Alternative
N/A — Not Applicable
NC — No Charge
CDU – Coolant distribution unit
VFD – Variable frequency drive
ATD – Approach temperature difference
HMI – Human machine interface
ATS – Automatic transfer switch
UPS – Uninterrupted power supply
ETO – Engineered to order
PFC – Primary fluid circuit
SFC – Secondary fluid circuit
SP – Single point
NFD – Non-fused disconnect
AHF – Active harmonic filter
EMM – Energy management module
BPHE – brazed plate heat exchanger
SCCR – Short circuit current rating