

ROUTINE INSPECTION REPORT

Report ID: IR-2024-031

Date: 20 February 2024

Facility: Visakhapatnam Industrial Complex, Unit 3

Equipment Inspected: Pump-101, Valve-22

Performed by: Suresh Patel (Inspection Officer)

Shift: Night Shift (22:00 - 06:00)

FINDINGS:

Pump-101: Vibration levels reduced to 4.1 mm/s following January maintenance (Ref: MR-2024-014). Bearing temperature normal at 61°C. No abnormalities detected during this inspection cycle.

Valve-22: Minor seal wear observed, within acceptable tolerance. No immediate action required. Scheduled for replacement during next planned shutdown.

COMPLIANCE CHECK:

Inspection conducted in accordance with Safety Procedure SP-45. All permit-to-work documentation verified and up to date.

REFERENCE DOCUMENTS:

- Safety Procedure SP-45
- Maintenance Report MR-2024-014

Status: Satisfactory

Next Inspection Due: 20 May 2024