

SAFETY PROCEDURE DOCUMENT

Document ID: SP-45

Title: Rotating Equipment Safety Protocol

Revision: 3.2

Effective Date: 1 April 2023

Applicable to: All centrifugal pumps, boiler feed systems, rotating machinery

PURPOSE:

This procedure establishes mandatory inspection intervals, vibration thresholds, and escalation protocols for rotating equipment to prevent catastrophic failures and ensure worker safety.

VIBRATION THRESHOLDS:

- Normal operating range: 0 - 4.5 mm/s
- Warning threshold: 4.5 - 6.5 mm/s (requires inspection within 7 days)
- Critical threshold: Above 6.5 mm/s (requires immediate shutdown and inspection within 24 hours)

ESCALATION PROTOCOL:

Any reading in the Warning or Critical range must be logged and escalated to the Maintenance Supervisor within 4 hours of detection. Failure to escalate constitutes a procedure violation and must be reported.

REGULATORY ALIGNMENT:

This procedure is aligned with OISD-105 guidelines and Factory Act requirements for rotating machinery safety.

REVISION HISTORY:

- Rev 3.2: Added mandatory 4-hour escalation window following INC-2023-089 investigation findings
- Rev 3.1: Updated vibration thresholds based on OEM recommendations