




<b>Industry &amp; Facilities Division</b>    <b>RELEASE NOTE Nr: SAP/AHM/IOCL/09500/RN/001</b>	Page 1 /2  v Completely Partially
<b>BV Job Nr:IND.A.4.21.0178 BVIL Zig No: 6122604</b>	

<b>Project: IOCL – Panipat</b>	<b>IPO Ref (If applicable):</b> (BV internal P/o)
<b>BV Client:</b> M/s. Sap Industries Ltd	<b>P/o nr:</b> --- (client to BV)
<b>Manufacturer/Vendor:</b> M/s Sap Industries Ltd	<b>P/o nr:</b> NCM2011068/26809500 Dtd:-13/02/2021 (IOCL To SAP)
<b>Sub Vendor:</b> N.A.	<b>P/o nr:</b> N.A.
<b>Inspection requested by:</b> M/s. Sap Industries Ltd	


SUPPLY / SUBJECT OF INSPECTION	ITEM / TAG Nr	QTY
Refer Below Annexure -A	Refer Below Annexure –A	

<b>CONCLUSIONS / REMARKS:</b>  All above items/material were inspected and accepted within the scope defined in approved QAP/ITP & found to meet the requirements of purchase order & specification.  Please Refer <b>BV Inspection Report No.</b> SAP/AHM/IOCL/09500/IR/001 <b>Date:</b> 29/03/2021 for Details & the stages witnessed as per QAP and inspection reference documents in force at the time of inspection.
---

This note is issued further to an inspection whose duration and scope were limited by the terms and conditions of the contract with BV principal. This note is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacturer, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation, patents, workmanship, materials, safety, performance in operation and/or reliability.

<b>Inspected by:</b> Bharat Akhaja <b>Name:</b> Bharat Akhaja   29/03/2021 Bharat Akhaja <b>Date of issue:</b> 29/03/2021 <b>Inspection centre:</b> BV – Ahmedabad	<b>Checked by:</b> <b>Name:</b>   <b>Signature:</b>
<b>Distribution:</b> <input checked="" type="checkbox"/> Client <input checked="" type="checkbox"/> BV – CO <input checked="" type="checkbox"/> BV – Ahmadabad.	

This note is subject to the General Conditions of Service of Bureau Veritas in force on the day of its issuance.

<b>Industry &amp; Facilities Division</b>   <b>RELEASE NOTE Nr: SAP/AHM/IOCL/09500/RN/001</b>	Page 2 /2
	√ Completely Partially

BV Job Nr:IND.A.4.21.0178 BVIL Zig No: 6122604

#### ANNEXURE A

Po Sr. No	Item Description	MATL CODE	PO QTY.	OFFER QTY.	Accepted Qty.	Prev. Cleared QTY.	Balance Qty.	Valve Sr. No.
10	Ball Valve - 14" - 600# - CS – 2PC – A216 WCB – F/E – Gear Operated	4802082844	04 Nos	04 Nos	04 Nos	--	--	21C5889 to 21C582.
20	Gate Valve - 14" - 150# - SS – A351 CF8 – F/E – Manual	4879422814	01 Nos	01 Nos	01 Nos	--	--	21C5801
30	Ball Valve - 8" - 300# - CS – 3PC – A216 WCB – F/E – Gear Operated	4802072284	01 Nos	01 Nos	01 Nos	--	--	21C5893
40	Gate Valve - 10" - 150# - SS – A351 CF8M – F/E – Manual	4861482464	13 Nos	13 Nos	13 Nos	--	--	21C5802 to 21C814.
50	Gate Valve - 2" - 150# - SS – A351 CF8M – F/E – Manual	4866021224	06 Nos	06 Nos	06 Nos	--	--	21C5815 to 21C5820.
60	Gate Valve - 8" - 300# - CS – A216 WCB – F/E – Manual	4878112284	02 Nos	02 Nos	02 Nos	--	--	21C5821 to 21C5822.
70	Gate Valve - 4" - 300# - CS – A216 WCB – F/E – Manual	4878111774	04 Nos	04 Nos	04 Nos	--	--	21C5823 to 21C5826.
80	Gate Valve - 4" - 150# - CS – A216 WCB – F/E – Manual	4878111764	54 Nos	54 Nos	54 Nos	--	--	21C5857 to 21C5880.
90	Gate Valve - 8" - 150# - CS – A216 WCB – F/E – Manual	4878112264	05 Nos	05 Nos	05 Nos	--	--	21C5881 to 21C5885.
100	Gate Valve - 12" - 300# - CS – A216 WCB – F/E – Manual	4878112644	01 Nos	01 Nos	01 Nos	--	--	21C5886.
110	Gate Valve - 14" - 150# - CS – A216 WCB – F/E – Manual	4878112814	02 Nos	02 Nos	02 Nos	--	--	21C5887 to 21C5888.

END OF REPORT