

INSITE

Inspection Report

Field Safety Inspection Record

KG-4E Verification Site

KG-4E SILICA-01

Inspection date: August 21, 2026

Inspector: KG4E Verification Inspector

Findings documented: 1

Report generated: August 21, 2026

Executive Summary

1

FINDINGS

0

CRITICAL / HIGH

1

OPEN ACTIONS

Completed

STATUS

RISK DISTRIBUTION

Critical		0
High		0
Moderate		1
Low		0

INSPECTION RECORD

SITE / FACILITY

KG-4E Verification Site

INSPECTION

KG-4E SILICA-01

INSPECTION DATE

August 21, 2026

INSPECTOR

KG4E Verification Inspector

REGULATORY CONTEXT

OSHA - Construction (29 CFR 1926)

ASSESSMENT

This inspection documented 1 finding: 1 Moderate. No Critical or High findings were identified. The moderate-risk findings below should be tracked through corrective action and verified on closure. 1 corrective action was logged for this inspection, of which 1 remains open.

BASIS AND LIMITATIONS

Regulatory context: OSHA - Construction (29 CFR 1926) — set for this inspection. HazLenz AI output is advisory and requires qualified human review; this report reflects findings as reviewed at the time of generation.

Findings Summary

Concise reference of every finding documented in this inspection.

#	HAZARD	RISK	STATUS	ACTION STATUS
1	Silica	Moderate	Finalized	Open

Detailed Findings

Finding 1 — Silica

WHAT WAS OBSERVED

a worker is dry-cutting concrete block with a handheld saw

Risk:

Moderate

Severity 2 · Likelihood 3 · Risk score 6

APPLICABLE STANDARD

29 CFR 1926.1153 — Respirable crystalline silica

HazLenz standard summary: Construction concrete or masonry cutting with visible dust and missing water or vacuum controls supports silica review.

QUALIFIED-PERSON REVIEW

Accepted — KG-4E verification: the qualified reviewer accepted the HazLenz assessment without edit.

RECOMMENDED CORRECTIVE ACTION

Control Silica Exposure

Immediate: Immediate hazard control required to prevent contact/exposure to Silica hazard.

Permanent: Address systemic factors to prevent recurrence.

Verification: Confirm the hazard control effectively removes the exposure.

Status: Open · Priority: High

Assigned To:

NOTES

Corrective Action Summary

Consolidated view of all corrective actions from this inspection for management follow-up.

FINDING	ACTION	OWNER	DUE	STATUS
#1	Control Silica Exposure	Unassigned	—	Open