A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Teknaf, Cox's Bazar.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 4.0m	R. L.: 0.15m below from Road Level.
CLIENT : Orascom Telecom Bangladesh Limited.	DATE OF BORING : 02-11-2008.	G. W. T : 0.061 below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Pale brown 10YR (6/3), medium dense to dense, fine sand, SM.			D-1	8		
1.0m	Light gray 10YR (7/1), dense to medium dense, fine sand with gravel, SM.			D-2	16		
1.45m	Light gray 10YR (7/1), medium dense to very dense, fine sand with gravel, SM.			D-3	10		
				D-4	50		Over
12.0m	**Boring was not possible due to fine sand with gravel.**						

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

ORGANIC

UNDISTURBED SAMPLE

DISTURBED SAMPLE

SHALE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED