A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION:Purba Badeshar, Rashidpur Bazar, Bahubal, Habigang.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 1.52m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 23-03-2012.	G. W. T : 3.05m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
4.0m	Yellowish Brown 7.5YR (6/4), medium plasticity, soft to medium stiff, Clay, CL.		UD-1, UD-2, UD-3, UD-4	D-1, D-2, D-3, D-4	7, 5, 4, 3		
2.0m	Gray 10YR (6/1), medium plasticity, soft to very stiff, Clay, CL.			D-5, D-6	4, 35		
3.0m	White 10YR (8/1), very dense, fine Sand, SM.			D-7, D-8	41, 6		
1.5m	Brown 7.5YR (4/4), medium plasticity, medium stiff to soft, Clay, CL.			D-9, D-10	4, 4		
4.5m	Dark Gray 10YR (4/1), medium plasticity, soft to medium stiff, Clay, CL.			D-11, D-12	9, 35		
6.45m	Dark Gray 10YR (4/1), very dense, fine Sand, SM.			D-13, D-14, D-15, D-16	37, 36, 32, 35		



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2	PROSOIL	BOREHOLE NO: BH-2	
		LOCATION:Purba Badeshar, Rashidpur Bazar, Bahubal, Habigang.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 1.52m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 23-03-2012.	G. W. T : 3.05m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
4.0m	Yellowish Brown 7.5YR (6/4), medium plasticity, soft to medium stiff, Clay, CL.		UD-1, UD-2, UD-3, UD-4	D-1, D-2, D-3, D-4	1: 6; 3: 4; 5: 5; 7: 4		
2.0m	Gray 10YR (6/1), medium plasticity, soft to very stiff, Clay, CL.			D-5, D-6	9: 6; 11: 35		
3.0m	White 10YR (8/1), very dense, fine Sand, SM.			D-7, D-8	13: 40; 15: 7		
1.5m	Brown 7.5YR (4/4), medium plasticity, medium stiff to soft, Clay, CL.			D-9	17: 3		
4.5m	Dark Gray 10YR (4/1), medium plasticity, soft to medium stiff, Clay, CL.			D-10, D-11	19: 5; 21: 10		
6.45m	Dark Gray 10YR (4/1), very dense, fine Sand, SM.			D-12, D-13, D-14, D-15, D-16	23: 36; 25: 34; 27: 38; 29: 33; 31: 34		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

- PLASTIC CLAY
- SHALE
- SILT
- SAND
- PEAT/HIGHLY ORGANIC SOIL
- MICACEOUS FINE SAND/SILT
- UNDISTURBED SAMPLE
- DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2	PROSOIL	BOREHOLE NO: BH-3	
		LOCATION:Purba Badeshar, Rashidpur Bazar, Bahubal, Habigang.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 1.52m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 24-03-2012.	G. W. T : 3.05m below from E. G. L.



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED