A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Munshiganj, Shatkhira.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 19.95m	R. L.: 1.57m below from Road Level.
CLIENT : Grameen Phone Ltd.	DATE OF BORING : 25-03-2005	G. W. T : 0.96m below from E.G.L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Remarks
2.0m	Gray 10YR(6/1), medium plastic, very soft, silty Clay, CL.			D-1, D-2	2, 1		
1.0m	Gray 10YR(5/1), low plastic, very soft, clayey silt, ML.			D-3	2		
2.0m	Gray color 10YR(5/1), non plastic, loose, sandy Silt, SM.			D-4	2		
1.0m	Reddish gray color 10YR(5/1), very loose, fine sand, with mica, SM.			D-5	1		
1.5m	Gray color 5YR(6/1), medium plastic, very soft, silty Clay, CL.			D-6	2		
6.0m	Light gray Gley1(7/1), medium dense to dense, fine sand, SM.			D-7, D-8, D-9, D-10, D-11	7, 9, 13, 17, 45		
6.45m	Light bluish gray Gley2(7/1), very dense, fine sand, SM.			D-12, D-13, D-14, D-15	50, Over; 50, Over; 50, Over; 50, Over		



ID FOR BOREHOLOG A RAIN SIZE DISTRIBU

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

UNDISTURBED SAMPLE

ORGANIC

DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED