A2	PROSOIL	BOREHOLE NO: BH-01	
		LOCATION : Nazirpur, Begumganj, Noakhali.	
PROJECT : Proposed Eight Storied Building.		DEPTH OF BORING : 15.0m	**R. L. : Road Level.**
CLIENT : Nazrul Islam.		DATE OF BORING : 03-01-2017	B. W. T : 1.5m below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
3.0m	Rubbish		1.5	1.95	1	1	1	2	D-1	2	
			3	3.45	1	1	2	3	D-2	3	
1.5m	Brown 7.5YR (5/3), very loose, low Plasticity Silt with Sand, ML.		4.5	4.95	4	7	8	15	D-3	15	
			6	6.45	4	8	10	18	D-4	18	
			7.5	7.95	3	6	13	19	D-5	19	
10.5m	Gray 7.5YR (5/1), medium dense to dense, silty Sand, SM.		9	9.45	7	13	19	32	D-6	32	
			10.5	10.95	6	12	13	25	D-7	25	
			12	12.45	9	13	15	28	D-8	28	
			13.5	13.95	8	14	15	29	D-9	29	
0.45m	Gray 7.5YR (5/1), medium dense, low Plasticity silt with Sand, ML.		15	15.45	3	5	8	13	D-10	13	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY	SILT	PEAT/HIGHLY ORGANIC SOIL	UNDISTURBED SAMPLE
MICACEOUS FINE SAND/SILT	SAND	SHALE	DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2 PROSOIL	BOREHOLE NO: BH-02	
	LOCATION : Nazirpur, Begumganj, Noakhali.	
PROJECT : Proposed Eight Storied Building.	DEPTH OF BORING : 18.0m	**R. L. : Road Level.**
CLIENT : Nazrul Islam.	DATE OF BORING : 04-01-2017	B. W. T : 1.5m above from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
3.0m	Rubbish.										
			3	3.45	1	1	3	4	D-2	4	
1.5m	Brown 7.5YR (5/3), loose, low Plasticity Silt with Sand, ML.		4.5	4.95	4	6	7	13	D-3	13	
			6	6.45	3	8	11	19	D-4	19	
			7.5	7.95	4	8	12	20	D-5	20	
10.5m	Gray 7.5YR (5/1), medium dense to dense, silty Sand, SM.		9	9.45	8	11	13	24	D-6	24	
			10.5	10.95	9	11	14	25	D-7	25	
			12	12.45	9	18	14	32	D-8	32	
			13.5	13.95	8	13	14	27	D-9	27	
			15	15.45	2	3	6	9	D-10	9	
1.5m	Gray 7.5YR (5/1), loose, Non Plasticity Silt with Sand, ML.		16.5	16.95	5	13	15	28	D-11	28	
1.95m	Gray 7.5YR (5/1), medium dense to dense, silty Sand, SM.		18	18.45	10	15	20	35	D-12	35	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2	PROSOIL	BOREHOLE NO: BH-03	
		LOCATION : Nazirpur, Begumganj, Noakhali.	
PROJECT : Proposed Eight Storied Building.		DEPTH OF BORING : 18.0m	**R. L. : -1.5m.**
CLIENT : Nazrul Islam.		DATE OF BORING : 05-01-2017	B. W. T : 1.4m below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
3.0m	Brown 7.5YR (5/3), very loose, Non Plasticity Silt with Sand, ML.		1.5	1.95	1	1	1	2	D-1	2	
			3	3.45	3	4	6	10	D-2	10	
			4.5	4.95	5	7	9	16	D-3	16	
			6	6.45	4	7	10	17	D-4	17	
10.5m	Gray 7.5YR (5/1), medium dense, silty Sand, SM.		7.5	7.95	9	10	17	27	D-5	27	
			9	9.45	7	8	16	24	D-6	24	
			10.5	10.95	8	10	15	25	D-7	25	
			12	12.45	8	12	16	28	D-8	28	
			13.5	13.95	2	3	4	7	D-9	7	
1.5m	Gray 7.5YR (5/1), loose, low Plasticity Silt with Sand, ML.		15	15.45	8	10	15	25	D-10	25	
3.45m	Gray 7.5YR (5/1), medium dense, silty Sand, SM.		16.5	16.95	10	13	15	28	D-11	28	
			18	18.45	11	14	17	31	D-12	31	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2	PROSOIL	BOREHOLE NO: BH-04	
		LOCATION : Nazirpur, Begumganj, Noakhali.	
PROJECT : Proposed Eight Storied Building.		DEPTH OF BORING : 18.0m	R. L. : Road Level.
CLIENT : Nazrul Islam.		DATE OF BORING : 05-01-2017	B. W. T : 1.5m above from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
4.5m	Brown 7.5YR (5/3), very loose, low Plasticity Silt with Sand, ML.		1.5	1.95	1	1	1	2	D-1	2	
			3	3.45	1	1	2	3	D-2	3	
			4.5	4.95	5	7	7	14	D-3	14	
10.5m	Gray 7.5YR (5/1), medium dense, silty Sand, SM.		6	6.45	5	8	7	15	D-4	15	
			7.5	7.95	6	9	11	20	D-5	20	
			9	9.45	8	10	13	23	D-6	23	
			10.5	10.95	8	11	14	25	D-7	25	
			12	12.45	9	12	15	27	D-8	27	
			13.5	13.95	7	12	14	26	D-9	26	
			15	15.45	2	5	5	10	D-10	10	
1.5m	Gray 7.5YR (5/1), loose, low Plasticity Silt with Sand, ML.		16.5	16.95	8	11	15	26	D-11	26	
1.95m	Gray 7.5YR (5/1), medium dense, silty Sand, SM.		18	18.45	10	14	16	30	D-12	30	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2 PROSOIL	BOREHOLE NO: BH-05	
	LOCATION : Nazirpur, Begumganj, Noakhali.	
PROJECT : Proposed Eight Storied Building.	DEPTH OF BORING : 18.0m	**R. L. : Road Level.**
CLIENT : Nazrul Islam.	DATE OF BORING : 06-01-2017	B. W. T : 1.5m below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
3.0m	Rubbish.		3	3.45	1	1	1	2	D-2	2	
1.5m	Brown 7.5YR (5/3), very loose, low Plasticity Silt with Sand, ML.		4.5	4.95	4	6	7	13	D-3	13	
10.5m	Gray 7.5YR (5/1), medium dense, silty Sand, SM.		6	6.45	5	7	9	16	D-4	16	
			7.5	7.95	7	11	13	24	D-5	24	
			9	9.45	8	13	14	27	D-6	27	
			10.5	10.95	8	12	15	27	D-7	27	
			12	12.45	9	13	16	29	D-8	29	
			13.5	13.95	7	11	14	25	D-9	25	
			15	15.45	2	4	5	9	D-10	9	
1.5m	Gray 7.5YR (5/1), loose, Non Plasticity Silt with Sand, ML.		16.5	16.95	8	10	14	24	D-11	24	
1.95m	Gray 7.5YR (5/1), medium dense, silty Sand, SM.		18	18.45	9	11	15	26	D-12	26	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BOREHOLE AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2 PROSOIL	BOREHOLE NO: BH-06	
	LOCATION : Nazirpur, Begumganj, Noakhali.	
PROJECT : Proposed Eight Storied Building.	DEPTH OF BORING : 18.0m	**R. L. : Road Level.**
CLIENT : Nazrul Islam.	DATE OF BORING : 06-01-2017	B. W. T : 1.5m below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
3.0m	Rubbish.		3	3.45	1	2	2	4	D-2	4	
1.5m	Brown 7.5YR (5/3), loose, Non Plasticity Silt with Sand, ML.		4.5	4.95	4	6	8	14	D-3	14	
10.5m	Gray 7.5YR (5/1), medium dense to dense, silty Sand, SM.		6	6.45	4	8	8	16	D-4	16	
			7.5	7.95	5	9	11	20	D-5	20	
			9	9.45	8	15	16	31	D-6	31	
			10.5	10.95	7	13	15	28	D-7	28	
			12	12.45	8	13	16	29	D-8	29	
			13.5	13.95	7	12	14	26	D-9	26	
			15	15.45	3	5	5	10	D-10	10	
3.5m	Gray 7.5YR (5/1), loose to medium dense, low Plasticity Silt with Sand, ML.		16.5	16.95	9	13	15	28	D-11	28	
			18	18.45	10	14	16	30	D-12	30	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BOREHOLE AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED