A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION : Osmanpur, Mirsorai, Chittagong.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING : 21.0m	R. L.: On Road Level.
CLIENT : Warid Telecom International Ltd.		DATE OF BORING: 14-01-2011.	G. W. T : 3.05m below from E.G.L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
3.0m	Grayish Brown 7.5YR (5/2), medium plasticity, soft to very soft, silty Clay, CL.		UD-1	D-1	4		
			UD-2	D-2	1		
3.0m	Gray 7.5YR (5/1), low plasticity, very soft to stiff, silty Clay, CL.		UD-3	D-3	3		
				D-4	13		
1.5m	Gray 7.5YR (5/1), medium dense to loose, fine Sand, SM.			D-5	4		
1.5m	Gray 7.5YR (5/1), loose to dense, sandy Silt, ML.			D-6	22		
				D-7	22		
				D-8	23		
				D-9	25		
12.45m	Gray 7.5YR (5/1), dense, fine Sand, SM.			D-10	17		
				D-11	20		
				D-12	22		
				D-13	26		
				D-14	27		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY	SAND	SHALE	UNDISTURBED SAMPLE
MICACEOUS FINE SAND/SILT	SILT	PEAT/HIGHLY ORGANIC SOIL	DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED