A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Mahilara Bazar, Barisal.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 0.46m below from Road Level.
CLIENT : AXIATA (Bangladesh) Ltd.		DATE OF BORING: 26-03-2010.	G. W. T : 3.05m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
3.0m	Graish Brown 10YR (5/2), medium plasticity, soft to medium stiff Clay, CL.		UD-1, UD-2	D-1, D-2, D-3	4, 5, 7		
1.0m	Light bluish Gray Gley2 (7/1), medium dense to very loose Silt, ML.			D-4	2		
1.0m	Very dark Brown 7.5YR (2.5/3), low plasticity, Organic Silt, OL.			D-5	2		
4.0m	Light bluish Gray Gley2 (7/1), very loose to loose Silt, ML.			D-6, D-7, D-8	3, 4, 6		
1.5m	Light bluish Gray Gley2 (7/1), loose to medium dense, silty Sand, SM.			D-9	5		
10.95m	Light bluish Gray Gley2 (7/1), dense, medium to fine Sand, SP.			D-10, D-11, D-12, D-13, D-14, D-15, D-16, D-17	19, 28, 18, 19, 21, 25, 23, 24		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SAND | SILT | SHALE

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED