A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION: Baqchor Bazaar, Sadar, Chapai Nawabganj.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING: 21.0m	R. L.: 0.31m below from Road Level.
CLIENT : Grameenphone Ltd.	DATE OF BORING: 07-08-2010.	G. W. T : 5.49m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
4.0m	Light bluish Gray Gley2 (7/1), medium dense, Silt, ML.			D-1 to D-3	7, 7, 7		
12.5m	Light bluish Gray Gley2 (7/1), medium dense to dense, fine sand, SM.			D-4 to D-10	8, 8, 10, 12, 16, 18, 22		
4.5m	Bluish Gray Gley2 (6/1), dense, fine Sand, SM.			D-11 to D-15	22, 23, 21, 20, 22		
0.45m	Light bluish Gray Gley2 (7/1), dense, fine Sand with quartz pebble, SM.			D-16	27		



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED