A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Lamakazi Bazar, Bishwanath, Sylhet.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 21.0m	R. L.: 2.13m below from Road Level.
CLIENT : Grameen Phone Ltd.	DATE OF BORING : 31-10-2005	G. W. T : 0.15m above from E.G.L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Remarks
2.0m	Very pale brown 10YR (7/3), medium plastic, very soft, silty Clay, CL.		UD-1	D-1	2		
2.0m	Gray 10YR (6/1), low plastic, very soft, clayey Silt, ML.			D-2, D-3	2, 3		
3.5m	Gray 10YR (6/1), medium plastic, soft to medium stiff, silty Clay, CL.		UD-4	D-4, D-5, D-6	5, 6, 5		
1.5m	Light gray 10YR (7/2), dense, fine sand, SM.			D-7	27		
3.0m	Gray 10YR (6/1), medium dense, cohesionless silt, SM.			D-8, D-9	10, 18		
1.5m	Light gray 10YR (7/1), dense, fine sand, SM.			D-10	21		
7.95m	Light gray 10YR (7/1), very dense, fine sand, SM.			D-11, D-12, D-13, D-14, D-15, D-16	35, 50, 50, 50, 50, 50		Over

ID FOR BORELOG A RAIN SIZE DISTRIBU

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

UNDISTURBED SAMPLE

ORGANIC

DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED